CITY OF WHITING, INDIANA
ADA TRANSITION PLAN

November 1, 2011

Prepared by:
Bob Kark
Program Access Coordinator

COMPLETE PLAN

November 20, 2012 Amended by Board of Public Works

Section 1: Executive Summary

Introduction

The City of Whiting began working on the Americans with Disabilities Act (ADA) Transition Plan in September 2011. The main purpose of this project is to develop the City's policies and practices for implementing physical pedestrian improvements within the public right-of-way of the City of Whiting. The goal is to optimize the pedestrian experience, to provide safe and usable pedestrian facilities for all pedestrians, and to assure compliance with all federal, state, and local regulations and standards.

The ADA Transition Plan is intended to represent both the legal and functional goals and objectives of the City to make the existing pedestrian facilities within the incorporated City right-of-way accessible and usable for persons with disabilities.

The ADA requires all public agencies to develop an ADA Transition Plan for the installation of curb ramps or other sloped areas at all locations where walkways cross curbs. The plan must include a schedule for curb ramp installation and for other improvements necessary to achieve programmatic accessibility for persons with disabilities. The main purpose of this ADA Transition Plan is to describe the curb ramp and other pedestrian facility needs in the City, and to outline the recommended procedures for implementing and scheduling remedial work to provide a complying system of curb ramps, pedestrian signals and sidewalks.

The ADA Transition Plan include streets and roadways, vehicular and pedestrian bridges, underground and above-ground utilities, vehicular and pedestrian signal systems, signage systems, on-street parking facilities, sidewalks with curb ramps at intersections, planting strips and buffers, pedestrian activity areas and unimproved open spaces.

Section 2: Introduction and Administrative Information

Introduction to the ADA

The Americans with Disabilities Act (ADA), enacted on July 26, 1990, provides comprehensive civil rights protections to persons with disabilities in the areas of employment, state and local government services, access to public accommodations, transportation and telecommunications. The ADA is companion civil rights legislation with the Civil Rights Act of 1964 and Section 504 of the Rehabilitation Act of 1973. This legislation mandates that qualified disabled individuals shall not be excluded from participation in, denied the benefit of, or be subjected to discrimination under any program or activity. The Act also protects employees with disabilities, with certain

protections and requires employers to make reasonable accommodation for applicants and employees with disabilities.

Title II: Public Services

Title II prohibits state and local governments from discriminating against persons with disabilities or from excluding participation in or denying benefits of programs, services or activities to persons with disabilities. It is under this Title that this ADA Transition Plan has been prepared. The ADA Transition Plan is intended to outline the methods by which physical or structural changes will be made to effect the non-discrimination policies described in Title II.

Title II of the ADA dictates that a public entity must evaluate its services, programs, policies and practices to determine whether they are in compliance with the nondiscrimination regulations of the ADA. The regulations detailing compliance requirements were issued in July 1991. A self-evaluation also is required. It is intended to examine activities and services, identify problems or barriers that may limit accessibility by persons with disabilities, and describe potential compliance solutions. The entity then must proceed to make the necessary changes resulting from the self-evaluation. The ADA further requires that an ADA transition plan be prepared to describe any structural or physical changes required to make programs accessible.

In the ADA, the term disability means, with respect to an individual:

(1) a physical or mental impairment that substantially limits one or more of the major life activities of such individual;
(2) a record of such an impairment; or
(3) being regarded as having such an impairment.

If an individual meets any one of these three tests, that person is considered to be an individual with a disability for purposes of coverage under the Americans with Disabilities Act. The Final Rules of the ADA describe in greater detail the conditions included and excluded as disabilities under the ADA.

Section 2.1: City Responsibilities under the ADA

The City of Whiting has various responsibilities under Title II of the ADA. Title II of the ADA is similar to Section 504 of the Rehabilitation Act of 1973, but differs in that Section 504 applies only to government agencies that receive federal financial assistance. The purpose of Section 504 is to ensure that no otherwise qualified individual with disabilities shall, solely by reason of disability, be discriminated against under any program or activity receiving federal financial assistance. The City of Whiting has been subject to and operating under the requirements of Section 504 for many years.

The ADA intends not to apply lesser standards than are required under other federal, state or local laws; therefore, the law that is the most stringent has precedence. This intent has particular application with respect to City obligations under Section 504, which in some cases, exceed ADA requirements with respect to structural and physical changes.

Title II also mandates that City governments may not require eligibility criteria for participation in programs and activities that would screen persons with disabilities, unless it can be proven that such requirements are necessary for the mandatory provision of the service or program. A public entity must reasonably modify its policies and procedures to avoid discrimination toward disabled residents. Nevertheless, if the public entity can demonstrate that a modification fundamentally would alter the nature of its service, it would not be required to make that modification.

The lone exception to these requirements would be because of undue hardship. Undue hardship is defined in the ADA as an "action requiring significant difficulty or expense" when considering the nature and cost of the accommodation in relation to the size, resources and structure of the specific operation. Undue hardship is determined on a case-by-case basis.

A public entity also is required to designate a person to be responsible for coordinating the implementation of ADA requirements and for investigating complaints of alleged noncompliance. At the time of the ADA Transition Plan preparations, for the intent of this portion of the ADA Transition Plan that relates to streets, sidewalks and public rights-of-way, that designated person is Robert Kark , Program Access Coordinator, City of Whiting, 1443 119th Street, Whiting, IN 46394, Telephone (219) 659-7700.

Section 2.2: ADA Transition Plan Requirements

According to ADA, a public agency is required to prepare an ADA Transition Plan if physical or structural modifications to facilities are required to provide access to programs or services. Title II of the ADA regulates government agencies, with its primary goal being to ensure that all of their programs and services are accessible to individuals with disabilities. The ADA Transition Plan is limited to evaluating physical barriers; however, an analysis of the programs and services rendered by the City also is important to determine what physical changes are necessary. The ADA Transition Plan documents what actions the City of Whiting will take to alter its facilities. The ADA requires that the ADA Transition Plan be submitted for public review before final approval and adoption by the appropriate regulatory agency.

The ADA Transition Plan contains detailed physical barrier surveys of City streets, curb ramps and related facilities. These surveys are being taken at the time of the development of this transition plan. The survey does not provide a complete listing of complying architectural or physical features.

In creating priorities, it is the City's intent to evaluate all areas of potential deficiency, and to make structural changes where necessary. The assignment of priorities is intended

to facilitate public review and to address specific concerns of the local disabled community. It must be emphasized that it is the intent for all individuals with disabilities to be reasonably accommodated by the City of Whiting

Section 3: Public Participation and Input

Section 3.1 Introduction

The ADA states that a public entity is required to make available to applicants, participants, residents and other interested parties information regarding the ADA Transition Plan and its applicability to the services, programs or activities of the public entity, and to apprise the public of the protections against discrimination afforded to them by the ADA. A public entity also is required to provide an opportunity for interested persons, including individuals with disabilities or organizations representing individuals with disabilities, to participate in the development of the ADA Transition Plan by submitting comments and making specific recommendations. The ADA also requires that a copy of the draft ADA Transition Plan shall be made available for public inspection during a formal public review period.

Section 3.2: Community Participation

The City of Whiting will set up the ADA Transition Plan project to encourage and facilitate the maximum degree of public participation. This process included persons with disabilities and those representing disability service organizations. The outreach efforts included the following components as shown in bullet points and described in more detail below:

- Web Site
- Press Releases
- Public Information Workshops
- Consumer Survey

The community ultimately will be able to submit formal comments about this ADA Transition Plan, either in written form or at a public hearing, per ADA requirements.

Section 3.3: ADA Transition Plan Public Review and Comment Period

A public entity that employs 50 or more people is required to seek public input on its ADA Transition Plan. Beyond the legal requirements, such input is vital to assure that those affected by the City's programs, services and facilities understand the scope and nature of City's responsibilities for providing equal access to the public.

Section 3.4: ADA Grievance Procedures

A public entity that employs 50 or more persons is required by the ADA to adopt and publish grievance procedures providing for prompt and equitable resolution of complaints or grievances alleging any action that would be prohibited by Title II of the ADA. The City of Whiting grievance procedure is described below. Any person with a disability or any parent or guardian who represents a minor person with a disability, who believes that they have been the subject of disability-related discrimination on the basis of the denial of access to facilities, programs or services, may file a grievance or complaint.

GRIEVANCE PROCEDURE

The City of Whiting has adopted an internal grievance procedure for prompt and equitable resolutions of complaints alleging any action prohibited by the Americans with Disabilities Act. Any individual who feels he or she has received treatment inconsistent with the policies and provisions of the Americans with Disabilities Act (ADA) may file a grievance with the City of Whiting by following these steps:

Complaints should be addressed to: Robert Kark, ADA Coordinator, 1443 119th Street, Whiting, Indiana 46394, who has been designated to coordinate ADA compliance efforts.

1. A complaint should be filed in writing, contain the name and address of the person filing the complaint (the "complainant"), and describe in particularity the alleged violation of the American with Disabilities Act. Upon request, the Coordinator will provide to any individual a Grievance Form to facilitate filing of such a grievance.
2. A complaint should be filed within 30 days after the complainant becomes aware of the alleged violation.
3. An investigation, as may be appropriate, shall follow a filing of a complaint. These rules contemplate informal but thorough investigations, affording all interested parties and their representatives, if any, an opportunity to submit evidence relevant to a complaint.
4. A written determination as to the validity of the complaint shall be issued by the ADA Coordinator and a copy forwarded to the complainant no later than 30 days

after its filing. If the Coordinator determines that a violation exists, he or she shall also determine the manner in which the City will abate the violation.

5. The ADA Coordinator will maintain the files and records of the City of Whiting relating to the complaints filed.
6. The complainant can request a reconsideration of the case where he or she is unsatisfied with the resolution of the grievance. The request for reconsideration should be made within 30 days after the written determination of the ADA Coordinator is issued.
7. The request for reconsideration should be made to the Board of Public Works and Safety by filing a written request for reconsideration with the Office of the Clerk Treasurer. The request for reconsideration should include the complainant's name and address, date the ADA Coordinator's determination was issued, and any additional information relevant to the complaint. To facilitate the individual's request for reconsideration, the complainant may obtain from the Office of the Clerk Treasurer a form suitable for this purpose.
8. A review of the ADA Coordinator's determination shall follow the filing of a request for reconsideration. Upon review, the Board of Public Works and Safety shall affirm, modify or overturn the decision of the ADA Coordinator.
9. A written decision as to the validity of the ADA Coordinator's determination shall be issued by the Board of Public Works and Safety and a copy forwarded to the complainant no later than 30 days after its filing.
10. The right of a person to a prompt and equitable resolution of the complaint filed hereunder shall not be impaired by the person's pursuit of other remedies.

Assistance in filling out the following documents is available by contacting Bob Kark at (219) 659 7700 extension 235. Individuals with hearing impairments may contact us through the Indiana Relay Service.

Requests for alternate formats please contact Bob Kark at (219) 659 7700 extension 235 or your bkark@whitingindiana.com . Individuals with hearing impairments may contact us through the Indiana Relay Service.

ADA GRIEVANCE FORM

Complainant:_____

Address:_____

City, State and Zip Code:_____

Telephone: Home: _____ **Business:** _____

Person Discriminated Against:
(if other than the complainant)_____

Address:_____

City, State and Zip Code:_____

Telephone: Home: _____ **Business:** _____

Describe the acts of discrimination providing the name(s) where possible of the individuals who discriminated:_____

_____

_____

Date of when the discrimination occurred:_____

Has the complaint been filed with any other Federal, State or local civil rights agency or court? **Yes**_____ **No**_____

_____

_____

Signature:_____

Date:_____

Return to:
City of Whiting Board of Public Works and Safety
Attn: Mark Adam
1443 119th Street
Whiting, IN 46394

Assistance in filling out the document is available by contacting Bob Kark at (219) 659 7700 extension 235. Individuals with hearing impairments may contact us through the Indiana Relay Service.

Requests for alternate formats please contact Bob Kark at (219) 659 7700 extension 235 or your bkark@whitingindiana.com . Individuals with hearing impairments may contact us through the Indiana Relay Service.

ADA GRIEVANCE FORM
****Request for Reconsideration****

Complainant:_____

Address:_____

City, State and Zip Code:_____

Telephone: Home: _____ **Business:** _____

Person Discriminated Against:
(if other than the complainant)_____

Address:_____

City, State and Zip Code:_____

Telephone: Home: _____ **Business:** _____

Describe the acts of discrimination providing the name(s) where possible of the individuals who discriminated:_____

_____

_____

_____

Date of when the discrimination occurred:_____

Have efforts been made to resolve this complaint through the internal grievance procedure? Yes_____ **No**_____

If yes, what is the status of the grievance?_____

_____

_____

Date of the ADA Coordinator's determination:_____

Has the complaint been filed with any other Federal, State or local civil rights agency or court? Yes_____ No_____

Signature:_____

Date:_____

Return to:
City of Whiting Board of Public Works and Safety
Attn: Mark Adam
1443 119th Street
Whiting, IN 46394

Assistance in filling out the document is available by contacting Bob Kark at (219) 659 7700 extension 235. Individuals with hearing impairments may contact us through the Indiana Relay Service.

Requests for alternate formats please contact Bob Kark at (219) 659 7700 extension 235 or your bkark@whitingindiana.com . Individuals with hearing impairments may contact us through the Indiana Relay Service.

Section 4: Inventory Methodology and Findings

Section 4.1: Purpose and Summary of the Inventory

The City of Whiting has a wide variety of facilities within the public right-of-way. These facilities include streets and roadways, vehicular and pedestrian bridges, underground and above-ground utilities, vehicular and pedestrian signal systems, signage systems, on-street parking facilities, sidewalks with curb ramps at intersections, improved planting strips, buffers, and pedestrian activity areas, and unimproved open spaces or natural areas. The goal of the overall project is to optimize the pedestrian experience and to provide safe and usable pedestrian facilities for all pedestrians, and to assure compliance with all federal, state, and local regulations and standards.

A six-month long period of surveying pedestrian facilities will be undertaken in the Spring of 2012 to document existing conditions within the public rights-of-way under the jurisdiction of the City of Whiting. Surveying, as used in this section, refers to visiting the particular location by a trained accessibility surveyor, and obtaining measurements, dimensions, gradients or other visual determinations as may be appropriate depending on the particular location.

Section 4.2: ADA Data Collection Items

For detailed measurements at or near intersections, the survey team will collect and analyze the following data:

Sidewalk and Pathway Clear Width: Check for narrowness.

Sidewalk and Pathway Cross Slope: Steepness, Irregularity, Variability, Warping

Landings Along Sidewalks and Pathways: Less than 4 feet by 4 feet.

Sidewalk and Pathway Grade: Steepness, Angle Points

Materials and Finishes: Deterioration of Surfaces, Deterioration of Markings, Appropriateness of material.

Gratings: Grating Type, Grate Opening Orientation

Discontinuities: Missing Sections, Gaps, Drops, Steps

Detectable Warning System: Missing, Inappropriate Materials, Inadequate Size, Wrong Location

Obstructions: Signs, Mail Boxes, Fire Hydrants, Benches, Telephones, Traffic Signal Poles, Traffic Signal Controller Boxes, Newspaper Boxes, Drainage Structures, Tree Grates, Pole Mounted Objects, Standing Water, Snow or Ice.

Traffic Signal Systems: Lack of Provision for the Visually Impaired such as APS, Inadequate Time Allowed, Inoperable Buttons, Inaccessible Buttons

Curb Ramp: Missing, Doesn't Fall within Marked Crosswalk, Doesn't Conform to Guidelines

Curb Ramp Flares: Missing Where Required, Too Steep

Standards set for each of the above are referenced in PROWAC Guide: http://www.access-board.gov/prowac/guide/PROWGuide.htm and the ADA Act of 1990 http://www.ada.gov/pubs/ada.htm

Section 4.3: Inventory

The City of Whiting took inventory of all the existing pedestrian facilities and facilities within the public right-of-way. These facilities include buildings, streets and roadways, vehicular and pedestrian bridges, underground and above-ground utilities, vehicular and pedestrian signal systems, signage systems, on-street parking facilities, sidewalks with curb ramps at intersections, improved planting strips, buffers, and pedestrian activity areas, and unimproved open spaces or natural areas. The goal of the overall project is to optimize the pedestrian experience and to provide safe and usable pedestrian facilities for all pedestrians in the City of Whiting. The buildings are compliant.

The inventory scope is city wide and is represented in the follow map of intersection locations. The actual location by location evaluation and survey results are depicted in Appendix A of the document.

WHITING

MAYOR JOSEPH M. STAHURA



Section 5.0: Implementation Plan

The implementation plan for the City of Whiting will be developed and become part of the city's capital plan and five year plan. It should be noted that all new construction will comply with ADA standards. The plan will be directed toward the following priorities:

High Priority Intersections and Roadway Segments

This ADA priority will be given to the work along the 119th Street Business District. This will address the deficiencies in our high trafficked areas of downtown which accommodate our business community and festival venues.

Lower Priority Intersections and Roadway Segments

This priority would encompass ADA compliance in single family residential area and industrial areas.

Section 6: ADA Capital Implementation Plan

The City of Whiting has set aside capital funds in its budget for the next three years for the ADA transition plan.

- 2013 - $3,000
- 2014 - $10,000
- 2015 - $10,000

Based on the above priority system, work will be focused on our 119th Business district first. Referencing the intersection map in Section 4.3, the following priorities will be addressed over the next three year capital periods. Presently our public buildings are ADA compliant. Audible crossing signals in our downtown will become part of our high priority as well.

Intersections 46, 48, 51, 57, 58, and 74 need surface repair in addition to ADA upgrades and should be addressed first.

The following intersections along 119th Street should round out the budget: 43, 44, 45, 47, 49, 50, 50A, 62, 63, 64, 67, 68, 69, 70, 73, and 150.

As the work progresses over time, this document will be updated as to status or completion on the inventory sheets in Appendix A. As a dynamic document, completions and additional needs will always be reflected in the inventory and budget structure.

ADOPTED AND APPROVED at a meeting of the Board of Public Works and Safety on the 15 day of NOVEMBER, 2011.

BOARD OF PUBLIC WORKS

JOSEPH M. STAHURA, MAYOR

MARTY JAKUBOWSKI, MEMBER

MARK HARBIN, MEMBER

ATTEST:

MARK S. ADAM
CLERK-TREASURER

Appendix A

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 01	Date: JULY 13, 2012
Location: ATCHISON & OHIO	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT R.R. TRACKS SE	Curb Ramp E:
Curb Ramp B:	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	"	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A							
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—							
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE							
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.							
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.							
14	What type of transit stop is there? (none, bus, other)	N							
15	What are the dimensions of any common landing for two curb ramps?	— "	"	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	"	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 01	Date: JULY 13, 2012
Location: ATCHISON & OHIO	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT R.R. TRACKS SE	Curb Ramp E:
Curb Ramp B:	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	"	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	2.4 %	%	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	%	%	%	%	%	%	%
		— %	%	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	OHIO							
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.7 %	%	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	"	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.4 %	%	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.9 %	%	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	%	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	"	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	"	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	%	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	%	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	"	"	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 02	Date: JULY 13, 2012
Location: OHIO ALLEY B/T ATCHISON & CLEVELAND	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: NO INFORMATION	Curb Ramp E:
Curb Ramp B:	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D: AVAILABLE	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	"	"	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)								
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?								
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)								
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)								
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)								
14	What type of transit stop is there? (none, bus, other)								
15	What are the dimensions of any common landing for two curb ramps?	"	"	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	"	"	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 02	Date: JULY 13, 2012
Location: OHIO ALLEY B/T ATCHISON & CLEVELAND	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A:	Curb Ramp E:
Curb Ramp B:	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	"	"	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	%	%	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	%	%	%	%	%	%	%	%
		%	%	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?								
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	%	%	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	%	%	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y, or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 03	Date: JULY 13, 2012
Location: CLEVELAND & OHIO	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: ADJ. 1518 CLEVELAND LOOKING AT LAKE SW	Curb Ramp E:
Curb Ramp B: LOOKING AT LAKE SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, Is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	S.S.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	24 "	24 "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 03	Date: JULY 13, 2012
Location: CLEVELAND & OHIO	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: ADJ. 1518 CLEVELAND LOOKING AT LAKE SW	Curb Ramp E:
Curb Ramp B: LOOKING AT LAKE SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.1 %	4.2 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	OHIO	OHIO						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.4 %	3.5 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.1 %	4.2 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.1 %	1.8 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.5 %	2.7 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	.5 "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "B" #27: HIGH CURB TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 04	Date: JULY 13, 2012
Location: OHIO ALLEY B/T CLEVELAND & CENTRAL	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: NO INFORMATION AVAILABLE	Curb Ramp E:
Curb Ramp B:	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	"	"	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)								
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?								
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)								
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)								
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)								
14	What type of transit stop is there? (none, bus, other)								
15	What are the dimensions of any common landing for two curb ramps?	"	"	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	"	"	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 04	Date: JULY 13, 2012
Location: OHIO ALLEY B/T CLEVELAND & CENTRAL	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A:	Curb Ramp E:
Curb Ramp B:	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	"	"	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	%	%	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	%	%	%	%	%	%	%	%
		%	%	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?								
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	%	%	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	%	%	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 05	Date: JULY 18, 2012
Location: CENTRAL & OHIO	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: ADJ. 1540 CENTRAL LOOKING AT LAKE SW	Curb Ramp E:
Curb Ramp B: LOOKING AT LAKE SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	40 "	40 "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 05	Date: JULY 12, 2012
Location: CENTRAL & OHIO	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: ADJ. ISLD CENTRAL LOOKING AT LAKE SW	Curb Ramp E:
Curb Ramp B: LOOKING AT LAKE SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	2.0 %	5.2 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	OHIO	OHIO						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	2.0 %	1.2 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.0 %	5.2 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.2 %	0.3 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.7 %	1.2 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction of grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 06	Date: JULY 13, 2012
Location: OHIO ALLEY B/T CENTRAL & LAPORTE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A:	Curb Ramp E:
Curb Ramp B: NO INFORMATION	Curb Ramp F:
Curb Ramp C: AVAILABLE	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	"	"	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)								
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?								
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)								
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)								
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If Island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control).								
14	What type of transit stop is there? (none, bus, other)								
15	What are the dimensions of any common landing for two curb ramps?	"	"	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	"	"	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 06	Date: JULY 13, 2012
Location: OHIO ALLEY B/T CENTRAL & LAPORTE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A:	Curb Ramp E:
Curb Ramp B:	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	"	"	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	%	%	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	%	%	%	%	%	%	%	%
		%	%	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?								
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	%	%	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	%	%	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 07	Date: JULY 13, 2012
Location: LAPORTE & OHIO	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: ADJ. 1612 LAPORTE LOOKING AT LAKE SW	Curb Ramp E:
Curb Ramp B: LOOKING AT R.R. TRACKS SE	Curb Ramp F:
Curb Ramp C: LOOKING AT OHIO NE	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A					
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—					
5	If a curb ramp is not present, and if a curb is not present, Is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SE	NE					
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.					
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	S.S.	N.C.					
14	What type of transit stop is there? (none, bus, other)	N	N	N					
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	36 "	58 "	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 07	Date: JULY 13, 2012
Location: LAPORTE & OHIO	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: ADJ. 1612 LAPORTE LOOKING AT LAKE SW	Curb Ramp E:
Curb Ramp B: LOOKING AT R.R. TRACKS SE	Curb Ramp F:
Curb Ramp C: LOOKING AT OHIO NE	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	5.7 %	2.7 %	10.2 %	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	%	%	%	%	%
		— %	— %	— %	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	OHIO	OHIO	OHIO					
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	4.7 %	2.3 %	2.6 %	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		5.7 %	2.7 %	10.2 %	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.0 %	0.2 %	0.3 %	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.4 %	4.5 %	2.2 %	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 08	Date: JULY 13, 2012
Location: OHIO ALLEY B/T LAPORTE & SHERIDAN	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A:	Curb Ramp E:
Curb Ramp B: NO INFORMATION	Curb Ramp F:
Curb Ramp C: AVAILABLE	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	"	"	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)								
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?								
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)								
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)								
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)								
14	What type of transit stop is there? (none, bus, other)								
15	What are the dimensions of any common landing for two curb ramps?	"	"	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	"	"	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 08	Date: JULY 13, 2012
Location: OHIO ALLEY B/T LAPORTE & SHERIDAN	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A:	Curb Ramp E:
Curb Ramp B:	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	"	"	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	%	%	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	%	%	%	%	%	%	%	%
		%	%	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?								
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	%	%	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	%	%	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 08.A	Date: JULY 13, 2012
Location: SHERIDAN & OHIO	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT TENNIS COURTS NE	Curb Ramp E:
Curb Ramp B: LOOKING AT PARKING LOT NW	Curb Ramp F:
Curb Ramp C: LOOKING AT TENNIS COURTS SW	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	72"	72"	—"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A					
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	V					
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NW	SW					
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	IRR.	IRR.	IRR.					
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	S.S.	S.S.					
14	What type of transit stop is there? (none, bus, other)	N	N	N					
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	—"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	62"	72"	—"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 08.A	Date: JULY 13, 2012
Location: SHERIDAN & OHIO	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT TENNIS COURTS	NE	Curb Ramp E:	
Curb Ramp B: LOOKING AT PARKING LOT	NW	Curb Ramp F:	
Curb Ramp C: LOOKING AT TENNIS COURTS	SW	Curb Ramp G:	
Curb Ramp D:		Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	.50 "	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	1.0 %	4.2 %	5.8 %	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	%	%	%	%	%
		6.1 %	7.6 %	— %	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	SHER-IDAN	SHER-IDAN	OHIO					
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	6.4 %	4.6 %	5.7 %	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.0 %	4.2 %	5.8 %	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.8 %	1.1 %	0.5 %	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	2.8 %	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	.5 "	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES	YES	— %	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	~~Y~~ or N	~~Y~~ or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	"	"	"	"	"

Comments: C.R."C" #27: HIGH CURB TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 09	Date: JULY 12, 2012
Location: ATCHISON & 116th	Surveyors: B. WASVODA

Describe each curb ramp's location:			
Curb Ramp A:	LOOKING AT 116th STREET	NE	Curb Ramp E:
Curb Ramp B:	LOOKING AT 1550 ATCHISON	NE	Curb Ramp F:
Curb Ramp C:	LOOKING AT LAKE	SE	Curb Ramp G:
Curb Ramp D:	LOOKING AT 1604 ATCHISON	SE	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NE	SE	SE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	72 x 72 "	72 x 72 "	72 x 72 "	72 x 72 "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 09	Date: JULY 12, 2012
Location: ATCHISON & 116th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 116th STREET	NE	Curb Ramp E:	
Curb Ramp B: LOOKING AT 1550 ATCHISON	NE	Curb Ramp F:	
Curb Ramp C: LOOKING AT LAKE	SE	Curb Ramp G:	
Curb Ramp D: LOOKING AT 1604 ATCHISON	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	4.2 %	1.6 %	13.5 %	7.2 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	116	ATCH-ISON	116	ATCH-ISON				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	2.6 %	1.9 %	9.9 %	5.0 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.2 %	1.6 %	13.5 %	7.2 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.9 %	1.0 %	1.2 %	0.1 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.5 "	2.5 "	1.0 "	.5 "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 10	Date: JULY 12, 2012
Location: 116th ALLEY BETWEEN ATCHISON & CLEVELAND	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A:	LOOKING AT CLEVELAND	SW	Curb Ramp E:
Curb Ramp B:	LOOKING AT ATCHISON	SE	Curb Ramp F:
Curb Ramp C:	LOOKING AT ATCHISON	NE	Curb Ramp G:
Curb Ramp D:	LOOKING AT CLEVELAND	NW	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SE	NE	NW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 10	Date: JULY 12, 2012
Location: 116th ALLEY BETWEEN ATCHISON & CLEVELAND	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT CLEVELAND	SW	Curb Ramp E:	
Curb Ramp B: LOOKING AT ATCHISON	SE	Curb Ramp F:	
Curb Ramp C: LOOKING AT ATCHISON	NE	Curb Ramp G:	
Curb Ramp D: LOOKING AT CLEVELAND	NW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.7 %	0.2 %	0.1 %	0.4 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	CLEVE-LAND	ATCH-ISON	ATCH-ISON	CLEVE LAND				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	— %	0.9 %	0.5 %	2.2 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.7 %	0.2 %	0.1 %	0.4 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.3 %	1.2 %	1.3 %	1.8 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" # 32 : DRIVEWAY

C.R. "B" # 32 : DRIVEWAY

C.R. "C" # 32 : DRIVEWAY

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 11	Date: JULY 12, 2012
Location: CLEVELAND & 116th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 116th	NW	Curb Ramp E: LOOKING AT LAKE	SE
Curb Ramp B: LOOKING AT 1547 CLEVELAND	NW	Curb Ramp F: LOOKING AT 1600 CLEVELAND	SE
Curb Ramp C: LOOKING AT 1546 CLEVELAND	NE	Curb Ramp G: LOOKING AT LAKE	SW
Curb Ramp D: LOOKING AT 116th	NE	Curb Ramp H: LOOKING AT 1601 CLEVELAND	SW

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	72"	72"	72"	72"	72"	72"	72"	72"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	B	B	B	B	B	B	B	B
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	—
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NW	NE	NE	SE	SE	SW	SW
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	N.C.	S.S.	S.S.	S.S.	S.S.
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	N
15	What are the dimensions of any common landing for two curb ramps?	72x72"	72x72"	72x72"	72x72"	71x72"	71x72"	72x72"	72x72"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	24"	24"	24"	24"	24"	24"	24"	24"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 11	Date: JULY 12, 2012
Location: CLEVELAND & 116th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 116th	NW	Curb Ramp E: LOOKING AT LAKE	SE
Curb Ramp B: LOOKING AT 1547 CLEVELAND	NW	Curb Ramp F: LOOKING AT 1600 CLEVELAND	SE
Curb Ramp C: LOOKING AT 1546 CLEVELAND	NE	Curb Ramp G: LOOKING AT LAKE	SW
Curb Ramp D: LOOKING AT 116th	NE	Curb Ramp H: LOOKING AT 1601 CLEVELAND	SW

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	— "	— "	— "	— "
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	4.5 %	7.3 %	7.7 %	8.9 %	5.4 %	9.3 %	7.0 %	4.1 %
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	— %	— %	— %	— %
		— %	— %	— %	— %	— %	— %	— %	— %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	116	CLEVE-LAND	CLEVE-LAND	116	116	CLEVE-LAND	116	CLEVE-LAND
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	2.3 %	1.7 %	2.5 %	2.4 %	2.8 %	2.2 %	4.0 %	1.9 %
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	— "	— "
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.5 %	7.3 %	7.7 %	8.9 %	5.4 %	9.3 %	7.0 %	4.1 %
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.4 %	0.6 %	1.7 %	0.8 %	1.5 %	0.3 %	0.8 %	3.0 %
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.5 %	4.2 %	3.2 %	6.7 %	2.5 %	3.7 %	3.0 %	3.1 %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		.5 "	— "	.5 "	.5 "	— "	— "	— "	— "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	— "	— "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	— %	— %	— %	— %
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
		— %	— %	— %	— %	— %	— %	— %	— %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
		— "	— "	— "	— "	— "	— "	— "	— "

Comments: C.R. "A" #27: HIGH CURB TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 12	Date: JULY 12, 2012
Location: 116th ALLEY BETWEEN CLEVELAND & CENTRAL	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT CENTRAL	SW	Curb Ramp E:	
Curb Ramp B: LOOKING AT CLEVELAND	SE	Curb Ramp F:	
Curb Ramp C: LOOKING AT CLEVELAND	NE	Curb Ramp G:	
Curb Ramp D: LOOKING AT CENTRAL	NW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SE	NE	NW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 12	Date: JULY 12, 2012
Location: 116th ALLEY BETWEEN CLEVELAND & CENTRAL	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT CENTRAL	SW	Curb Ramp E:	
Curb Ramp B: LOOKING AT CLEVELAND	SE	Curb Ramp F:	
Curb Ramp C: LOOKING AT CLEVELAND	NE	Curb Ramp G:	
Curb Ramp D: LOOKING AT CENTRAL	NW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	1.0 %	2.5 %	3.9 %	6.3 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	CEN-TRAL	CLEVE-LAND	CLEVE-LAND	CEN-TRAL				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	2.3 %	0.5 %	0.8 %	0.2 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.0 %	2.5 %	3.9 %	6.3 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.3 %	1.0 %	2.3 %	0.5 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" #32: DRIVEWAY
C.R. "B" #32: DRIVEWAY
C.R. "C" #32: DRIVEWAY

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 13	Date: JULY 12, 2012
Location: CENTRAL & 116th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT LAKE	SW	Curb Ramp E:	
Curb Ramp B: LOOKING AT 116th	NW	Curb Ramp F:	
Curb Ramp C: LOOKING AT 1601 CENTRAL	NW	Curb Ramp G:	
Curb Ramp D: LOOKING AT 1546 CENTRAL	NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	NW	NW	NE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	N.C.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	71" x 71"	71" x 71"	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	40 "	40 "	40 "	40 "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 **(After 1/26/92)**

Intersection #: 13	Date: JULY 12, 2012
Location: CENTRAL & 116th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT LAKE	SW	Curb Ramp E:	
Curb Ramp B: LOOKING AT 116th	NW	Curb Ramp F:	
Curb Ramp C: LOOKING AT 1601 CENTRAL	NW	Curb Ramp G:	
Curb Ramp D: LOOKING AT 1546 CENTRAL	NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	9.2 %	6.9 %	6.0 %	4.3 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	CEN-TRAL	CEN-TRAL	116	116				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	4.9 %	6.6 %	5.0 %	4.6 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		9.2 %	6.9 %	6.0 %	4.3 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.4 %	0.8 %	0.9 %	0.9 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.1 %	5.6 %	4.7 %	1.4 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 **After 1/26/92**

Intersection #:	14	Date:	JUNE 19, 2012
Location:	ATCHISON & 117th	Surveyors:	B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A:	LOOKING AT 1704 ATCHISON SE	Curb Ramp E:	
Curb Ramp B:	LOOKING AT LAKE SE	Curb Ramp F:	
Curb Ramp C:	LOOKING AT 119th NE	Curb Ramp G:	
Curb Ramp D:	LOOKING AT 1650 ATCHISON NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SE	NE	NE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	67x 72 "	67x 72 "	72x 72 "	72x 72 "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	27 "	27 "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 14	Date: JUNE 19, 2012
Location: ATCHISON & 117th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 1704 ATCHISON SE	Curb Ramp E:
Curb Ramp B: LOOKING AT LAKE SE	Curb Ramp F:
Curb Ramp C: LOOKING AT 119th NE	Curb Ramp G:
Curb Ramp D: LOOKING AT 1650 ATCHISON NE	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25.	.25.	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	6.6 %	4.8 %	5.2 %	2.7 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	ATCH-ISON	117	117	ATCH-ISON				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	3.4 %	2.0 %	5.8 %	3.3 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		6.6 %	4.8 %	5.2 %	2.7 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.9 %	1.1 %	0.6 %	0.9 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	2.8 %	3.6 %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	2.0 "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "C&D" COMMON LANDING IS ALL SMASHED

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #:	15	Date:	JUNE 19, 2012
Location:	117th ALLEY B/T ATCHISON & CLEVELAND	Surveyors:	B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A:	ATCHISON HALF	SW	Curb Ramp E:
Curb Ramp B:	CLEVELAND HALF	SE	Curb Ramp F:
Curb Ramp C:	ATCHISON HALF	NW	Curb Ramp G:
Curb Ramp D:	CLEVELAND HALF	NE	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SE	NW	NE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	31 "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 15	Date: JUNE 19, 2012
Location: 117th ALLEY B/T ATCHISON & CLEVELAND	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: ATCHISON HALF	SW	Curb Ramp E:	
Curb Ramp B: CLEVELAND HALF	SE	Curb Ramp F:	
Curb Ramp C: ATCHISON HALF	NW	Curb Ramp G:	
Curb Ramp D: CLEVELAND HALF	NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	.25 "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	1.9 %	2.1 %	1.3 %	1.8 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	CLEVE-LAND	ATCH-ISON	CLEVE-LAND	ATCH-ISON				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.8 %	1.0 %	3.3 %	2.3 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.9 %	2.1 %	1.3 %	1.8 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.1 %	3.7 %	0.7 %	1.3 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	.25 "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" # 32 GARAGE/DRIVEWAY
C.R. "B" # 32 HOUSE/DRIVEWAY
C.R. "D" # 32 FENCE/GRASS

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 16	Date: JUNE 19, 2012
Location: CLEVELAND & 117th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 1647 CLEVELAND	NW	Curb Ramp E: LOOKING AT 1700 CLEVELAND	SE
Curb Ramp B: LOOKING AT 119th	NW	Curb Ramp F: LOOKING AT LAKE	SE
Curb Ramp C: LOOKING AT 1646 CLEVELAND	NE	Curb Ramp G: LOOKING AT CHURCH	SW
Curb Ramp D: LOOKING AT 119th	NE	Curb Ramp H: LOOKING AT LAKE	SW

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	72"	— "	72"	— "	73"	— "	73"	— "
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	B	A	B	A	B	A	B	A
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	—
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NW	NE	NE	SE	SE	SW	SW
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	N.C.	S.S.	N.C.	S.S.	N.C.
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	N
15	What are the dimensions of any common landing for two curb ramps?	71 x 71"	71 x 71"	74 x 72"	74 x 72"	71 x 72"	71 x 72"	71 x 73"	71 x 73"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	24"	24"	24"	24"	24"	24"	24"	24"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 16	Date: JUNE 19, 2012
Location: CLEVELAND & 117th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 1647 CLEVELAND	NW	Curb Ramp E: LOOKING AT 1700 CLEVELAND	SE
Curb Ramp B: LOOKING AT 119th	NW	Curb Ramp F: LOOKING AT LAKE	SE
Curb Ramp C: LOOKING AT 1646 CLEVELAND	NE	Curb Ramp G: LOOKING AT CHURCH	SW
Curb Ramp D: LOOKING AT 119th	NE	Curb Ramp H: LOOKING AT LAKE	SW

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25"	— "	— "	— "	— "	— "	— "	— "
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	4.2 %	8.6 %	3.9 %	2.6 %	5.1 %	2.9 %	2.5 %	8.3 %
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— % / — %	— % / — %	— % / — %	— % / — %	— % / — %	— % / — %	— % / — %	— % / — %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	CLEVE-LAND	117	CLEVE-LAND	117	CLEVE-LAND	117	CLEVE-LAND	117
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	4.3 %	3.4 %	2.5 %	2.8 %	2.7 %	2.6 %	3.8 %	1.8 %
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "
24	Does CR have a running slope of 8.33% or less?	Y or N / 4.2 %	Y or N / 8.6 %	Y or N / 3.9 %	Y or N / 2.6 %	Y or N / 5.1 %	Y or N / 2.9 %	Y or N / 2.5 %	Y or N / 8.3 %
25	Does CR have a cross slope of 2% or less?	Y or N / 0.7 %	Y or N / 0.1 %	Y or N / 0.8 %	Y or N / 1.2 %	Y or N / 2.2 %	Y or N / 0.2 %	Y or N / 0.2 %	Y or N / 2.7 %
26	Does CR have a gutter slope of 5% or less?	Y or N / 5.5 %	Y or N / 4.2 %	Y or N / 3.4 %	Y or N / 4.2 %	Y or N / 3.0 %	Y or N / 0.1 %	Y or N / 0.8 %	Y or N / 2.1 %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N / — "	Y or N / .75 "	Y or N / — "	Y or N / .75 "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	— %	— %	— %	— %
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	~~Y~~ or N	Y or N	~~Y~~ or N	Y or N	~~Y~~ or N	Y or N	~~Y~~ or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "

Comments: C.R. "B" #27 : HIGH CURB TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 17	Date: JULY 10, 2012
Location: 117th ALLEY BETWEEN CLEVELAND & CENTRAL	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT CENTRAL	NW	Curb Ramp E:	
Curb Ramp B: LOOKING AT CLEVELAND	NE	Curb Ramp F:	
Curb Ramp C: LOOKING AT CLEVELAND	SE	Curb Ramp G:	
Curb Ramp D: LOOKING AT CENTRAL	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NE	SE	SW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 17	Date: JULY 10, 2012
Location: 117th ALLEY BETWEEN CLEVELAND & CENTRAL	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT CENTRAL	NW	Curb Ramp E:	
Curb Ramp B: LOOKING AT CLEVELAND	NE	Curb Ramp F:	
Curb Ramp C: LOOKING AT CLEVELAND	SE	Curb Ramp G:	
Curb Ramp D: LOOKING AT CENTRAL	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.2 %	2.6 %	0.1 %	0.9 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	CEN-TRAL	CLEVE-LAND	CLEVE-LAND	CEN-TRAL				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.3 %	3.7 %	0.7 %	0.1 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.2 %	2.6 %	0.1 %	0.9 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.9 %	1.2 %	1.5 %	1.7 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" # 32: DRIVEWAY
C.R. "B" # 32: LANDSCAPE/FENCE
C.R. "C" # 32: DRIVEWAY

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 18	Date: JULY 10, 2012
Location: CENTRAL & 117th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT LAKE	SW	Curb Ramp E: LOOKING AT 1646 CENTRAL	NE
Curb Ramp B: LOOKING AT 1701 CENTRAL	SW	Curb Ramp F: LOOKING AT 119th	NE
Curb Ramp C: LOOKING AT LAKE	SE	Curb Ramp G: LOOKING AT 119th	NW
Curb Ramp D: LOOKING AT 1700 CENTRAL	SE	Curb Ramp H: LOOKING AT 1649 CENTRAL	NW

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	— "	— "	— "	— "
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A	A	A	A
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	—
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SW	SE	SE	NE	NE	NW	NW
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	N.C.	N.C.	N.C.	S.S.	S.S.
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	N
15	What are the dimensions of any common landing for two curb ramps?	72x 72"	72x 72"	72x 72"	72x 72"	72x 72"	72x 72"	72x 72"	72x 72"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	40"	40"	40"	40"	40"	40"	40"	40"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 18	Date: JULY 10, 2012
Location: CENTRAL & 117th	Surveyors: B. WASVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT LAKE	SW	Curb Ramp E: LOOKING AT 1646 CENTRAL	NE
Curb Ramp B: LOOKING AT 1701 CENTRAL	SW	Curb Ramp F: LOOKING AT 119th	NE
Curb Ramp C: LOOKING AT LAKE	SE	Curb Ramp G: LOOKING AT 119th	NW
Curb Ramp D: LOOKING AT 1700 CENTRAL	SE	Curb Ramp H: LOOKING AT 1649 CENTRAL	NW

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	.25 "	.25 "	— "	.25 "	— "	— "
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	6.3 %	7.3 %	5.7 %	6.6 %	6.4 %	4.8 %	7.1 %	7.4 %
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	— %	— %	— %	— %
		— %	— %	— %	— %	— %	— %	— %	— %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	117	CEN-TRAL	117	CEN-TRAL	CEN-TRAL	117	117	CEN-TRAL
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	4.9 %	5.4 %	4.8 %	4.5 %	5.4 %	3.9 %	3.8 %	3.9 %
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	— "	— "
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		6.3 %	7.3 %	5.7 %	6.6 %	6.4 %	4.8 %	7.1 %	7.4 %
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.9 %	0.7 %	2.5 %	0.7 %	0.7 %	2.0 %	1.4 %	1.2 %
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.0 %	2.4 %	5.7 %	7.1 %	4.0 %	9.0 %	5.2 %	4.8 %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		.5 "	.5 "	.5 "	.5 "	1.0 "	.5 "	.75 "	.5 "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	— "	— "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	— %	— %	— %	— %
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
		— %	— %	— %	— %	— %	— %	— %	— %
32	If no flared sides, is there an obstruction on grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
		— "	— "	— "	— "	— "	— "	— "	— "

Comments: C.R. "A" #27 : HIGH CURB TRANSITION
C.R. "B" #27 : HIGH CURB TRANSITION
C.R. "C" #27 : HIGH CURB TRANSITION
C.R. "E" #27: HIGH CURB TRANSITION
C.R. "F" #27: HIGH CURB TRANSITION
C.R. "G" #27: HIGH CURB TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 19	Date: JULY 10.2012
Location: 117th ALLEY BETWEEN CENTRAL & LAPORTE	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT CENTRAL	NE	Curb Ramp E:	
Curb Ramp B: LOOKING AT LAPORTE	NW	Curb Ramp F:	
Curb Ramp C: LOOKING AT LAPORTE	SW	Curb Ramp G:	
Curb Ramp D: LOOKING AT CENTRAL	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NW	SW	SE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	31 "	— "	— "	30 "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 19	Date: JULY 10, 2012
Location: 117th ALLEY BETWEEN CENTRAL & LAPORTE	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT CENTRAL	NE	Curb Ramp E:	
Curb Ramp B: LOOKING AT LAPORTE	NW	Curb Ramp F:	
Curb Ramp C: LOOKING AT LAPORTE	SW	Curb Ramp G:	
Curb Ramp D: LOOKING AT CENTRAL	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.2 %	0.0 %	1.3 %	2.0 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	CEN-TRAL	LAP-ORTE	LAP-ORTE	CEN-TRAL				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.2 %	0.3 %	0.1 %	0.0 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.2 %	0.0 %	1.3 %	2.0 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.7 %	2.4 %	2.4 %	1.0 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" #32: DRIVEWAY
C.R. "B" #32: DRIVEWAY
C.R. "C" #32: FENCE/GRASS

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 20	Date: JULY 10, 2012
Location: LAPORTE & 117th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT LAKE	SW	Curb Ramp E: LOOKING AT 1648 LAPORTE	NE
Curb Ramp B: LOOKING AT HOUSE	SW	Curb Ramp F: LOOKING AT 119th	NE
Curb Ramp C: LOOKING AT 1700 LAPORTE	SE	Curb Ramp G: LOOKING AT 119th	NW
Curb Ramp D: LOOKING AT LAKE	SE	Curb Ramp H: LOOKING AT HOUSE	NW

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	— "	— "	— "	— "
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A	A	A	A
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	—
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SW	SE	SE	NE	NE	NW	NW
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.	N.C.	N.C.
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	N
15	What are the dimensions of any common landing for two curb ramps?	70 x 72"	70 x 72"	71 x 73"	71 x 73"	72 x 72"	72 x 72"	71 x 71"	71 x 71"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	24"	28"	25"	28"	28"	28"	26"	24"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 20	Date: JULY 10, 2012
Location: LAPORTE & 117th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT LAKE	SW	Curb Ramp E: LOOKING AT 1648 LAPORTE	NE
Curb Ramp B: LOOKING AT HOUSE	SW	Curb Ramp F: LOOKING AT 119th	NE
Curb Ramp C: LOOKING AT 1700 LAPORTE	SE	Curb Ramp G: LOOKING AT 119th	NW
Curb Ramp D: LOOKING AT LAKE	SE	Curb Ramp H: LOOKING AT HOUSE	NW

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	— "	— "	.25 "	— "
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	5.0 %	5.2 %	4.0 %	5.8 %	8.5 %	5.5 %	4.8 %	5.4 %
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— % / — %	— % / — %	— % / — %	— % / — %	— % / — %	— % / — %	— % / — %	— % / — %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	117	LAP-ORTE	LAP-ORTE	117	LAP-ORTE	117	117	LAP-ORTE
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	5.2 %	5.7 %	1.6 %	7.6 %	5.5 %	6.5 %	4.1 %	4.9 %
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "
24	Does CR have a running slope of 8.33% or less?	Y or N / 5.0 %	Y or N / 5.2 %	Y or N / 4.0 %	Y or N / 5.8 %	Y or N / 8.5 %	Y or N / 5.5 %	Y or N / 4.8 %	Y or N / 5.4 %
25	Does CR have a cross slope of 2% or less?	Y or N / 0.7 %	Y or N / 0.9 %	Y or N / 1.9 %	Y or N / 1.2 %	Y or N / 0.2 %	Y or N / 0.4 %	Y or N / 1.7 %	Y or N / 0.4 %
26	Does CR have a gutter slope of 5% or less?	Y or N / 3.4 %	Y or N / 3.7 %	Y or N / 2.4 %	Y or N / 1.5 %	Y or N / 3.8 %	Y or N / 5.5 %	Y or N / 4.8 %	Y or N / 4.3 %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / 2 "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	— %	— %	— %	— %
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %
32	If no flared sides, is there an obstruction of grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "

Comments: C.R. "D" #27 : LARGE POT HOLE 12" x 24" x 2"

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 21	Date:
Location: 117th ALLEY B/T SHERIDAN & LAPORTE	Surveyors: B. WAJVODA

Describe each curb ramp's location:		
Curb Ramp A: LOOKING AT LAPORTE	NE	Curb Ramp E:
Curb Ramp B: LOOKING AT SHERIDAN	NW	Curb Ramp F:
Curb Ramp C: LOOKING AT SHERIDAN	SW	Curb Ramp G:
Curb Ramp D: LOOKING AT LAPORTE	SE	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NW	SW	SE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	22 "	33 "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 21	Date:
Location: 117th ALLEY B/T SHERIDAN & LAPORTE	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT LAPORTE	NE	Curb Ramp E:	
Curb Ramp B: LOOKING AT SHERIDAN	NW	Curb Ramp F:	
Curb Ramp C: LOOKING AT SHERIDAN	SW	Curb Ramp G:	
Curb Ramp D: LOOKING AT LAPORTE	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	.25 "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.3 %	1.3 %	0.2 %	2.0 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	LAP-ORTE	SHER-IDAN	SHER-IDAN	LAP-ORTE				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.9 %	0.1 %	0.5 %	0.6 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.3 %	1.3 %	0.2 %	2.0 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.8 %	3.2 %	1.7 %	3.0 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.1 %	7.0 %	1.3 %	2.3 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		.5 "	.5 "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" #32: DRIVEWAY
C.R. "B" #32: DRIVEWAY
C.R. "C" #32: DRIVEWAY
C.R. "B" #27: HIGH CURB TRANSITION
C.R. "C" #27: HIGH CURB TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 22	Date: JUNE 28, 2012
Location: SHERIDAN & 117th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 119th	NE	Curb Ramp E: LOOKING AT LAKE	SW
Curb Ramp B: LOOKING AT 1648 SHERIDAN	NE	Curb Ramp F: LOOKING AT BEACH HOUSE	SW
Curb Ramp C: LOOKING AT 119th	NW	Curb Ramp G: LOOKING AT LAKE	SE
Curb Ramp D: LOOKING AT 1649 SHERIDAN	NW	Curb Ramp H: LOOKING AT 1700 SHERIDAN	SE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	"	"	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A	A	A	A
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	—
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NE	NW	NW	SW	SW	SE	SE
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.	N.C.	N.C.	N.C.	N.C.
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	N
15	What are the dimensions of any common landing for two curb ramps?	"	"	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	— "	— "	— "	— "

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 22	Date: JUNE 28, 2012
Location: SHERIDAN & 117th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 119th	NE	Curb Ramp E: LOOKING AT LAKE	SW
Curb Ramp B: LOOKING AT 1648 SHERIDAN	NE	Curb Ramp F: LOOKING AT BEACH HOUSE	SW
Curb Ramp C: LOOKING AT 119th	NW	Curb Ramp G: LOOKING AT LAKE	SE
Curb Ramp D: LOOKING AT 1649 SHERIDAN	NW	Curb Ramp H: LOOKING AT 1700 SHERIDAN	SE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	.25 "	.25 "	— "	— "	— "	— "	— "
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	8.4 %	5.1 %	6.0 %	3.0 %	4.0 %	4.4 %	5.3 %	4.4 %
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— % — %	— % — %	— % — %	— % — %	— % — %	— % — %	— % — %	— % — %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	117	SHER-IDAN	117	SHER-IDAN	117	SHER-IDAN	117	SHER-IDAN
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	9.0 %	1.5 %	3.8 %	3.5 %	1.5 %	2.6 %	2.2 %	5.6 %
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
24	Does CR have a running slope of 8.33% or less?	Y or N 8.4 %	Y or N 5.1 %	Y or N 6.0 %	Y or N 3.0 %	Y or N 4.0 %	Y or N 4.4 %	Y or N 5.3 %	Y or N 4.4 %
25	Does CR have a cross slope of 2% or less?	Y or N 0.4 %	Y or N 0.1 %	Y or N 0.3 %	Y or N 1.4 %	Y or N 0.8 %	Y or N 0.1 %	Y or N 0.3 %	Y or N 0.5 %
26	Does CR have a gutter slope of 5% or less?	Y or N 9.3 %	Y or N 2.3 %	Y or N 4.8 %	Y or N 3.7 %	Y or N 3.1 %	Y or N 2.7 %	Y or N 9.4 %	Y or N 1.9 %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	— %	— %	— %	— %
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "

Comments: #34 C.R. "A-H" NEED RE-PAINTING

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 23	Date: JULY 10, 2012
Location: 117th ALLEY BETWEEN SHERIDAN & OLIVER	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT PARK SW	Curb Ramp E:
Curb Ramp B: LOOKING AT 1701 SHERIDAN SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 23	Date: JULY 10, 2012
Location: 117th ALLEY BETWEEN SHERIDAN & OLIVER	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT PARK SW	Curb Ramp E:
Curb Ramp B: LOOKING AT 1701 SHERIDAN SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25"	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.6%	0.1 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	OLI-VER	SHER-IDAN						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	2.1%	0.7%	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.6 %	0.1 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.4 %	0.1 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	1.7 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" # 32: FENCE/GRASS
C.R. "B" # 32: DRIVEWAY

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 24	Date: JUNE 28, 2012
Location: OLIVER & 117th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A:	LOOKING AT WHITE HOUSE	SE	Curb Ramp E:
Curb Ramp B:	LOOKING AT PARK	SW	Curb Ramp F:
Curb Ramp C:	LOOKING AT PARK	NW	Curb Ramp G:
Curb Ramp D:	LOOKING AT TAN GARAGE	NE	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	"	"	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	—	—						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	V	V	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,NE)	SE	SW	NW	NE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	~~Y~~ or N	~~Y~~ or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments: #9 C.R. "A & B": TRIANGLE PLANTER

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 24	Date: JUNE 28, 2012
Location: OLIVER & 117th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT WHITE HOUSE	SE	Curb Ramp E:	
Curb Ramp B: LOOKING AT PARK	SW	Curb Ramp F:	
Curb Ramp C: LOOKING AT PARK	NW	Curb Ramp G:	
Curb Ramp D: LOOKING AT TAN GARAGE	NE	Curb Ramp H:	

	CURB RAMP	A	B	C	D				
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.5 %	0.2 %	4.6 %	3.2 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	0.9 %	%	%	%	%
		— %	— %	— %	7.8 %	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	SHER-IDAN	CEN-TER	CEN-TER	SHER-IDAN				
22	What is the slope of the transition to the sidewalk? (should be 5% or less)	0.3 %	0.5 %	1.5 %	4.2 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	~~Y or N~~	~~Y or N~~	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	4.6 %	3.2 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	~~Y or N~~	~~Y or N~~	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N
		— %	— %	1.8 %	2.5 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		1.4 %	2.6 %	2.1 %	0.3 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	YES %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If	Y or (N)	Y or (N)	(Y) or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	(X) or (N)	(X) or (N)	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: # 34 CROSS WALK MARKINGS NEED PAINTING

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 25	Date: JUNE 28, 2012
Location: CENTER & 117th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT PARK SW	Curb Ramp E:
Curb Ramp B: LOOKING AT BLUE HOUSE SE	Curb Ramp F:
Curb Ramp C: LOOKING AT SPORTS COMPLEX SE	Curb Ramp G:
Curb Ramp D: LOOKING AT FOOTBALL PARKING LOT NE	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	B	A/B				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,NE)	SW	SE	SE	NE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 25	Date: JUNE 28, 2012
Location: CENTER & 117th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT PARK	SW	Curb Ramp E:	
Curb Ramp B: LOOKING AT BLUE HOUSE	SE	Curb Ramp F:	
Curb Ramp C: LOOKING AT SPORTS COMPLEX	SE	Curb Ramp G:	
Curb Ramp D: LOOKING AT FOOTBALL PARKING LOT	NE	Curb Ramp H:	

	CURB RAMP	A	B	C	D				
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	(Y) or N	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	.25 "	.25 "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	9.3 %	8.3 %	8.3 %	5.2 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	CEN-TER	CEN-TER	117	117				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	7.2 %	0.5 %	0.5 %	3.7 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or (N)	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		9.3 %	8.3 %	8.3 %	5.2 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or (N)	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		2.3 %	0.6 %	0.6 %	0.9 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or (N)	(Y) or N	(Y) or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		3.9 %	1.4 %	1.4 %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If	(Y) or N	Y or (N)	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	(X) or (N)	(X) or (N)	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 **After 1/26/92**

Intersection #: 26	Date: JUNE 12, 2012
Location: ATCHISON & 118th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A:	LOOKING AT BURGER KING NE	Curb Ramp E:	LOOKING AT LAKE SE
Curb Ramp B:	LOOKING AT INDY BLVD. NE	Curb Ramp F:	LOOKING AT BURGER KING SE
Curb Ramp C:	LOOKING AT 1749 ATCHISON NW	Curb Ramp G:	
Curb Ramp D:	LOOKING AT AIR ONE NW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	— "	— "	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A	A		
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—		
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	~~Y or N~~	~~Y or N~~	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NE	NW	NW	SE	SE		
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.		
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	N.C.	N.C.	N.C.	N.C.		
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N		
15	What are the dimensions of any common landing for two curb ramps?	72 "	72 "	— "	— "	72 "	72 "	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	26 "	29 "	— "	— "	36 "	36 "	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 26	Date: JUNE 12, 2012
Location: ATCHISON & 118th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT BURGER KING NE	Curb Ramp E: LOOKING AT LAKE SE
Curb Ramp B: LOOKING AT INDY BLVD. NE	Curb Ramp F: LOOKING AT BURGER KING SE
Curb Ramp C: LOOKING AT 1749 ATCHISON NW	Curb Ramp G:
Curb Ramp D: LOOKING AT AIR ONE NW	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	.25 "	.25 "	.25 "	.25 "	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	6.6 %	5.3 %	7.7 %	1.3 %	7.7 %	7.2 %	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	— %	— %	%	%
		— %	— %	— %	— %	— %	— %	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	ATCHISON	118	ATCH-ISON	118	118	ATCH-ISON		
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	5.5 %	4.9 %	2.0 %	1.6 %	6.0 %	6.5 %	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		6.6 %	5.3 %	7.7 %	1.3 %	7.7 %	7.2 %	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.2 %	0.6 %	0.3 %	1.3 %	4.6 %	4.1 %	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	2.9 %	3.3 %	— %	2.4 %	2.1 %	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.0 "	1.25 "	.50 "	.25 "	1.0 "	— "	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	— %	— %	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
		— %	— %	— %	— %	— %	— %	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 26.A	Date: JUNE 12, 2012
Location: DRIVEWAY SOUTH OF 118th & ATCHISON	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT INDY BLVD. NW	Curb Ramp E:
Curb Ramp B: LOOKING AT LAKE SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	72 "	72 "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	SW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	X or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 26. A	Date: JUNE 12, 2012
Location: DRIVEWAY SOUTH OF 118th & ATCHISON	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT INDY BLVD. NW	Curb Ramp E:
Curb Ramp B: LOOKING AT LAKE SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.2 %	1.5 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	INDY	LOOK AT LAKE						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.6 %	1.0 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.2 %	1.5 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.7 %	1.6 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction of grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 27	Date: JUNE 12, 2012
Location: 118th ALLEY B/T ATCHISON & CLEVELAND	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: ATCHISON HALF SW	Curb Ramp E:
Curb Ramp B: CLEVELAND HALF SE	Curb Ramp F:
Curb Ramp C: CLEVELAND HALF NE	Curb Ramp G:
Curb Ramp D: ATCHISON HALF NW	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SE	NE	NW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	S.S.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	24 "	— "	— "	35 "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 27	Date: JUNE 12, 2012
Location: 118th ALLEY B/T ATCHISON & CLEVELAND	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: ATCHISON HALF SW	Curb Ramp E:
Curb Ramp B: CLEVELAND HALF SE	Curb Ramp F:
Curb Ramp C: ATCHISON HALF NE	Curb Ramp G:
Curb Ramp D: CLEVELAND HALF NW	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	.25 "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.6 %	0.2 %	0.1 %	0.8 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	CLEVE-LAND	ATCH-ISON	ATCH-ISON	CLEVE-LAND				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.4 %	0.7 %	1.2 %	0.1 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.6 %	0.2 %	0.1 %	0.8 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.6 %	0.7 %	1.5 %	2.3 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.0 %	3.7 %	0.2 %	1.0 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	.25 "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction on grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" #32 : GRASS ; BUILDING
C.R. "B" #32 : LANDSCAPING ; GRASS
C.R. "C" #32 : UTILITY POLE

ADA

Construction/Alteration (circle one): Before 1/26/92 **After 1/26/92**

Intersection #: 28	Date: JUNE 08, 2012
Location: CLEVELAND & 118th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT LAKE SE	Curb Ramp E: LOOKING AT 119th NW
Curb Ramp B: LOOKING AT BURGER KING SE	Curb Ramp F: LOOKING AT CLEVELAND NW
Curb Ramp C: LOOKING AT 1801 CLEVELAND SW	Curb Ramp G: LOOKING AT BURGER KING NE
Curb Ramp D: LOOKING AT LAKE SW	Curb Ramp H: LOOKING AT 119th NE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	72"	72"	72"	73"	73"	72"	72"	72"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	B	B	B	B	B	B	B	B
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	—
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SE	SW	SW	NW	NW	NE	NE
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	N
15	What are the dimensions of any common landing for two curb ramps?	72" x 72"	72" x 72"	72" x 72"	72" x 72"	72" x 72"	72" x 72"	72" x 72"	72" x 72"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	22.5"	24"	24"	24"	24"	24"	24"	24"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 28	Date: JUNE 08, 2012
Location: CLEVELAND & 118th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT LAKE	SE	Curb Ramp E: LOOKING AT 119th	NW
Curb Ramp B: LOOKING AT BURGER KING	SE	Curb Ramp F: LOOKING AT CLEVELAND	NW
Curb Ramp C: LOOKING AT 1801 CLEVELAND	SW	Curb Ramp G: LOOKING AT BURGER KING	NE
Curb Ramp D: LOOKING AT LAKE	SW	Curb Ramp H: LOOKING AT 119th	NE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	— "	— "	— "	— "
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	6.5 %	6.6 %	7.7 %	6.4 %	9.1 %	9.9 %	8.5 %	8.5 %
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— % — %	— % — %	— % — %	— % — %	— % — %	— % — %	— % — %	— % — %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	118	CLEVE-LAND	CLEVE-LAND	118	118	CLEVE-LAND	CLEVE-LAND	118
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	3.1 %	1.7 %	5.2 %	5.6 %	5.6 %	5.0 %	8.8 %	7.3 %
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
24	Does CR have a running slope of 8.33% or less?	Y or N 6.5 %	Y or N 6.6 %	Y or N 7.7 %	Y or N 6.4 %	Y or N 9.1 %	Y or N 9.9 %	Y or N 8.5 %	Y or N 8.5 %
25	Does CR have a cross slope of 2% or less?	Y or N 2.0 %	Y or N 1.0 %	Y or N 1.0 %	Y or N 0.3 %	Y or N 0.7 %	Y or N 0.5 %	Y or N 0.3 %	Y or N 1.0 %
26	Does CR have a gutter slope of 5% or less?	Y or N 0.1 %	Y or N 3.7 %	Y or N 4.7 %	Y or N 3.7 %	Y or N 1.1 %	Y or N 2.4 %	Y or N 1.3 %	Y or N 2.0 %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	— %	— %	— %	— %
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %
32	If no flared sides, is there an obstruction on grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	⊗ or N	⊗ or N	⊗ or N	⊗ or N	⊗ or N	⊗ or N	⊗ or N	⊗ or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 29	Date: JUNE 08, 2012
Location: 118th ALLEY B/T CLEVELAND & CENTRAL	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: CLEVELAND HALF SW	Curb Ramp E:
Curb Ramp B: CENTRAL HALF SE	Curb Ramp F:
Curb Ramp C: CENTRAL HALF NE	Curb Ramp G:
Curb Ramp D: CLEVELAND HALF NW	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	PAN	PAN	PAN	PAN				
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SE	NE	NW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 29	Date: JUNE 08, 2012
Location: 118th ALLEY B/T CLEVELAND + CENTRAL	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A:	CLEVELAND HALF	SW	Curb Ramp E:
Curb Ramp B:	CENTRAL HALF	SE	Curb Ramp F:
Curb Ramp C:	CENTRAL HALF	NE	Curb Ramp G:
Curb Ramp D:	CLEVELAND HALF	NW	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	3.7 %	0.3 %	4.0 %	2.8 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	CEN-TRAL	CLEVE-LAND	CLEVE-LAND	CEN-TRAL				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	3.4 %	1.7 %	3.8 %	4.3 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.7 %	0.3 %	4.0 %	2.8 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.6 %	3.2 %	4.8 %	5.0 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.2 %	1.2 %	2.4 %	1.3 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	.50 "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"

Comments: C.R. "A-D" #32: DRWEWAY

C.R. "D" #27: CURB TRANSITION IS HIGH

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 30	Date: JUNE 08, 2012
Location: CENTRAL & 118th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT LAKE SE	Curb Ramp E: LOOKING AT 119th NW
Curb Ramp B: LOOKING AT BURGER KING SE	Curb Ramp F: LOOKING AT CHURCH NW
Curb Ramp C: LOOKING AT GREEN HOUSE SW	Curb Ramp G: LOOKING AT 119th NE
Curb Ramp D: LOOKING AT LAKE SW	Curb Ramp H: LOOKING AT BURGER KING NE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	— "	— "	— "	— "
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A	A	A	A
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	—
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SE	SW	SW	NW	NW	NE	NE
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	N
15	What are the dimensions of any common landing for two curb ramps?	72 x 72 "	72 x 72 "	72 x 72 "	72 x 72 "	72 x 72 "	72 x 72 "	72 x 72 "	72 x 72 "
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	40 "	40 "	40 "	40 "	40 "	40 "	40 "	40 "

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 30	Date: JUNE 08, 2012
Location: CENTRAL & 118th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT LAKE	SE	Curb Ramp E: LOOKING AT 119th	NW
Curb Ramp B: LOOKING AT BURGER KING	SE	Curb Ramp F: LOOKING AT CHURCH	NW
Curb Ramp C: LOOKING AT GREEN HOUSE	SW	Curb Ramp G: LOOKING AT 119th	NE
Curb Ramp D: LOOKING AT LAKE	SW	Curb Ramp H: LOOKING AT BURGER KING	NE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	—	.25	—	—	—	—	—	—
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	8.1 %	3.0 %	6.1 %	5.6 %	4.5 %	6.7 %	3.5 %	6.5 %
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— % / — %	— % / — %	— % / — %	— % / — %	— % / — %	— % / — %	— % / — %	— % / — %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	118	CEN-TRAL	CEN-TRAL	118	118	CEN-TRAL	118	CEN-TRAL
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	2.0 %	4.3 %	4.3 %	7.3 %	5.8 %	3.9 %	2.7 %	2.2 %
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "
24	Does CR have a running slope of 8.33% or less?	Y or N / 8.1 %	Y or N / 3.0 %	Y or N / 6.1 %	Y or N / 5.6 %	Y or N / 4.5 %	Y or N / 6.7 %	Y or N / 3.5 %	Y or N / 2.2 %
25	Does CR have a cross slope of 2% or less?	Y or N / 0.7 %	Y or N / 0.7 %	Y or N / 0.7 %	Y or N / 1.3 %	Y or N / 0.3 %	Y or N / 1.0 %	Y or N / 0.7 %	Y or N / 0.0 %
26	Does CR have a gutter slope of 5% or less?	Y or N / 1.9 %	Y or N / 1.7 %	Y or N / 6.8 %	Y or N / 2.1 %	Y or N / 3.6 %	Y or N / 3.1 %	Y or N / 4.4 %	Y or N / 5.3 %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N / .25	Y or N / —	Y or N / .75	Y or N / .50	Y or N / —	Y or N / —	Y or N / —	Y or N / —
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	— %	— %	— %	— %
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "

Comments: C.R "D" # 27: 1/2" LEVEL CHANGE B/T SIDEWALK AND CURB
C.R. "C" # 27: 1/2" LEVEL CHANGE B/T SIDEWALK RAMP AND CURB
C.R. "A" # 27: 1/2" LEVEL CHANGE B/T SIDEWALK RAMP AND CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 31	Date: JUNE 08, 2012
Location: 118th ALLEY B/T LAPORTE & CENTRAL	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LAPORTE HALF NE	Curb Ramp E:
Curb Ramp B: CENTRAL HALF NW	Curb Ramp F:
Curb Ramp C: CENTRAL HALF SW	Curb Ramp G:
Curb Ramp D: LAPORTE HALF SE	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	PAN	PAN	PAN	PAN				
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, Is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,NE)	NE	NW	SE	SW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 31	Date: JUNE 08, 2012
Location: 118th ALLEY B/T LAPORTE & CENTRAL	Surveyors: B. WAJYODA

Describe each curb ramp's location:			
Curb Ramp A: LAPORTE HALF	NE	Curb Ramp E:	
Curb Ramp B: CENTRAL HALF	NW	Curb Ramp F:	
Curb Ramp C: CENTRAL HALF	SW	Curb Ramp G:	
Curb Ramp D: LAPORTE HALF	SE	Curb Ramp H:	

17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	1.0 "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	1.5 %	3.4 %	1.1 %	0.8 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	CEN-TRAL	LAP-ORTE	LAP-ORTE	CEN-TRAL				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.1 %	1.8 %	0.7 %	1.2 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.5 %	3.4 %	1.1 %	0.8 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.1 %	0.1 %	2.0 %	0.3 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	2.2 %	0.2 %	4.0 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" #32: DRIVEWAY
C.R. "B" #32: DRIVEWAY
C.R. "D" #32: DRIVEWAY

ADA

Construction/Alteration (circle one): Before 1/26/92 (After 1/26/92)

Intersection #: 32	Date: JUNE 08, 2012
Location: LAPORTE & 118th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT LAKE SE	Curb Ramp E: LOOKING AT 119th NE
Curb Ramp B: LOOKING AT 1800 LAPORTE SE	Curb Ramp F: LOOKING AT 1748 LAPORTE NE
Curb Ramp C: LOOKING AT 1801 LAPORTE SW	Curb Ramp G: LOOKING AT CHURCH NW
Curb Ramp D: LOOKING AT LAKE SW	Curb Ramp H: LOOKING AT 119th NW

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	— "	— "	— "	— "
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A	A	A	A
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	—
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
6	What is the directional corner of the intersection? (NE,SE,NW,NE)	SE	SE	SW	SW	NE	NE	NW	NW
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)
8.A	If island is present, are there curb ramps and push buttons?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N
12	Does the crosswalk have any tactile guide strips?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	N
15	What are the dimensions of any common landing for two curb ramps?	72 x 72 "	72 x 72 "	72 x 72 "	72 x 72 "	72 x 72 "	72 x 72 "	72 x 72 "	72 x 72 "
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	— "	— "	— "	— "

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 **After 1/26/92**

Intersection #: 32	Date: JUNE 08, 2012
Location: LAPORTE & 118th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT LAKE	SE	Curb Ramp E: LOOKING AT 119th	NE
Curb Ramp B: LOOKING AT 1800 LAPORTE	SE	Curb Ramp F: LOOKING AT 1748 LAPORTE	NE
Curb Ramp C: LOOKING AT 1801 LAPORTE	SW	Curb Ramp G: LOOKING AT CHURCH	NW
Curb Ramp D: LOOKING AT LAKE	SW	Curb Ramp H: LOOKING AT 119th	NW

	CURB RAMP	A	B	C	D	E	F	G	H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	— "	— "	— "	— "
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	9.6 %	8.2 %	4.3 %	3.9 %	7.6 %	5.2 %	7.6 %	7.4 %
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— % — %	— % — %	— % — %	— % — %	— % — %	— % — %	— % — %	— % — %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	118	LA-PORTE	LA-PORTE	118	118	LA-PORTE	LA-PORTE	118
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	9.9 %	11.4 %	7.0 %	5.6 %	4.5 %	3.8 %	8.4 %	8.1 %
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
24	Does CR have a running slope of 8.33% or less?	Y or N 9.6 %	Y or N 8.2 %	Y or N 4.3 %	Y or N 3.9 %	Y or N 7.6 %	Y or N 5.2 %	Y or N 7.6 %	Y or N 7.4 %
25	Does CR have a cross slope of 2% or less?	Y or N 1.7 %	Y or N 0.2 %	Y or N 0.4 %	Y or N 2.3 %	Y or N 0.4 %	Y or N 0.5 %	Y or N 1.4 %	Y or N 0.7 %
26	Does CR have a gutter slope of 5% or less?	Y or N 3.6 %	Y or N 3.8 %	Y or N 2.0 %	Y or N 2.8 %	Y or N 1.5 %	Y or N 3.7 %	Y or N 4.2 %	Y or N 2.1 %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N 1.0 "	Y or N — "	Y or N — "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	— %	— %	— %	— %
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "

Comments: C.R. "F" #27: CURB EDGE IS HIGH

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 33	Date: JUNE 08, 2012
Location: 118th ALLEY BETWEEN LAPORTE & SHERIDAN	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: SHERIDAN HALF SE	Curb Ramp E:
Curb Ramp B: LAPORTE HALF SW	Curb Ramp F:
Curb Ramp C: SHERIDAN HALF NE	Curb Ramp G:
Curb Ramp D: LAPORTE HALF NW	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	PAN	PAN	PAN	PAN				
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,NE)	SE	SW	NE	NW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	— "	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 33	Date: JUNE 08, 2012
Location: 118th ALLEY BETWEEN LAPORTE & SHERIDAN	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A:	SHERIDAN HALF	SE	Curb Ramp E:
Curb Ramp B:	LAPORTE HALF	SW	Curb Ramp F:
Curb Ramp C:	SHERIDAN HALF	NE	Curb Ramp G:
Curb Ramp D:	LAPORTE HALF	NW	Curb Ramp H:

	CURB RAMP :	A	B	C	D				
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	Y or (N)	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	.25 "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.8 %	0.2 %	0.2 %	0.2 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	(Y) or N	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	LAP-ORTE	SHER-IDAN	LAP-ORTE	SHER-IDAN				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.5 %	0.1 %	0.7 %	0.4 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		0.8 %	0.2 %	0.2 %	0.2 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		0.4 %	0.8 %	0.9 %	0.9 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		4.8 %	3.5 %	0.2 %	0.1 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	(Y) or N	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If	(Y) or N	Y or (N)	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" # 32 : DRIVEWAY

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 34	Date: JUNE 08, 2012
Location: SHERIDAN & 118th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT LAKE SW	Curb Ramp E: LOOKING AT 1751 SHERIDAN NW
Curb Ramp B: LOOKING AT 1801 SHERIDAN SW	Curb Ramp F: LOOKING AT 119th NW
Curb Ramp C: LOOKING AT 1800 SHERIDAN SE	Curb Ramp G:
Curb Ramp D: LOOKING AT 1748 SHERIDAN NE	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	N.A."	71"	71"	67"	67"	NA."	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A	A		
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	FLARE	FLARE	FLARE	FLARE	FLARE	FLARE		
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—		
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,NE)	SW	SW	SE	NE	NW	NW		
7	What is the Geometry of the Intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A	R.A.	R.A		
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.		
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N		
15	What are the dimensions of any common landing for two curb ramps?	6'x6'"	6'x6'"	—"	—"	6'x6'"	6'x6'"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	—"	—"	—"	—"	—"	—"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 34	Date: JUNE 08, 2012
Location: SHERIDAN & 118th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT LAKE	SW	Curb Ramp E: LOOKING AT 1751 SHERIDAN	NW
Curb Ramp B: LOOKING AT 1801 SHERIDAN	SW	Curb Ramp F: LOOKING AT 119th	NW
Curb Ramp C: LOOKING AT 1800 SHERIDAN	SE	Curb Ramp G:	
Curb Ramp D: LOOKING AT 1748 SHERIDAN	NE	Curb Ramp H:	

	CURB RAMP:	A	B	C	D	E	F		
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	(Y) or N	Y or (N)	(Y) or N	(Y) or N	Y or (N)	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	.25 "	— "	.25 "	.25 "	— "	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	4.6 %	5.9 %	7.9 %	5.0 %	5.4 %	5.2 %	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	— %	— %	%	%
		— %	— %	— %	— %	— %	— %	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	118	SHER-IDAN	SHER-IDAN	SHER-IDAN	SHER-IDAN	118		
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	4.7 %	6.3 %	1.4 %	2.9 %	3.1 %	3.3 %	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N
		4.6 %	5.9 %	7.9 %	5.0 %	5.4 %	5.2 %	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N
		0.6 %	1.1 %	1.2 %	0.1 %	0.0 %	0.5 %	%	%
26	Does CR have a gutter slope of 5% or less?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or (N)	(Y) or N	Y or N	Y or N
		1.3 %	3.2 %	3.8 %	3.1 %	5.2 %	2.1 %	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	— %	— %	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
		— %	— %	— %	— %	— %	— %	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	(X) or (N)	(X) or (N)	(X) or (N)	(X) or (N)	Y or (N)	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 35	Date: JULY 10, 2012
Location: ATCHISON ALLEY B/T 117th & INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT INDIANAPOLIS BLVD. NE	Curb Ramp E:
Curb Ramp B: LOOKING AT 117th SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	70 "	70 "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	SE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	33 "	37 "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 35	Date: JULY 10, 2012
Location: ATCHISON ALLEY B/T 117th & INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT INDIANAPOLIS BLVD NE	Curb Ramp E:
Curb Ramp B: LOOKING AT 117th SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.7 %	9.6 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	INDY	117						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.3 %	6.8 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.7 %	9.6 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.8 %	0.2 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.4 %	5.2 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" #32: FENCE/GRASS
C.R. "B" #32: BUILDING/FENCE

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 36	Date: JULY 10, 2012
Location: ATCHISON & INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT AIR ONE NE	Curb Ramp E:
Curb Ramp B:	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	63 "	"	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A							
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	PAN							
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—							
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE							
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.							
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.							
14	What type of transit stop is there? (none, bus, other)	N							
15	What are the dimensions of any common landing for two curb ramps?	— "	"	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	69 "	"	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 36	Date: JULY 10, 2012
Location: ATCHISON & INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT AIR ONE NE	Curb Ramp E:
Curb Ramp B:	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	"	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	9.4 %	%	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	%	%	%	%	%	%	%
		— %	%	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	ATCH-ISON							
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	5.8 %	%	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	"	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		9.4 %	%	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.4 %	%	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	%	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		.25"	"	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	"	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	%	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	%	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	"	"	"	"	"	"	"

Comments: C.R. "A" #27 : HIGH CURB TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 37	Date: JUNE 12, 2012
Location: ALLEY BY WHITE CASTLE & CLEVELAND	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT LAKE SW	Curb Ramp E:
Curb Ramp B: LOOKING AT FOUNTAIN NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	72 "	72 "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	NW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 37	Date: JUNE 12, 2012
Location: ALLEY BY WHITE CASTLE & CLEVELAND	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT LAKE SW	Curb Ramp E:
Curb Ramp B: LOOKING AT FOUNTAIN NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	3.2 %	0.9 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	LAKE	119						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	2.4 %	1.0 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.2 %	0.9 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.3 %	1.6 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" #32: LANDSCAPING

C.R. "B" #32: FENCE

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 38	Date: JUNE 12, 2012
Location: CLEVELAND ALLEY NORTH OF 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT LAKE SE	Curb Ramp E:
Curb Ramp B: LOOKING AT 119th NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	72"	72"	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	NE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	—"	—"	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 38	Date: JUNE 12, 2012
Location: CLEVELAND ALLEY NORTH OF 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT LAKE SE	Curb Ramp E:
Curb Ramp B: LOOKING AT 119th NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	5.5 %	0.6 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	LAKE	119						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	5.0 %	1.2 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		5.5 %	0.6 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.5 %	0.9 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 39	Date: JUNE 12, 2012
Location: CENTRAL ALLEY NORTH OF 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT LAKE SE	Curb Ramp E:
Curb Ramp B: LOOKING AT 119th NE	Curb Ramp F:
Curb Ramp C: LOOKING AT 119th NW	Curb Ramp G:
Curb Ramp D: LOOKING AT LAKE SW	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,NE)	SE	NE	NW	SW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	40 "	40 "	40 "	38 "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 39	Date: JUNE 12, 2012
Location: CENTRAL ALLEY NORTH OF 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT LAKE SE	Curb Ramp E:
Curb Ramp B: LOOKING AT 119th NE	Curb Ramp F:
Curb Ramp C: LOOKING AT 119th NW	Curb Ramp G:
Curb Ramp D: LOOKING AT LAKE SW	Curb Ramp H:

17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	3.7 %	2.6 %	0.5 %	5.0 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	LAKE	119	119	LAKE				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	4.3 %	0.0 %	0.7 %	3.5 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.7 %	2.6 %	0.5 %	5.0 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.4 %	2.8 %	1.0 %	1.5 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		6.9 %	0.0 %	1.8 %	1.8 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or ~~N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction on grass on each side of CR that discourages pedestrians from traveling across ramp? If	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 40	Date: JUNE 12, 2012
Location: LAPORTE ALLEY NORTH OF 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT LAKE SE	Curb Ramp E:
Curb Ramp B: LOOKING AT 119th NE	Curb Ramp F:
Curb Ramp C: LOOKING AT 119th NW	Curb Ramp G:
Curb Ramp D: LOOKING AT LAKE SW	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,NE)	SE	NE	NW	SW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	46.5"	35 "	24 "	44 "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 40	Date: JUNE 12, 2012
Location: LAPORTE ALLEY NORTH OF 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT LAKE	SE	Curb Ramp E:	
Curb Ramp B: LOOKING AT 119th	NE	Curb Ramp F:	
Curb Ramp C: LOOKING AT 119th	NW	Curb Ramp G:	
Curb Ramp D: LOOKING AT LAKE	SW	Curb Ramp H:	

	CURB RAMP:	A	B	C	D				
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	3.8 %	0.8 %	2.2 %	4.5 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	LAKE	119	119	LAKE				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	3.6 %	0.5 %	2.3 %	4.2 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.8 %	0.8 %	2.2 %	4.5 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.6 %	1.9 %	1.6 %	1.5 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		7.2 %	1.6 %	1.1 %	13.3 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "D" # 32 : CURB ; BUILDING

C.R. "A" # 32 : CURB ; BUILDING

C.R. "B" # 32 : BUSHES

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 41	Date: JUNE 12, 2012
Location: SHERIDAN ALLEY NORTH OF 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT LAKE SE	Curb Ramp E:
Curb Ramp B: LOOKING AT 119th NE	Curb Ramp F:
Curb Ramp C: LOOKING AT 119th NW	Curb Ramp G:
Curb Ramp D: LOOKING AT LAKE SW	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,NE)	SE	NE	NW	SW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 41	Date: JUNE 12, 2012
Location: SHERIDAN ALLEY NORTH OF 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT LAKE	SE	Curb Ramp E:	
Curb Ramp B: LOOKING AT 119th	NE	Curb Ramp F:	
Curb Ramp C: LOOKING AT 119th	NW	Curb Ramp G:	
Curb Ramp D: LOOKING AT LAKE	SW	Curb Ramp H:	

	CURB RAMP	A	B	C	D				
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.50"	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	9.0 %	0.3 %	4.3 %	6.0 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	LAKE	119	119	LAKE				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	7.6 %	1.0 %	4.4 %	7.1 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		9.0 %	0.3 %	4.3 %	6.0 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.6 %	0.5 %	1.2 %	3.6 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		5.8 %	2.1 %	3.0 %	1.2 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.0"	— "	— "	.50"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" #27: LOTS OF STANDING WATER; #32: BUILDING CURB
C.R. "B" #32: FENCE/CURB
C.R. "D" #32: FENCE/CURB; #27: LOTS OF STANDING WATER

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 42	Date: JUNE 12, 2012
Location: OLIVER ALLEY NORTH OF 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT LAKE SW	Curb Ramp E:
Curb Ramp B: LOOKING AT 119th SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,NE)	SW	NW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	40 "	40 "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 42	Date: JUNE 12, 2012
Location: OLIVER ALLEY NORTH OF 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT LAKE SW	Curb Ramp E:
Curb Ramp B: LOOKING AT 119th NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	1.6 %	2.6 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	LAKE	119						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.9 %	2.9 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.6 %	2.6 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.0 %	0.4 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.9 %	1.9 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	.25 "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" #32: BUILDING

C.R. "B" #27: LOW CURB WHERE IT MEETS SIDEWALK

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 43	Date: 03-07-12
Location: 119th & ATCHISON	Surveyors: B. WAJVODA / J. MISTRO

Describe each curb ramp's location:	
Curb Ramp A: N (SIDE OF KEITHS)	Curb Ramp E:
Curb Ramp B: S (ILLIANA HOTEL)	Curb Ramp F:
Curb Ramp C: W (KNIGHTS OF COLUMBUS (LOOKING AT))	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	96"	96"	50"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	B	B	A					
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	F	B.C	B.C.					
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—					
5	If a curb ramp is not present, and if a curb is not present, Is there a flush transition from the street to the sidewalk?	Y or N N/A	Y or N N/A	Y or N N/A	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,NE)	N	S	W					
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.					
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N N/A	Y or N N/A	Y or N N/A	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.					
14	What type of transit stop is there? (none, bus, other)	N	N	N					
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	—"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	—"	—"	—"	"	"	"	"	"

Comments: C.R.C #9 FIRE HYDRANT & STANDING WATER

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 43	Date: 03-07-12
Location: 119th & ATCHISON	Surveyors: B. WAJVODA/J. MISTRO

Describe each curb ramp's location:	
Curb Ramp A: N SIDE OF KEITHS	Curb Ramp E:
Curb Ramp B: S ILLIANA HOTEL	Curb Ramp F:
Curb Ramp C: W (LOOKING AT KNIGHTS OF COLUMBUS)	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

17	Is a lip present at the bottom of the curb ramp?	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	0 "	.5 "	0 "	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	5.6 %	7.7 %	6.6 %	%	%	%	%	%
19	Is a side slope or parallel slope present?	(Y) or N	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	4.4 % 4.3 %	— % — %	— % — %	% %	% %	% %	% %	% %
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	119	119	ATCHI-SON					
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	.1 %	-3.1 %	3.2 %	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N "	(Y) or N "	Y or (N) 35 "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
24	Does CR have a running slope of 8.33% or less?	(Y) or N 5.6 %	(Y) or N 7.7 %	(Y) or N 6.6 %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
25	Does CR have a cross slope of 2% or less?	(Y) or N 1.9 %	Y or (N) 6.0 %	Y or (N) 5.3 %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
26	Does CR have a gutter slope of 5% or less?	(Y) or N 1.5 %	(Y) or N .7 %	(Y) or N 2.4 %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N "	(Y) or N "	Y or (N) 1.75 "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N 67 "	(Y) or N 62 "	(Y) or N 62 "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	N/A Y or N — %	N/A Y or N — %	N/A Y or N — %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N N/A	Y or N N/A	Y or N N/A	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	(X) or (N)	(X) or (N)	(X) or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	Y or (N) "	Y or N N/A "	Y or N N/A "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "

Comments: C.R. B #22 NEGATIVE SLOPE ; TRANSITION FROM SIDEWALK TO CURB RAMP IS LOWER THEN THE CURB RAMP

C.R. #27 HOLES IN ASPHALT

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 44	Date: 03-07-12
Location: 119th & INDIANAPOLIS BLVD	Surveyors: B. WAJVODA / J. MISTRO

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARD LIBERTY	Curb Ramp E:
Curb Ramp B: LOOKING TOWARD WHITE CASTLE	Curb Ramp F:
Curb Ramp C: LOOKING TOWARD FOUNTAIN	Curb Ramp G:
Curb Ramp D: LOOKING TOWARD KEITHS	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	72"	87"	86"	72"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.	B.C.	B.C.				
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	Y or N N/A	Y or N N/A	Y or N N/A	Y or N N/A	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,NE)								
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	I.R.	I.R.	I.R.	I.R.				
8	Is there a pedestrian Island or right turn lane?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N N/A	Y or N N/A	Y or N N/A	Y or N N/A	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	(Y) or N	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	T.C.	T.C.	T.C.	T.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	—"	—"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	—"	—"	—"	—"	"	"	"	"

Comments: C.R. B #9 PUSH BUTTON IN PATH OF C.R.

PEDESTRIAN SIGNAL BURNED OUT LOOKING TOWARD WHITE CASTLE

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 44	Date: 03-07-12
Location: 119th & INDIANAPOLIS BLVD.	Surveyors: B. NAIVODA / J. MISTRO

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARD LIBERTY	Curb Ramp E:
Curb Ramp B: LOOKING TOWARD WHITE CASTLE	Curb Ramp F:
Curb Ramp C: LOOKING TOWARD FOUNTAIN	Curb Ramp G:
Curb Ramp D: LOOKING TOWARD KEITHS	Curb Ramp H:

17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	5/8 "	5/8 "	7/8 "	0 "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	6.6 %	4.9 %	2.0 %	.9 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	119	INDY	INDY	119				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	4.1 %	0 %	1.4 %	.3 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		6.6 %	4.9 %	2.0 %	.9 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		5.5 %	6.4 %	.2 %	1.6 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.7 %	5.4 %	2.7 %	.8 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	N/A Y or N	N/A Y or N	N/A Y or N	N/A Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N N/A	Y or N N/A	Y or N N/A	Y or N N/A	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		N/A "	N/A "	N/A "	N/A "	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 45	Date: 03 - 07 - 12
Location: INDIANAPOLIS \ 119th (FOUNTAIN CORNER)	Surveyors: B. WAJVODA / J. MISTRO

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARD CLIPPER	Curb Ramp E:
Curb Ramp B: LOOKING AT ILLIANA HOTEL	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	84 -	86 "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	Y or N N/A	Y or N N/A	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,NE)	N.E.	N.W.						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	IRR	IRR						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N N/A	Y or N N/A	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	T.C.	T.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments: UTILITY POLE IN WAY

PEDESTRIAN SIGNAL IN WAY

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 45	Date: 03 - 07 - 12
Location: INDIANAPOLIS \ 119th (FOUNTAIN CORNER)	Surveyors: B. WAJVODA / J. MISTRO

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARD CLIPPER	Curb Ramp E:
Curb Ramp B: LOOKING TOWARD INDIANA HOTEL	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	1/4 "	1/4 "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	4.8 %	4.8%	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	119	INDY						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	2.6 %	1.3 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.8 %	4.8 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.8 %	2.8 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.5 %	4.5%	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	N/A Y or N	N/A Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N N/A	Y or N N/A	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 46	Date: 03-07-12
Location: INDIANAPOLIS \ CLEVELAND \ 119th	Surveyors: B. WAJYODA / J. MISTRO

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARD WHITE CASTLE (N)	Curb Ramp E:
Curb Ramp B: LOOKING TOWARD FOUNTAIN (S)	Curb Ramp F:
Curb Ramp C: LOOKING TOWARD FLAGS (W)	Curb Ramp G:
Curb Ramp D: LOOKING TOWARD CLIPPER (E)	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp 8	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	84"	86"	87"	84"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.	F	F				
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	Y or N N/A	Y or N N/A	Y or N N/A	Y or N N/A	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,NE)	N	S	W	E				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	IRR	IRR	IRR	IRR				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N N/A	Y or N N/A	Y or N N/A	Y or N N/A	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	T.C.	T.C.	T.C.	T.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	97"	97"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	—"	—"	24"	24"	"	"	"	"

Comments: C.R. C & C.R. D #16 2" GROOVES



Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 46	Date: 03-07-12
Location: INDIANAPOLIS\CLEVELAND\119th	Surveyors: B. WAJVODA / J. MISTRO

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARD WHITE CASTLE (N)	Curb Ramp E:
Curb Ramp B: LOOKING TOWARD FOUNTAIN (S)	Curb Ramp F:
Curb Ramp C: LOOKING TOWARD FLAGS (W)	Curb Ramp G:
Curb Ramp D: LOOKING TOWARD CLIPPER (E)	Curb Ramp H:

17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	5/8 "	1/2 "	1/2 "	1/2 "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	1.5 %	2.6 %	6.3 %	4.7 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	4.8 %	5.8 %	%	%	%	%
		— %	— %	5.2 %	6.6 %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	CLEVE-LAND	119	INDY	CLEVE-LAND				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	4.6 %	2.1 %	3.7 %	4.3 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.6 %	2.1 %	6.3 %	4.7 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.1 %	2.7 %	.2 %	.6 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.4 %	1.2 %	5.7 %	3.6 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	5 %	9.3 %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	N/AN	N/AN	N/AN	N/AN	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If	Y or N	Y or N	Y or N N/A	Y or N N/A	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	~~Y~~ or N	~~Y~~ or N	~~Y~~ or N	~~Y~~ or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	N/AN	N/AN	N/AN	N/AN	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. A HAS CRACKS

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 47	Date: JULY 10, 2012
Location: 119th & CENTRAL	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT FAMILY DOLLAR	NE	Curb Ramp E: LOOKING AT FAMILY DOLLAR	SW
Curb Ramp B: LOOKING AT WALGREENS	NE	Curb Ramp F: LOOKING AT WALGREENS SIGN	SW
Curb Ramp C: LOOKING AT CASTELAN JEWELRY	NW	Curb Ramp G: LOOKING AT CASTELAN JEWELRY	SE
Curb Ramp D: LOOKING AT FAGEN PHARMACY	NW	Curb Ramp H: LOOKING AT FAGEN PHARMACY	SE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	96"	72"	72"	96"	72"	70"	70"	72"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	B	A	A	B	A	C	C	A
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	PAN	B.C.	B.C.	PAN	B.C.	PAN	PAN
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	—
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NE	NW	NW	SW	SW	SE	SE
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	T.C.	T.C.	T.C.	T.C.	T.C.	T.C.	T.C.	T.C.
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	N
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	—"	—"	—"	—"	—"	—"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	40"	—"	40"	14"	—"	—"	—"	—"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 47	Date: JULY 10, 2012
Location: 119th & CENTRAL	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT FAMILY DOLLAR	NE	Curb Ramp E: LOOKING AT FAMILY DOLLAR	SW
Curb Ramp B: LOOKING AT WALGREENS	NE	Curb Ramp F: LOOKING AT WALGREENS SIGN	SW
Curb Ramp C: LOOKING AT CASTELAN JEWELRY	NW	Curb Ramp G: LOOKING AT CASTELAN JEWELRY	SE
Curb Ramp D: LOOKING AT FAGEN PHARMACY	NW	Curb Ramp H: LOOKING AT FAGEN PHARMACY	SE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	.25 "	— "	— "	— "	— "	— "	— "
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	5.8 %	7.9 %	%	%	14.9 %	2.6 %	4.5 %	10.4 %
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— % — %	— % — %	— % — %	— % — %	— % — %	— % — %	— % — %	— % — %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	CEN-TRAL	119	119	CEN-TRAL	119	CEN-TRAL	CEN-TRAL	119
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	2.3 %	4.8 %	%	%	9.8 %	4.3 %	0.8 %	8.1 %
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N — "	Y or N — "	Y or N "	Y or N "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
24	Does CR have a running slope of 8.33% or less?	Y or N 5.8 %	Y or N 7.9 %	Y or N %	Y or N %	Y or N 14.9 %	Y or N 2.6 %	Y or N 4.5 %	Y or N 10.4 %
25	Does CR have a cross slope of 2% or less?	Y or N 0.4 %	Y or N 0.5 %	Y or N %	Y or N %	Y or N 1.0 %	Y or N 3.1 %	Y or N 1.7 %	Y or N 0.3 %
26	Does CR have a gutter slope of 5% or less?	Y or N 3.7 %	Y or N 3.8 %	Y or N %	Y or N %	Y or N 2.8 %	~~Y or N~~ — %	~~Y or N~~ — %	Y or N 2.1 %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	— %	— %	— %	— %
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "

Comments: C.R. "A" #32: LIGHT POLE

C.R. "H" #32: LIGHT POLE

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 48	Date: APRIL 27, 2012
Location: 119th & TEMPLE	Surveyors: B. WAJVODA / J. MISTRO

Describe each curb ramp's location:	
Curb Ramp A: SE LOOKING AT CENTER LOUNGE	Curb Ramp E:
Curb Ramp B: SW LOOKING AT VACANT BUILDING	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	97"	97"	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	B	B						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	—"	—"	"	"	"	"	"	"

Comments: CURB RAMP "A" HAS A CRACK

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 48	Date: APRIL 27, 2012
Location: 119th & TEMPLE	Surveyors: B. WASVODA/J. MISTRO

Describe each curb ramp's location:	
Curb Ramp A: SE LOOKING AT CENTER LOUNGE	Curb Ramp E:
Curb Ramp B: SW LOOKING AT VACANT BUILDING	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	2.0 "	.25 "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	2.1 %	1.9 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	TEMPLE	TEMPLE						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	4.7 %	2.0 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.1 %	1.9 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.7 %	5.0 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		.4 %	.5 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2 "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	2.1 %	1.9 %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	(X) or (N)	(X) or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: CURB RAMP "B" CRACK IN RAMP

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 48.A	Date: SEPTEMBER 10, 2012
Location: TEMPLE ALLEY B/T 119½ & COMMUNITY	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT COMMUNITY	NE	Curb Ramp E:	
Curb Ramp B: LOOKING AT 119	SE	Curb Ramp F:	
Curb Ramp C: LOOKING AT 119	SW	Curb Ramp G:	
Curb Ramp D: LOOKING AT COMMUNITY	NW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C	C	C				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	SE	SW	NW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	S.S.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 48. A	Date: SEPTEMBER 10, 2012
Location: TEMPLE ALLEY B/T 119th & COMMUNITY	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT COMMUNITY	NE	Curb Ramp E:	
Curb Ramp B: LOOKING AT 119th	SE	Curb Ramp F:	
Curb Ramp C: LOOKING AT 119th	SW	Curb Ramp G:	
Curb Ramp D: LOOKING AT COMMUNITY	NW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	.25 "	.25 "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	8.1 %	5.5 %	7.6 %	13.1 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	COMM-UNITY	119	119	COMM-UNITY				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	10.0 %	0.3 %	8.5 %	11.3 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		8.1 %	5.5 %	7.6 %	13.1 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.0 %	2.3 %	0.9 %	4.1 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	4.5 %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	.25 "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" #32: BUILDING / CURB
C.R. "B" #32: BUILDING / CURB
C.R. "C" #27: LOW CURB TRANSITION/GUTTER SLOPE; #32: LANDSCAPING

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 49	Date: APRIL 27, 2012
Location: 119th & LAPORTE	Surveyors: B. WASVODA / J. MISTRO

Describe each curb ramp's location:	
Curb Ramp A: NE LOOKING AT HORIZON BANK	Curb Ramp E:
Curb Ramp B: NE LOOKING AT SHERMAN BUILDING	Curb Ramp F:
Curb Ramp C: SE LOOKING AT VACANT BUILDING	Curb Ramp G:
Curb Ramp D: NW LOOKING AT VACANT BUILDING	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	96"	71"	71"	96"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	B	A	A	B				
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C	B.C.	F	B.C.				
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NE	SE	NW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	—"	—"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	—"	—"	—"	—"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 49	Date: APRIL 27, 2012
Location: 119th & LAPORTE	Surveyors: B. WAJVODA / J. MISTRO

Describe each curb ramp's location:			
Curb Ramp A: NE	LOOKING AT HORIZON BANK	Curb Ramp E:	
Curb Ramp B: NE	LOOKING AT SHERMAN BUILDING	Curb Ramp F:	
Curb Ramp C: SE	LOOKING AT VACANT BUILDING	Curb Ramp G:	
Curb Ramp D: NW	LOOKING AT VACANT BUILDING	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	(Y) or N	Y or (N)	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	1.0 "	— "	.25 "	.25 "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	1.9 %	2.4 %	14.1 %	3.0 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	6.9 %	— %	%	%	%	%
		— %	— %	4.7 %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	LAPORTE	119	119	LAPORTE				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.6 %	0.8 %	11.6 %	4.9 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N
		1.9 %	2.4 %	14.1 %	3.0 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	(Y) or N	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N
		0.9 %	0.1 %	1.0 %	2.8 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		0.2 %	1.3 %	1.9 %	0.1 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or (N)	(Y) or N	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N
		SEE NOTE "	— "	— "	SEE NOTE "	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	1.9 %	2.4 %	14.1 %	3.0 %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	~~(Y)~~ or (N)	~~(Y)~~ or (N)	~~(Y)~~ or (N)	~~(Y)~~ or (N)	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: CURB RAMP "A" & "D" EXTEMELY WAVEY BRICK WORK FROM CARS REPEATEDLY DRIVING OVER IT CREATING GROOVES.

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 50	Date: APRIL 27, 2012
Location: 119th & SHERIDAN	Surveyors: B. WASVODA/J. MISTRO

Describe each curb ramp's location:	
Curb Ramp A: SE LOOKING AT LUBIAS	Curb Ramp E:
Curb Ramp B: NE LOOKING AT WIRELESS	Curb Ramp F:
Curb Ramp C: NE LOOKING AT SALON	Curb Ramp G:
Curb Ramp D: NW LOOKING AT LUBIAS	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	70 "	70 "	97 "	97 "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	B	B				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	F	B.C.	B.C.	B.C.				
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	NE	NE	NW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	T.C.	T.C.	T.C.	T.C.				
14	What type of transit stop is there? (none, bus, other)	N	B	B	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 50	Date: APRIL 27, 2012
Location: 119th & SHERIDAN	Surveyors: B. WASVODA / J. MISTRO

Describe each curb ramp's location:	
Curb Ramp A: SE LOOKING AT LUBIAS	Curb Ramp E:
Curb Ramp B: NE LOOKING AT WIRELESS	Curb Ramp F:
Curb Ramp C: NE LOOKING AT SALON	Curb Ramp G:
Curb Ramp D: NW LOOKING AT LUBIAS	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	.25 "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	11.1 %	3.7 %	2.5 %	3.9 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	4.6 %	— %	— %	7.4 %	%	%	%	%
		5.3 %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	119	119	SHERIDAN	SHERIDAN				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	11.0%	4.5 %	2.8 %	5.9 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		11.1 %	3.7 %	2.5 %	3.9 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.6 %	3.5 %	3.8 %	4.1 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.1 %	4.9 %	0.3 %	1.2 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		.25 "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	YES %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	Y or N	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		11.1 %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	~~Y or N~~	Y or N	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	~~Y~~ or N	~~Y~~ or N	~~Y~~ or N	~~Y~~ or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: STANDING WATER

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 50.A	Date: APRIL 27, 2012
Location: 119th & CLARK	Surveyors: B. WAJVODA/J. MISTRO

Describe each curb ramp's location:			
Curb Ramp A:	NE LOOKING AT SUNRISE	Curb Ramp E:	
Curb Ramp B:	SE LOOKING AT FLOWER SHOP	Curb Ramp F:	
Curb Ramp C:	SE LOOKING AT LEVIN	Curb Ramp G:	
Curb Ramp D:	SW LOOKING AT SUNRISE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	72 "	72 "	97 "	97 "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	B	B				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	F	B.C.	B.C.	B.C.				
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	SE	SE	SW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	T.C.	T.C.	T.C.	T.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 50.A	Date: APRIL 27, 2012
Location: 119th & CLARK	Surveyors: B. WAJVODA/J. MISTRO

Describe each curb ramp's location:			
Curb Ramp A:	NE LOOKING AT SUNRISE	Curb Ramp E:	
Curb Ramp B:	SE LOOKING AT FLOWER SHOP	Curb Ramp F:	
Curb Ramp C:	SE LOOKING AT LEVIN	Curb Ramp G:	
Curb Ramp D:	SW LOOKING AT SUNRISE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	.25 "	.25 "	.5 "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	9.3 %	5.1 %	5.0 %	4.7 %	%	%	%	%
19	Is a side slope or parallel slope present?	(Y) or N	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	8.8 % 6.4 %	— % — %	— % — %	— % — %	% %	% %	% %	% %
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	119	119	CLARK	CLARK				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	6.0 %	2.0 %	4.6 %	3.6 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N — "	(Y) or N — "	(Y) or N — "	(Y) or N — "	Y or N "	Y or N "	Y or N "	Y or N "
24	Does CR have a running slope of 8.33% or less?	Y or (N) 9.3 %	(Y) or N 5.1 %	(Y) or N 5.0 %	(Y) or N 4.7 %	Y or N %	Y or N %	Y or N %	Y or N %
25	Does CR have a cross slope of 2% or less?	(Y) or N 1.0 %	Y or (N) 5.0 %	Y or (N) 3.5 %	Y or (N) 2.1 %	Y or N %	Y or N %	Y or N %	Y or N %
26	Does CR have a gutter slope of 5% or less?	Y or (N) 5.2 %	(Y) or N 2.1 %	(Y) or N 0.6 %	(Y) or N 1.8 %	Y or N %	Y or N %	Y or N %	Y or N %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N — "	Y or (N) .25 "	Y or (N) .25 "	Y or (N) .5 "	Y or N "	Y or N "	Y or N "	Y or N "
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N — "	(Y) or N — "	(Y) or N — "	Y or (N) "	Y or N "	Y or N "	Y or N "	Y or N "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	(Y) or N	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	9.3 %	— %	5.0 %	4.7 %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	Y or N %	Y or N %	Y or N %	Y or N %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	~~Y or N~~	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	(X) or (N)	(X) or (N)	(X) or (N)	(X) or (N)	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	Y or N "	Y or N "	Y or N "	Y or N "

Comments: CURB RAMP "A" - STANDING WATER

CURB RAMP "B" & "C" - HOLES

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 51	Date: APRIL 13, 2012
Location: 119th & OLIVER	Surveyors: B. WAJVODA/J. MISTRO

Describe each curb ramp's location:	
Curb Ramp A: NE LOOKING TOWARD ABC	Curb Ramp E:
Curb Ramp B: NW LOOKING TOWARD SCHOOL	Curb Ramp F:
Curb Ramp C: NE LOOKING TOWARD HERBALIFE	Curb Ramp G:
Curb Ramp D: SE LOOKING TOWARD SCHOOL	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	100 "	100 "	71 "	71 "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	B	B	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.	F	F				
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NW	NE	SE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	(Y) or N	(Y) or N	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments: #9 CURB RAMP "D" - TRIPPING HAZARD

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 51	Date: APRIL 13, 2012
Location: 119th & OLIVER	Surveyors: B. WAJVODA/J. MISTRO

Describe each curb ramp's location:	
Curb Ramp A: NE LOOKING TOWARD ABC	Curb Ramp E:
Curb Ramp B: NW LOOKING TOWARD SCHOOL	Curb Ramp F:
Curb Ramp C: NE LOOKING TOWARD HERBALIFE	Curb Ramp G:
Curb Ramp D: SE LOOKING TOWARD SCHOOL	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25 "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	2.2 %	3.0 %	0.8 %	7.1 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	0.8 %	0.1 %	— %	6.6 %	%	%	%	%
		— %	— %	— %	5.2 %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	OLIVER	OLIVER	119	119				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	4.6 %	3.1 %	4.6 %	9.0 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.2 %	3.0 %	0.8 %	7.1 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.7 %	0.9 %	2.8 %	0.1 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.0 %	0.2 %	0.9 %	1.2 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	1 "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
		2.2 %	3.0 %	— %	7.1 %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	⊗ or N	⊗ or N	⊗ or N	⊗ or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: #27 CURB RAMP "D" TRIPPING HAZARD

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 52	Date: JUNE 28, 2012
Location: 117th ALLEY OF OHIO NEAR LITTLE LEAGUE FIELD	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT SPORTS COMPLEX SE	Curb Ramp E:
Curb Ramp B: LOOKING AT 119th NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,NE)	SE	NE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments: #9 C.R. "A" : HIGH CURB TRANSITION

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 52	Date: JUNE 28, 2012
Location: 117th ALLEY OF OHIO NEAR LITTLE LEAGUE FIELD	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT SPORTS COMPLEX SE	Curb Ramp E:
Curb Ramp B: LOOKING AT 119th NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

17	Is a lip present at the bottom of the curb ramp?	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25 "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.9 %	5.1 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	117	OHIO						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.1 %	2.4 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.9 %	5.1 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		7.0 %	3.9 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	(Y) or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.6 %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.5 "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: # 32 C.R. "A" : LANDSCAPING / CURB

"B" : LANDSCAPING / CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 53	Date: JUNE 28, 2012
Location: OHIO & OLIVER	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT LAKE	SE	Curb Ramp E:	
Curb Ramp B: LOOKING AT HOUSE	SE	Curb Ramp F:	
Curb Ramp C: LOOKING AT 119th	NE	Curb Ramp G:	
Curb Ramp D: LOOKING AT LIBRARY	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SE	NE	SW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	IRR.	IRR.	IRR.	IRR.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	"	"	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 53	Date: JUNE 28, 2012
Location: OHIO & OLIVER	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT LAKE	SE	Curb Ramp E:	
Curb Ramp B: LOOKING AT HOUSE	SE	Curb Ramp F:	
Curb Ramp C: LOOKING AT 119th	NE	Curb Ramp G:	
Curb Ramp D: LOOKING AT LIBRARY	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	.50 "	.50 "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	5.0 %	6.7 %	6.2 %	4.9 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— % / — %	— % / — %	— % / — %	— % / — %	% / %	% / %	% / %	% / %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	OHIO	OLI-VER	OLI-VER	OLI-VER				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	6.3 %	6.0 %	3.1 %	3.1 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / "	Y or N / "	Y or N / "	Y or N / "
24	Does CR have a running slope of 8.33% or less?	Y or N / 5.0 %	Y or N / 6.7 %	Y or N / 6.2 %	Y or N / 4.9 %	Y or N / %	Y or N / %	Y or N / %	Y or N / %
25	Does CR have a cross slope of 2% or less?	Y or N / 0.6 %	Y or N / 1.6 %	Y or N / 0.2 %	Y or N / 0.4 %	Y or N / %	Y or N / %	Y or N / %	Y or N / %
26	Does CR have a gutter slope of 5% or less?	Y or N / 1.7 %	Y or N / 3.7 %	Y or N / 2.8 %	Y or N / 5.9 %	Y or N / %	Y or N / %	Y or N / %	Y or N / %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / "	Y or N / "	Y or N / "	Y or N / "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / "	Y or N / "	Y or N / "	Y or N / "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	Y or N / %	Y or N / %	Y or N / %	Y or N / %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	⊗ or N	⊗ or N	⊗ or N	⊗ or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	Y or N / "	Y or N / "	Y or N / "	Y or N / "

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 54	Date:
Location: SCHOOL PARKING LOT ADJ. OHIO AVENUE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT LIBRARY SE	Curb Ramp E:
Curb Ramp B: LOOKING AT NEW YORK AVENUE SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	72"	72"	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	—"	—"	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 54	Date:
Location: SCHOOL PARKING LOT ADJ. OHIO AVENUE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT LIBRARY SE	Curb Ramp E:
Curb Ramp B: LOOKING AT NEW YORK AVENUE SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	1.3 %	0.7 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	OLI-VER	NEW YORK						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	5.3 %	1.6 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.3 %	0.7 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.2 %	1.9 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 55	Date:
Location: NEW YORK & OHIO	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT LAKE	SW	Curb Ramp E: LOOKING AT LAKE	SE
Curb Ramp B: LOOKING AT WHITE HOUSE	SW	Curb Ramp F:	
Curb Ramp C: LOOKING AT SCHOOL	NW	Curb Ramp G:	
Curb Ramp D: LOOKING AT SCHOOL	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	70"	72"	70"	72"	—	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	B	A	B	A			
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.		B.C.		B.C.	B.C.			
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—			
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SW	NW	SE	SE			
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	IRR.	IRR.	IRR.	IRR.	IRR.			
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.	S.S.			
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N			
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	—"	—"	—"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	—"	—"	—"	—"	—"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 55	Date:
Location: NEW YORK & OHIO	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT LAKE	SW	Curb Ramp E: LOOKING AT LAKE	SE
Curb Ramp B: LOOKING AT WHITE HOUSE	SW	Curb Ramp F:	
Curb Ramp C: LOOKING AT SCHOOL	NW	Curb Ramp G:	
Curb Ramp D: LOOKING AT SCHOOL	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	.25 "	— "	— "	— "	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	10.1 %	6.5 %	8.7 %	2.0 %	2.0 %	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	4.2 % — %	5.5 % 1.9 %	— % — %	1.1 % 0.4 %	1.1 % 0.4 %	% %	% %	% %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	OHIO	NEW YORK	OHIO	NEW YORK	OHIO			
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	5.5 %	10.0 %	5.0 %	2.0 %	1.3 %	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N "	Y or N "	Y or N "
24	Does CR have a running slope of 8.33% or less?	Y or N 10.1 %	Y or N 6.5 %	Y or N 8.7 %	Y or N 2.0 %	Y or N 2.0 %	Y or N %	Y or N %	Y or N %
25	Does CR have a cross slope of 2% or less?	Y or N 0.7 %	Y or N 0.5 %	Y or N 0.6 %	Y or N 0.7 %	Y or N 0.7 %	Y or N %	Y or N %	Y or N %
26	Does CR have a gutter slope of 5% or less?	Y or N 3.4 %	Y or N 1.9 %	Y or N 4.1 %	Y or N 1.2 %	Y or N 1.2 %	Y or N %	Y or N %	Y or N %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N .5 "	Y or N — "	Y or N .25 "	Y or N — "	Y or N — "	Y or N "	Y or N "	Y or N "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N "	Y or N "	Y or N "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	YES %	— %	YES %	YES %	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	Y or N %	Y or N %	Y or N %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	~~Y or N~~	Y or N	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	⊗ or N	⊗ or N	⊗ or N	⊗ or N	⊗ or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	Y or N "	Y or N "	Y or N "

Comments: C.R. "A" #27: HIGH SIDEWALK TRANSITION
C.R. "C" #27: HIGH CURB & SIDEWALK TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 56	Date: JULY 18, 2012
Location: NEW YORK ALLEY NORTH OF 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT LAKE	SW	Curb Ramp E:	
Curb Ramp B: LOOKING AT 119th	NW	Curb Ramp F:	
Curb Ramp C: LOOKING AT LAKE	SE	Curb Ramp G:	
Curb Ramp D: LOOKING AT 119th	NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	74 "	74 "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C	C	C				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	NW	SE	NE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" #9: UTILITY POLE

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 56	Date: JULY 18, 2012
Location: NEW YORK ALLEY NORTH OF 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT LAKE	SW	Curb Ramp E:	
Curb Ramp B: LOOKING AT 119th	NW	Curb Ramp F:	
Curb Ramp C: LOOKING AT LAKE	SE	Curb Ramp G:	
Curb Ramp D: LOOKING AT 119th	NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	4.5 %	10.1 %	0.6 %	0.2 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	LAKE	119	LAKE	119				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	3.2 %	9.9 %	0.9 %	1.6 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.5 %	10.1 %	0.6 %	0.2 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.9 %	6.9 %	2.9 %	1.8 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction o grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "C" #32: FENCE/GRASS
C.R. "B" #32: FENCE/CURB
C.R. "A" #32: LANDSCAPE/CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 57	Date: 02-29-12
Location: NEW YORK AVENUE / 119th STREET	Surveyors: J. MISTRO / B. WASVODA

Describe each curb ramp's location:	
Curb Ramp A: CHASE BANK	Curb Ramp E: —
Curb Ramp B: POST OFFICE	Curb Ramp F: —
Curb Ramp C: CHRISLOVE COLLECTABLES	Curb Ramp G: —
Curb Ramp D: CENTIER BANK	Curb Ramp H: —

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	96"	96"	96"	96"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	B	B	B	B				
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	BC	BC	BC	BC				
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	N/A	N/A	N/A	N/A				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~ N/A	~~Y or N~~ N/A	~~Y or N~~ N/A	~~Y or N~~ N/A	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,NE)	NW	NE	SE	SW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	RA	RA	RA	RA				
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~ N/A	~~Y or N~~ N/A	~~Y or N~~ N/A	~~Y or N~~ N/A	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	(Y) or N	(Y) or (N)	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	T.C	T.C	T.C.	T.C				
14	What type of transit stop is there? (none, bus, other)	N	B	N	N				
15	What are the dimensions of any common landing for two curb ramps?	N/A"	N/A"	N/A"	N/A"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	N/A"	N/A"	N/A"	N/A"	"	"	"	"

Comments: #9 C.R. (C) 2 PUDDLES

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 57	Date: 02-29-12
Location: NEW YORK AVENUE / 119th STREET	Surveyors: B. WAJVODA / J. MISTRO

Describe each curb ramp's location:	
Curb Ramp A: CHASE	Curb Ramp E:
Curb Ramp B: POST OFFICE	Curb Ramp F:
Curb Ramp C: CHRIS LOVE	Curb Ramp G:
Curb Ramp D: CENTIER	Curb Ramp H:

17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.5 "	.25 "	.0 "	.0 "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	4.2 %	5.9 %	5.7 %	5.2 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	1.5 % 3.3 %	1.8 % 3.0 %	1.4 % 3.1 %	1.7 % 3.1 %	% %	% %	% %	% %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	FACING INTER.	F.I.	F.I.	F.I.				
22	What is the slope of the transition to the sidewalk? (should be 5% or less)	4.2 %	5.0 %	4.2 %	5.1 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
24	Does CR have a running slope of 8.33% or less?	Y or N 2.6 %	Y or N 5.3 %	Y or N 4.1 %	Y or N 6.6 %	Y or N %	Y or N %	Y or N %	Y or N %
25	Does CR have a cross slope of 2% or less?	Y or N .3 %	Y or N 1.2 %	Y or N .4 %	Y or N 1.0 %	Y or N %	Y or N %	Y or N %	Y or N %
26	Does CR have a gutter slope of 5% or less?	Y or N 1.4 %	Y or N .7 %	Y or N 1.4 %	Y or N 4.2 %	Y or N %	Y or N %	Y or N %	Y or N %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N .5 "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	%	%	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~ N/A	~~Y or N~~ N/A	~~Y or N~~ N/A	~~Y or N~~ N/A	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "

Comments: C.R. (C) LARGE CRACK IN GUTTER

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 58	Date: JULY 19, 2012
Location: PENNSYLVANIA & 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT ELKS	NE	Curb Ramp E: LOOKING AT 1530 119th	SW
Curb Ramp B: LOOKING AT 1533 119th	NW	Curb Ramp F: LOOKING AT BUILDING	SE
Curb Ramp C: LOOKING AT PARKING LOT	NW	Curb Ramp G: LOOKING AT 1533 119th	SE
Curb Ramp D: LOOKING AT ELKS	SW	Curb Ramp H: LOOKING AT 1530 119th	NE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	72"	72"	72"	72"	96"	96"	—"	—"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	B	B	A	A	B	B	A	A
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	—
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NW	NW	SW	SW	SE	SE	NE
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	N.C.	N.C.	N.C.	N.C.	S.S.
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	N
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	—"	—"	—"	—"	—"	—"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	24"	—"	—"	24"	24"	24"	24"	—"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 58	Date: JULY 19, 2012
Location: PENNSYLVANIA & 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT ELKS	NE	Curb Ramp E: LOOKING AT 1530 119th	SW
Curb Ramp B: LOOKING AT 1533 119th	NW	Curb Ramp F: LOOKING AT BUILDING	SE
Curb Ramp C: LOOKING AT PARKING LOT	NW	Curb Ramp G: LOOKING AT 1533 119th	SE
Curb Ramp D: LOOKING AT ELKS	SW	Curb Ramp H: LOOKING AT 1530 119th	NE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	.25 "	— "	— "	— "	— "	— "	— "
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	3.7 %	4.5 %	3.6 %	5.1 %	1.4 %	3.9 %	7.7 %	5.6 %
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	6.4 % 4.5 %	5.8 % 3.4 %	5.8 % 3.4 %	6.1 % 11.3 %	6.1 % 11.3 %	10.2 % 10.2 %	5.6 % 4.8 %	6.4 % 4.5 %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	PENN.	PENN.	119	119	PENN.	PENN.	119	119
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	4.2 %	3.8 %	0.8 %	4.8 %	4.1 %	2.2 %	6.1 %	0.7 %
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
24	Does CR have a running slope of 8.33% or less?	Y or N 3.7 %	Y or N 4.5 %	Y or N 3.6 %	Y or N 5.1 %	Y or N 1.4 %	Y or N 3.9 %	Y or N 7.7 %	Y or N 5.6 %
25	Does CR have a cross slope of 2% or less?	Y or N 1.1 %	Y or N 0.2 %	Y or N 1.7 %	Y or N 1.4 %	Y or N 3.2 %	Y or N 0.4 %	Y or N 0.5 %	Y or N 2.4 %
26	Does CR have a gutter slope of 5% or less?	Y or N 1.4 %	Y or N 1.4 %	Y or N 1.6 %	Y or N 0.5 %	Y or N 1.4 %	Y or N 2.6 %	Y or N 2.9 %	Y or N 2.2 %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N .5 "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES %	YES %	YES %	NO %	NO %	NO %	YES %	YES %
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	⊗ or N	⊗ or N	⊗ or N	⊗ or N	⊗ or N	⊗ or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "

Comments: C.R. "A" #27: HIGH GUTTER SLOPE

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 59	Date: JULY 24, 2012
Location: PENNSYLVANIA ALLEY NORTH OF 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT OHIO	SE	Curb Ramp E:	
Curb Ramp B: LOOKING AT 119th	NE	Curb Ramp F:	
Curb Ramp C: LOOKING AT 119th	NW	Curb Ramp G:	
Curb Ramp D: LOOKING AT OHIO	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	84"	84"	85"	85"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C	C	C				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	NE	NW	SW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	—"	—"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	—"	—"	—"	—"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 59	Date: JULY 24, 2012
Location: PENNSYLVANIA ALLEY NORTH OF 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT OHIO	SE	Curb Ramp E:	
Curb Ramp B: LOOKING AT 119th	NE	Curb Ramp F:	
Curb Ramp C: LOOKING AT 119th	NW	Curb Ramp G:	
Curb Ramp D: LOOKING AT OHIO	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.1 %	1.4 %	0.4 %	0.1 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	OHIO	119	119	OHIO				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.5 %	1.2 %	0.6 %	0.3 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.1 %	1.4 %	0.4 %	0.1 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.9 %	3.6 %	4.2 %	3.4 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" #32: DRIVEWAY
C.R. "B" #32: GRASS/LANDSCAPE
C.R. "D" #32: GRASS/CURB/POLE

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 60	Date: JULY 19, 2012
Location: PENNSYLVANIA & OHIO	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT CORNER HOUSE	SW	Curb Ramp E:	
Curb Ramp B: LOOKING AT 1537 OHIO	SW	Curb Ramp F:	
Curb Ramp C: LOOKING AT OHIO AVENUE	NW	Curb Ramp G:	
Curb Ramp D: LOOKING AT PENNSYLVANIA AVE.	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	B	A	A	B				
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	YES				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SW	NW	SE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	72 x 72 "	72 x 72 "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 60	Date: JULY 19, 2012
Location: PENNSYLVANIA & OHIO	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT CORNER HOUSE	SW	Curb Ramp E:	
Curb Ramp B: LOOKING AT 1537 OHIO	SW	Curb Ramp F:	
Curb Ramp C: LOOKING AT OHIO AVENUE	NW	Curb Ramp G:	
Curb Ramp D: LOOKING AT PENNSYLVANIA AVE.	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	9.0 %	7.3 %	7.5 %	7.3 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	PENN.	OHIO	OHIO	PENN.				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	6.4 %	2.7 %	9.3 %	8.8 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		9.0 %	7.3 %	7.5 %	7.3 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.1 %	2.2 %	0.1 %	4.6 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		3.5 %	3.4 %	1.8 %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	.5 "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction on grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "D" #27: HIGH CURB TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 60.A	Date: JULY 18, 2012
Location: OHIO ALLEY B/T NEW YORK & PENNSYLVANIA	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT PENNSYLVANIA SW	Curb Ramp E:
Curb Ramp B: LOOKING AT NEW YORK SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 60. A	Date: JULY 18, 2012
Location: OHIO ALLEY B/T NEW YORK & PENNSYLVANIA	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOORING AT NEW YORK SE	Curb Ramp E:
Curb Ramp B: LOOKING AT PENNSYLVANIA SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.4 %	0.6 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	N.Y.	PENN.						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.3 %	1.2 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.4 %	0.6 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.5 %	2.2 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 61	Date: JULY 18, 2012
Location: OHIO ALLEY NORTH OF 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 119th SW	Curb Ramp E:
Curb Ramp B: LOOKING AT PENNSYLVANIA SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	72"	72"	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop-sign, yield control, or no control)	S.S.	S.S.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	—"	—"	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 61	Date: JULY 18, 2012
Location: OHIO ALLEY NORTH OF 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 119th SW	Curb Ramp E:
Curb Ramp B: LOOKING AT PENNSYLVANIA SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	2.7 %	0.2 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	119	PENN.						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.7 %	0.3 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.7 %	0.2 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.0 %	3.6 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 62	Date: JULY 24, 2012
Location: WHITE OAK & 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 1544 119th SE	Curb Ramp E:
Curb Ramp B: LOOKING AT WHITE OAK CAFE SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	97"	97"	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	B	B						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control).	S.S.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 62	Date: JULY 24, 2012
Location: WHITE OAK & 119th	Surveyors: B. WASVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 1544 119th SE	Curb Ramp E:
Curb Ramp B: LOOKING AT WHITE OAK CAFE SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	.25 "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	10.3 %	6.4 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	8.5 % 3.9 %	5.9 % 4.1 %	% %	% %	% %	% %	% %	% %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	WHITE OAK	WHITE OAK						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.6 %	3.6 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N — "	Y or N — "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
24	Does CR have a running slope of 8.33% or less?	Y or N 10.3 %	Y or N 6.4 %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
25	Does CR have a cross slope of 2% or less?	Y or N 1.3 %	Y or N 3.0 %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
26	Does CR have a gutter slope of 5% or less?	Y or N 1.5 %	Y or N 1.2 %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N — "	Y or N — "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N — "	Y or N — "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES %	YES %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ — %	~~Y or N~~ — %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ — "	~~Y or N~~ — "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 63	Date: JULY 24, 2012
Location: OHIO & 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT PARKING LOT	NE	Curb Ramp E:	
Curb Ramp B: LOOKING AT OHIO	NW	Curb Ramp F:	
Curb Ramp C: LOOKING AT MUSEUM	NW	Curb Ramp G:	
Curb Ramp D: LOOKING AT PARKING LOT	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	96"	96"	72"	72"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	B	B	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.	B.C.	B.C.				
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NW	NW	SW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	T.C.	T.C.	T.C.	T.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	—"	—"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	—"	—"	—"	—"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 63	Date: JULY 24, 2012
Location: OHIO & 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT PARKING LOT	NE	Curb Ramp E:	
Curb Ramp B: LOOKING AT OHIO	NW	Curb Ramp F:	
Curb Ramp C: LOOKING AT MUSEUM	NW	Curb Ramp G:	
Curb Ramp D: LOOKING AT PARKING LOT	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	"	— "	.5 "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	%	2.8 %	2.8 %	10.1 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	%	7.6 %	7.6 %	6.6 %	%	%	%	%
		%	6.7 %	6.7 %	8.8 %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	OHIO	OHIO	119	119				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	%	3.6 %	10.6 %	12.7 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	2.8 %	2.8 %	10.1 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	0.5 %	2.0 %	0.7 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	0.5 %	2.6 %	3.9 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	%	YES %	YES %	YES %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	Y or N	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		%	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	⊗ or N	⊗ or N	⊗ or N	⊗ or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 64	Date: JULY 24, 2012
Location: 119th ALLEY EAST OF OHIO AVENUE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT OHIO AVE. NE	Curb Ramp E:
Curb Ramp B: LOOKING AT FRONT ST. NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 64	Date: JULY 24, 2012
Location: 119th ALLEY EAST OF OHIO AVENUE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT OHIO AVE. NE	Curb Ramp E:
Curb Ramp B: LOOKING AT FRONT ST. NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	6.1 %	4.2 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	OHIO	FRONT						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	3.6 %	3.4 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		6.1 %	4.2 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.7 %	0.4 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" #32 : CURB / POLE / GRASS

"B" #32 : CURB / BUILDING

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 65	Date: JULY 24, 2012
Location: CENTER STREET & CENTER COURT	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT ISLAND	SE	Curb Ramp E:	
Curb Ramp B: LOOKING AT SOFTBALL FIELD	SE	Curb Ramp F:	
Curb Ramp C: LOOKING AT 1644 CENTER CT.	SW	Curb Ramp G:	
Curb Ramp D: LOOKING AT 119th	NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.				—				
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	V				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SE	SW	NE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	~~Y or N~~	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	S.S.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	60 x 60 "	60 x 60 "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 65	Date: JULY 24, 2012
Location: CENTER STREET & CENTER COURT	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT ISLAND	SE	Curb Ramp E:	
Curb Ramp B: LOOKING AT SOFTBALL FIELD	SE	Curb Ramp F:	
Curb Ramp C: LOOKING AT 1644 CENTER CT.	SW	Curb Ramp G:	
Curb Ramp D: LOOKING AT 119th	NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25 "	.25 "	.25 "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	5.6 %	9.1 %	12.4 %	— %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	CENTER COURT	CENTER STREET	CENTER COURT	CENTER STREET				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	2.9 %	0.6 %	1.7 %	— %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		5.6 %	9.1 %	12.4 %	— %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		4.3 %	1.9 %	7.7 %	— %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		3.7 %	4.5 %	5.9 %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		.5 "	.5 "	.5 "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" #27: HIGH CURB TRANSITION
C.R. "B" #27: HIGH CURB TRANSITION
C.R. "C" #27: HIGH CURB TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 66	Date: JULY 24, 2012
Location: CENTER STREET ALLEY EAST OF CENTER COURT	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 1656 CENTER ST.	SW	Curb Ramp E:	
Curb Ramp B: LOOKING AT CENTER CT.	SE	Curb Ramp F:	
Curb Ramp C: LOOKING AT SOFTBALL FIELD	NE	Curb Ramp G:	
Curb Ramp D: LOOKING AT 1647 CENTER ST.	NW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SE	NE	NW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A	R.A.	R.A	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	N.C.	S.S.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	30 "	— "	— "	"	"	"	"

Comments: C.R. "C": SMASHED UP

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 66	Date: JULY 24, 2012
Location: CENTER STREET ALLEY EAST OF CENTER COURT	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 1656 CENTER ST.	SW	Curb Ramp E:	
Curb Ramp B: LOOKING AT CENTER CT.	SE	Curb Ramp F:	
Curb Ramp C: LOOKING AT SOFTBALL FIELD	NE	Curb Ramp G:	
Curb Ramp D: LOOKING AT 1647 CENTER ST.	NW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	.25 "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	4.4 %	0.7 %	4.3 %	5.9 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	ALLEY	CENTER CT.	ALLEY	ALLEY				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	3.7 %	1.0 %	2.8 %	3.0 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.4 %	0.7 %	4.3 %	5.9 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.3 %	3.9 %	3.4 %	3.5 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		2.3 %	2.7 %	2.8 %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	.50 "	.50 "	.25 "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" #32: DRIVEWAY/GRASS ; C.R. "B" #27: HIGH CURB TRANSITION
C.R. "B" #32: GRASS/LANDSCAPE ; C.R. "C" #27: HIGH CURB TRANSITION
C.R. "D" #32: GRASS/CURB ; C.R. "D" #27: LIP

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 67	Date: APRIL 05, 2012
Location: 11th & ALLEY OFF OF CENTER ST. (SENIOR CONDO SITE)	Surveyors: B. WAJVODA / J. MISTRO

Describe each curb ramp's location:	
Curb Ramp A: NE NEAR HOUSES	Curb Ramp E:
Curb Ramp B: NW NEAR EMPTY LOT	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? if present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	96"	96"	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the Intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,NE)	NE	NW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irreguiar)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	S.S.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 67	Date: 04-05-12
Location: 119th & ALLEY OFF OF CENTER ST.	Surveyors: WAJVODA / MISTRO

Describe each curb ramp's location:	
Curb Ramp A: NE NEAR HOUSES	Curb Ramp E:
Curb Ramp B: NW NEAR EMPTY LOT	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

17	Is a lip present at the bottom of the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25 "	.25 "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	4.0 %	1.0 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	ALLEY	ALLEY						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.3 %	1.6 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.0 %	1.0 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.0 %	1.4 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.2 %	5.6 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	(Y) or (N)	(Y) or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: #30 TOP IS ON THE SIDES OF RAMP, NOTHING DIRECTLY IN FRONT

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 68	Date: JULY 24, 2012
Location: 119th & WEST OF STANDARD AVENUE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: NO LONGER EXISTS	Curb Ramp E:
Curb Ramp B:	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	"	"	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)								
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?								
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)								
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)								
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)								
14	What type of transit stop is there? (none, bus, other)								
15	What are the dimensions of any common landing for two curb ramps?	"	"	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	"	"	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 68	Date: JULY 24, 2012
Location: 119th & WEST OF STANDARD AVENUE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A:	Curb Ramp E:
Curb Ramp B:	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	"	"	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	%	%	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	%	%	%	%	%	%	%	%
		%	%	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?								
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	%	%	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	%	%	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 69	Date: JULY 24, 2012
Location: STANDARD AVE. & 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT FRONT STREET SE	Curb Ramp E:
Curb Ramp B: LOOKING AT BASEBALL STADIUM SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.		B.C.						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	32 "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 69	Date: JULY 24, 2012
Location: STANDARD AVE. & 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT FRONT STREET SE	Curb Ramp E:
Curb Ramp B: LOOKING AT BASEBALL STADIUM SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	3.7 %	6.2 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	11.9 %	— %	%	%	%	%	%	%
		12.3 %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	STANDARD	STANDARD						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	4.1 %	5.5 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.7 %	6.2 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.0 %	4.0 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.6 %	6.6 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	NO	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "B" #32: FENCE / CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 70	Date: 04-05-12
Location: 119th & CENTER STREET	Surveyors: B. WAJVODA/J. MISTRO

Describe each curb ramp's location:	
Curb Ramp A: NE (HOUSE)	Curb Ramp E:
Curb Ramp B: NW (EMPTY LOT)	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	100 "	100 "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	B	B						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,NE)	NE	NW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	S.S.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 70	Date: 04-05-12
Location: 119th & CENTER STREET	Surveyors: WAJVODA / MISTRO

Describe each curb ramp's location:	
Curb Ramp A: NE (HOUSE)	Curb Ramp E:
Curb Ramp B: NW (EMPTY LOT)	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	1.0 "	1.0 "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	8.4 %	4.4 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	3.6 %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	CENTER	CENTER						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.1 %	1.6 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		8.4 %	4.4 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		5.0 %	4.6 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.4 %	2.5 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: #30 C.R. "A" TOP OF RAMP IS A HOUSE

C.R. "A" CHIPPED GUTTER SLOPE

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 71	Date: AUGUST 10, 2012
Location: CENTER STREET ALLEY NORTH OF 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT SOFTBALL FIELD SE	Curb Ramp E:
Curb Ramp B: LOOKING AT FRONT STREET SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 Inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 71	Date: AUGUST 10, 2012
Location: CENTER STREET ALLEY NORTH OF 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT SOFTBALL FIELD SE	Curb Ramp E:
Curb Ramp B: LOOKING AT FRONT STREET SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.5 "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	8.7 %	6.6 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	CENTER ALLEY	FRONT						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	5.1 %	6.8 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		8.7 %	6.6 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.1 %	2.5 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		.5 "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" #27: HIGH SIDEWALK ; #32: FENCE/GRASS
C.R. "B" ; #32: FENCE/GRASS

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 72	Date: AUGUST 10, 2012
Location: CENTER STREET ALLEY WEST OF FRONT STREET	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 1733 119th NE	Curb Ramp E:
Curb Ramp B: LOOKING AT 1735 CENTER SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	SE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 72	Date: AUGUST 10, 2012
Location: CENTER STREET ALLEY WEST OF FRONT STREET	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 1733 119th NE	Curb Ramp E:
Curb Ramp B: LOOKING AT 1735 CENTER SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25"	—"	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	1.8 %	3.8 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	119	CEN-TER						
22	What is the slope of the transition to the sidewalk? (should be 5% or less)	0.7 %	3.9 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		—"	—"	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.8 %	3.8 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.3 %	3.0 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.9 %	5.6 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		.5"	.25"	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		—"	—"	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		—"	—"	"	"	"	"	"	"

Comments: C.R. "A" #27: POT HOLE ; #32: FENCE/GRASS

C.R. "B" #27: HIGH SIDEWALK TRANSITION ; #32 HOUSE/GRASS

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 73	Date: AUGUST 10, 2012
Location: 119th STREET ALLEY WEST OF FRONT STREET	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT FRONT STREET SW	Curb Ramp E:
Curb Ramp B: LOOKING AT STANDARD AVENUE SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 73	Date: AUGUST 10, 2012
Location: 119th STREET ALLEY WEST OF FRONT STREET	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT FRONT STREET SW	Curb Ramp E:
Curb Ramp B: LOOKING AT STANDARD AVENUE SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	1.5 "	.25 "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	6.1 %	6.7 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	FRONT	STAND-ARD						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	3.3 %	4.9 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		6.1 %	6.7 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.3 %	0.3 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.5 "	.25 "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R."A" #27: SUNKEN SIDEWALK ; #32: POLE/CURB/YARD
C.R."B" #27: SUNKEN SIDEWALK ; #32: FENCE/CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 74	Date: 04-05-12
Location: 119th & FRONT STREET	Surveyors: B. WAJVODA/J. MISTRO

Describe each curb ramp's location:	
Curb Ramp A: SW (HOUSE)	Curb Ramp E:
Curb Ramp B: NW (GRAVEL)	Curb Ramp F:
Curb Ramp C: NE (RAILROAD SIGNAL)	Curb Ramp G:
Curb Ramp D: SE (BIKE TRAIL)	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	118"	— "	— "	118"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	—	—	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.							
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	Y or N	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,NE)	SW	NW	NE	SE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	~~Y~~ or N	Y or ~~N~~	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	N.C.	S.S.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	"	"	"	"	"	"	"	"

Comments: #9 C.R. "D" ONLY 32" (PIPE & POLE)

C.R. "B" IS ALL GRAVEL - NOT SUITABLE TO SURVEY

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 74	Date: 04-05-12
Location: 119th & FRONT STREET	Surveyors: WAJVODA/MISTRO

Describe each curb ramp's location:	
Curb Ramp A: SW (HOUSE)	Curb Ramp E:
Curb Ramp B: NW (GRAVEL)	Curb Ramp F:
Curb Ramp C: NE (RAILROAD SIGNAL)	Curb Ramp G:
Curb Ramp D: SE (BIKE TRAIL)	Curb Ramp H:

17	Is a lip present at the bottom of the curb ramp?	Y or (N)	Y or (N)	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	.25 "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	3.2 %	— %	1.3 %	4.6 %	%	%	%	%
19	Is a side slope or parallel slope present?	(Y) or N	~~Y or N~~	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	6.7 % 9.0 %	— % — %	6.1 % 6.7 %	— % — %	% %	% %	% %	% %
20	Is there a slip-resistant surface?	(X) or (N)	~~Y or N~~	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	INTERSEC FRONT	—	FRONT	FRONT				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.8 %	— %	— %	1.8 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N "	~~Y or N~~ —	(Y) or N "	(Y) or N "	Y or N "	Y or N "	Y or N "	Y or N "
24	Does CR have a running slope of 8.33% or less?	(Y) or N 3.2 %	~~Y or N~~ — %	(Y) or N 1.3 %	(Y) or N 4.6 %	Y or N %	Y or N %	Y or N %	Y or N %
25	Does CR have a cross slope of 2% or less?	(Y) or N 0.4 %	~~Y or N~~ — %	(Y) or N 0.6 %	(Y) or N 0.1 %	Y or N %	Y or N %	Y or N %	Y or N %
26	Does CR have a gutter slope of 5% or less?	(Y) or N 2.7 %	~~Y or N~~ — %	(Y) or N 2.2 %	(Y) or N 1.4 %	Y or N %	Y or N %	Y or N %	Y or N %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N — "	~~Y or N~~ — "	(Y) or N — "	(Y) or N — "	Y or N "	Y or N "	Y or N "	Y or N "
28	Does CR have detectable warnings?	(Y) or N	~~Y or N~~	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	~~Y or N~~	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N — "	~~Y or N~~ — "	(X) or (N) GRASS "	(Y) or N — "	Y or N "	Y or N "	Y or N "	Y or N "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	~~Y or N~~	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	Y or N %	Y or N %	Y or N %	Y or N %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If	(X) or (N)	~~Y or N~~	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	(X) or (N)	~~Y or N~~	Y or (N)	(X) or (N)	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	Y or N "	Y or N "	Y or N "	Y or N "

Comments: C.R. "B" IS ALL GRAVEL NOT ABLE TO SURVEY

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 75	Date: AUGUST 10, 2012
Location: FRONT & STANDARD	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 121ST STREET NW	Curb Ramp E:
Curb Ramp B: LOOKING AT LAKE SW	Curb Ramp F:
Curb Ramp C: LOOKING AT FRONT STREET SW	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	72"	72"	72"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A					
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.		B.C.	B.C.					
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—					
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	SW	SW					
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.					
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	S.S.	S.S.					
14	What type of transit stop is there? (none, bus, other)	N	N	N					
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	—"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	64"	17"	68"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 75	Date: AUGUST 10, 2012
Location: FRONT & STANDARD	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A:	LOOKING AT 121 ST STREET NW	Curb Ramp E:	
Curb Ramp B:	LOOKING AT LAKE SW	Curb Ramp F:	
Curb Ramp C:	LOOKING AT FRONT STREET SW	Curb Ramp G:	
Curb Ramp D:		Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.9 %	0.7 %	3.8 %	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— % — %	— % — %	— % 3.9 %	% %	% %	% %	% %	% %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	STAND-ARD	STAND-ARD	FRONT					
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.6 %	1.3 %	0.6 %	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N — "	Y or N — "	Y or N — "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
24	Does CR have a running slope of 8.33% or less?	Y or N 0.9 %	Y or N 0.7 %	Y or N 3.8 %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
25	Does CR have a cross slope of 2% or less?	Y or N 2.0 %	Y or N 2.0 %	Y or N 1.7 %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
26	Does CR have a gutter slope of 5% or less?	Y or N 2.1 %	Y or N 0.4 %	Y or N 0.4 %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N — "	Y or N — "	Y or N — "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N — "	Y or N — "	Y or N — "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	YES %	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	⊗ or N	⊗ or N	⊗ or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "

Comments: C.R. "B" #32: BUILDING/LANDSCAPE
C.R. "C" #32: BUILDING/CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 76	Date:
Location: 121st & FRONT	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A:	Curb Ramp E:
Curb Ramp B:	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	"	"	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)								
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?								
5	If a curb ramp is not present, and if a curb is not present, Is there a flush transition from the street to the sidewalk?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)								
7	What Is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)								
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)								
14	What type of transit stop is there? (none, bus, other)								
15	What are the dimensions of any common landing for two curb ramps?	"	"	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	"	"	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 76	Date:
Location: 121st & FRONT	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A:	Curb Ramp E:
Curb Ramp B:	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	"	"	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	%	%	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	%	%	%	%	%	%	%	%
		%	%	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?								
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	%	%	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	%	%	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 77	Date: SEPTEMBER 26, 2012
Location: 121ST & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 2045 SCHRAGE	NW	Curb Ramp E: LOOKING AT 2045 SCHRAGE	SE
Curb Ramp B: LOOKING AT EMPTY LOT (SW)	NW	Curb Ramp F: LOOKING AT EMPTY LOT (SW)	SE
Curb Ramp C: LOOKING AT EMPTY LOT (NW)	NE	Curb Ramp G: LOOKING AT EMPTY LOT (SE)	SW
Curb Ramp D: LOOKING AT EMPTY LOT (SE)	NE	Curb Ramp H: LOOKING AT EMPTY LOT (NW)	SW

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	78"	78"	78"	78"	78"	77"	77"	78"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A	A	A	A
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	—
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NW	NE	NE	SE	SE	SW	SW
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	N
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	—"	—"	—"	—"	—"	—"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	—"	—"	—"	42"	74"	—"	—"	—"

Comments: C.R. "C/D" #9: UTILITY POLE

C.R. "E/F" #9: UTILITY POLE

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 77	Date: SEPTEMBER 26, 2012
Location: 121 ST & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 2045 SCHRAGE	NW	Curb Ramp E: LOOKING AT 2045 SCHRAGE	SE
Curb Ramp B: LOOKING AT EMPTY LOT (SW)	NW	Curb Ramp F: LOOKING AT EMPTY LOT (SW)	SE
Curb Ramp C: LOOKING AT EMPTY LOT (NW)	NE	Curb Ramp G: LOOKING AT EMPTY LOT (SE)	SW
Curb Ramp D: LOOKING AT EMPTY LOT (SE)	NE	Curb Ramp H: LOOKING AT EMPTY LOW (NW)	SW

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25"	.25"	—"	.25"	—"	—"	—"	—"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	8.3 %	4.8 %	1.1 %	2.3 %	8.7 %	1.0 %	3.4 %	3.2 %
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	7.0 % 7.8 %	7.0 % 7.8 %	6.8 % 5.5 %	6.8 % 5.5 %	6.2 % 6.5 %	6.2 % 6.5 %	6.0 % 5.1 %	6.0 % 5.1 %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	SCH-RAGE	121	SCH-RAGE	121	121	SCH-RAGE	SCH-RAGE	121
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	8.5 %	4.7 %	1.1 %	1.8 %	4.1 %	0.7 %	0.9 %	1.3 %
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N —"	Y or N —"	Y or N —"	Y or N —"	Y or N —"	Y or N —"	Y or N —"	Y or N —"
24	Does CR have a running slope of 8.33% or less?	Y or N 8.3 %	Y or N 4.8 %	Y or N 1.1 %	Y or N 2.3 %	Y or N 8.7 %	Y or N 1.0 %	Y or N 3.4 %	Y or N 3.2 %
25	Does CR have a cross slope of 2% or less?	Y or N 2.0 %	Y or N 5.1 %	Y or N 1.3 %	Y or N 0.4 %	Y or N 2.6 %	Y or N 2.6 %	Y or N 3.6 %	Y or N 5.4 %
26	Does CR have a gutter slope of 5% or less?	Y or N 2.2 %	Y or N 2.2 %	Y or N 3.8 %	Y or N 3.7 %	Y or N 1.7 %	Y or N 1.8 %	Y or N 3.0 %	Y or N 3.7 %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N —"	Y or N —"	Y or N 1.0"	Y or N —"	Y or N —"	Y or N —"	Y or N —"	Y or N —"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N —"	Y or N —"	Y or N —"	Y or N —"	Y or N —"	Y or N —"	Y or N —"	Y or N —"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES %	YES %	YES %	YES %	YES %	YES %	YES %	YES %
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ —%	~~Y or N~~ —%	~~Y or N~~ —%	~~Y or N~~ —%	~~Y or N~~ —%	~~Y or N~~ —%	~~Y or N~~ —%	~~Y or N~~ —%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ —"	~~Y or N~~ —"	~~Y or N~~ —"	~~Y or N~~ —"	~~Y or N~~ —"	~~Y or N~~ —"	~~Y or N~~ —"	~~Y or N~~ —"

Comments: C.R."C" #27: HIGH CURB TRANSITION

C.R."E" #26: CRACKED GUTTER SLOPE

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 78	Date: AUGUST 10, 2012
Location: FRED & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS JOHN ST. SW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS 121 ST ST. NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	70 "	70 "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	NW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 78	Date: AUGUST 10, 2012
Location: FRED & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS JOHN ST. SW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS 121ST ST. NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25"	.25"	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	4.4 %	4.6 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	8.4 % 8.5 %	8.9 % 6.4 %	% %	% %	% %	% %	% %	% %
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	FRED	FRED						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	3.7 %	2.0 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N —"	(Y) or N —"	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
24	Does CR have a running slope of 8.33% or less?	(Y) or N 4.4 %	(Y) or N 4.6 %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
25	Does CR have a cross slope of 2% or less?	Y or (N) 4.5 %	Y or (N) 3.3 %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
26	Does CR have a gutter slope of 5% or less?	(Y) or N 4.8 %	(Y) or N 4.7 %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or (N) .25"	Y or (N) .25"	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N —"	(Y) or N —"	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES %	YES %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ —%	~~Y or N~~ —%	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ —"	~~Y or N~~ —"	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "

Comments: C.R. "A" #27 : HIGH ASPHALT

C.R. "B" #27 : HIGH ASPHALT

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 79	Date: AUGUST 23, 2012
Location: JOHN & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS FISCHRUPP SW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS FRED NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	70 "	70 "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	NW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 79	Date: AUGUST 23, 2012
Location: JOHN & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS FISCHRUPP SW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS FRED NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25 "	.25 "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	2.2 %	3.8 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	6.5 % 4.5 %	6.0 % 4.8 %	% %	% %	% %	% %	% %	% %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	JOHN	JOHN						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.8 %	2.4 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N — "	Y or N — "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
24	Does CR have a running slope of 8.33% or less?	Y or N 2.2 %	Y or N 3.8 %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
25	Does CR have a cross slope of 2% or less?	Y or N 2.2 %	Y or N 1.9 %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
26	Does CR have a gutter slope of 5% or less?	Y or N 3.9 %	Y or N 4.9 %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N .25 "	Y or N .25 "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N — "	Y or N — "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES	YES	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ — %	~~Y or N~~ — %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ — "	~~Y or N~~ — "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "

Comments: C.R. "A" # 27: HIGH ASPHALT

C.R. "B" # 27: HIGH ASPHALT

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 80	Date: AUGUST 10, 2012
Location: FISCHRUPP & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT FRED ST. NW	Curb Ramp E:
Curb Ramp B: LOOKING AT 119th ST. SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	72"	72"	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	B	B						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	SE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	—"	—"	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 80	Date: AUGUST 10, 2012
Location: FISCHRUPP & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT FRED ST. NW	Curb Ramp E:
Curb Ramp B: LOOKING AT 119th ST. SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	1.9 %	1.7 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		8.7 %	5.9 %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	FRED	119						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	2.5 %	2.0 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.9 %	1.7 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.1 %	0.3 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.4 %	0.1 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES %	YES %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	(X) or (N)	(X) or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 81	Date: AUGUST 10, 2012
Location: ALLEY SOUTH OF 119th B/T WHITE OAK & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS FISCHRUPP NW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS 119th SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	SE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 81	Date: AUGUST 10, 2012
Location: ALLEY SOUTH OF 119th B/T WHITE OAK & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS FISCHRUPP	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS SCHRAGE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	5.4 %	0.8 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	FISCH-RUPP	119						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.1 %	3.0 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		5.4 %	0.8 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		5.5 %	2.3 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.6 %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" #32 : PLANTER/CURB
C.R. "B" #32 : CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 82	Date: AUGUST 21, 2012
Location: WHITE OAK ALLEY B/T 119th & FISCHRUPP - EAST SIDE	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS 119th	SE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS FISCHRUPP	NE	Curb Ramp F:	
Curb Ramp C:		Curb Ramp G:	
Curb Ramp D:		Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	NE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 82	Date: AUGUST 21, 2012
Location: WHITE OAK ALLEY B/T 119 & FISCHRUPP – EAST SIDE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 119th SE	Curb Ramp E:
Curb Ramp B: LOOKING AT FISCHRUPP NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.2 %	5.9 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	119	FISCH-RUPP						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.1 %	2.7 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.2 %	5.9 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.6 %	1.9 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" # 32: POLE / DRIVEWAY
C.R. "B" # 32: CURB / BUILDING

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 83	Date: AUGUST 21, 2012
Location: WHITE OAK ALLEY B/T 119th & FISCHRUPP WEST SIDE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS FISCHRUPP NW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS 119th SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, Is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	SW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 83	Date: AUGUST 21, 2012
Location: WHITE OAK ALLEY B/T 119th & FISCHRUPP - WEST SIDE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS FISCHRUPP NW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS 119th SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	5.2 %	4.7 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	FISCH-RUPP	119						
22	What is the slope of the transition to the sidewalk? (should be 5% or less)	1.7 %	3.8 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		5.2 %	4.7 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.3 %	2.6 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R."A" #32: BUILDING/POLE
C.R."B" #32: BUILDING/CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 84	Date: AUGUST 21, 2012
Location: FISCHRUPP ALLEY B/T WHITEOAK & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS WHITE OAK SE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS SCHRAGE SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 84	Date: AUGUST 21, 2012
Location: FISCHRUPP ALLEY B/T WHITE OAK & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS WHITE OAK SE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS SCHRAGE SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25"	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.6 %	0.8 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	W.O.	SCH-RAGE						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.6 %	0.5 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.6 %	0.8 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.2 %	2.9 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		.25"	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R."A"#27: LOW SIDEWALK TRANSITION

C.R."A"#32: POLE/LANDSCAPING/GRASS

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 85	Date: AUGUST 21, 2012
Location: FISCHRUPP & WHITE OAK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 1548 FISCHRUPP	NW	Curb Ramp E: LOOKING AT 1548 FISCHRUPP	SE
Curb Ramp B: LOOKING AT FIRE STATION	NW	Curb Ramp F: LOOKING AT FIRE STATION	SE
Curb Ramp C: LOOKING AT 1549 FISCHRUPP	SW	Curb Ramp G: LOOKING AT EMPTY LOT	NE
Curb Ramp D: LOOKING AT 1930 SCHRAGE	SW	Curb Ramp H: LOOKING AT 1549 FISCHRUPP	NE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	72"	—"	72"	—"	—"	72"	72"	—"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	B	A	B	A	A	B	B	A
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	—
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NW	SW	SW	SE	SE	NE	NE
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	N.C.	N.C.	N.C.	S.S.	S.S.
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	N
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	60x 72"	60x 72"	48x 72"	48x 72"	—"	—"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	—"	—"	—"	—"	—"	—"	—"	—"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 85	Date: AUGUST 21, 2012
Location: FISCHRUPP & WHITE OAK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 1548 FISCHRUPP	NW	Curb Ramp E: LOOKING AT 1548 FISCHRUPP	SE
Curb Ramp B: LOOKING AT FIRE STATION	NW	Curb Ramp F: LOOKING AT FIRE STATION	SE
Curb Ramp C: LOOKING AT 1549 FISCHRUPP	SW	Curb Ramp G: LOOKING AT EMPTY LOT	NE
Curb Ramp D: LOOKING AT 1930 SCHRAGE	SW	Curb Ramp H: LOOKING AT 1549 FISCHRUPP	NE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	.5 "	— "	.5 "	.5 "	— "	— "	.5 "
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	1.9 %	4.4 %	3.0 %	0.1 %	0.8 %	1.4 %	2.7 %	7.4 %
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— % / 5.5 %	— % / — %	— % / — %	— % / — %	— % / — %	— % / — %	— % / 4.1 %	— % / — %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	FISCH-RUPP	W.O.	FISCH-RUPP	W.O.	W.O.	FISCH-RUPP	FISCH-RUPP	W.O.
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	3.8 %	3.8 %	3.1 %	0.0 %	0.9 %	1.9 %	3.4 %	4.7 %
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
24	Does CR have a running slope of 8.33% or less?	Y or N 1.9 %	Y or N 4.4 %	Y or N 3.0 %	Y or N 0.1 %	Y or N 0.8 %	Y or N 1.4 %	Y or N 2.7 %	Y or N 7.4 %
25	Does CR have a cross slope of 2% or less?	Y or N 1.3 %	Y or N 0.5 %	Y or N 0.2 %	Y or N 1.9 %	Y or N 2.7 %	Y or N 0.9 %	Y or N 3.1 %	Y or N 2.0 %
26	Does CR have a gutter slope of 5% or less?	Y or N 0.8 %	Y or N 5.4 %	Y or N 2.5 %	Y or N 8.0 %	Y or N 5.8 %	Y or N 1.0 %	Y or N 6.0 %	~~Y or N~~ — %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N — "	Y or N .5 "	Y or N .25 "	Y or N .5 "	Y or N .5 "	Y or N — "	Y or N — "	Y or N .5 "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES — %	— %	— %	— %	— %	— %	YES — %	— %
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %
32	If no flared sides, is there an obstruction b grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	⊗ or N	Y or N	⊗ or N	Y or N	Y or N	⊗ or N	⊗ or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "

Comments: C.R. "B" #27: HIGH ASPHALT
C.R. "C" #27: HIGH SIDEWALK
C.R. "D" #27: HIGH ASPHALT
C.R. "E" #27: HIGH ASPHALT
C.R. "H" #27: HIGH ASPHALT

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 86	Date: AUGUST 22, 2012
Location: WHITE OAK ALLEY B/T FISCHRUPP & JOHN	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS JOHN	NW	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS FISCHRUPP	SW	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS FISCHRUPP	SE	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS JOHN	NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C	C	C				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	SW	SE	NE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	N.C.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 86	Date: AUGUST 22, 2012
Location: WHITE OAK ALLEY B/T FISCHRUPP & JOHN	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT JOHN	NW	Curb Ramp E:	
Curb Ramp B: LOOKING AT FISCHRUPP	SW	Curb Ramp F:	
Curb Ramp C: LOOKING AT FISCHRUPP	SE	Curb Ramp G:	
Curb Ramp D: LOOKING AT JOHN	NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.1 %	0.4 %	0.9 %	1.4 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	JOHN	FISCH-RUPP	FISCH-RUPP	JOHN				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.6 %	0.5 %	0.3 %	0.6 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.1 %	0.4 %	0.9 %	1.4 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.0 %	1.9 %	1.8 %	1.7 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" #32: GRASS/ BUILDING
C.R. "B" #32: GRASS/ FENCE - CRACK THRU WHOLE SLAB
C.R. "C" #32: GRASS / FENCE

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 87	Date: AUGUST 23, 2012
Location: JOHN & WHITE OAK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 1601 JOHN	SE	Curb Ramp E: LOOKING AT 2000 WHITE OAK	NW
Curb Ramp B: LOOKING AT 2000 WHITE OAK	SE	Curb Ramp F: LOOKING AT 1601 JOHN	NW
Curb Ramp C: LOOKING AT 1549 JOHN	SW	Curb Ramp G: LOOKING AT 1549 JOHN	NE
Curb Ramp D: LOOKING AT SCHRAGE HOME	SW	Curb Ramp H: LOOKING AT SCHRAGE HOME	NE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	— "	— "	— "	— "
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A	A	A	A
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	—
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SE	SW	SW	NW	NW	NE	NE
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	S.S.	S.S.	N.C.	N.C.		
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	N
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	— "	— "	— "	— "
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	— "	— "	— "	— "

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 87	Date: AUGUST 23, 2012
Location: JOHN & WHITE OAK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 1601 JOHN	SE	Curb Ramp E: LOOKING AT 2000 WHITE OAK	NW
Curb Ramp B: LOOKING AT 2000 WHITE OAK	SE	Curb Ramp F: LOOKING AT 1601 JOHN	NW
Curb Ramp C: LOOKING AT 1549 JOHN	SW	Curb Ramp G: LOOKING AT 1599 JOHN	NE
Curb Ramp D: LOOKING AT SCHRAGE HOME	SW	Curb Ramp H: LOOKING AT SCHRAGE HOME	NE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	.5 "	.25 "	.25 "	.5 "	— "
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.7 %	0.7 %	3.5 %	2.3 %	2.3 %	2.5 %	0.5 %	3.1 %
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	~~Y~~ or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— % / 8.4 %	— % / 8.4 %	— % / 6.4 %	— % / — %	2.4 % / 11.7 %	2.4 % / 11.7 %	— % / 6.1 %	— % / 6.1 %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	JOHN	W.O.	JOHN	W.O.	JOHN	W.O.	W.O.	JOHN
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	5.0 %	4.7 %	1.3 %	3.6 %	6.0 %	0.8 %	4.0 %	7.4 %
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "
24	Does CR have a running slope of 8.33% or less?	Y or N / 0.7 %	Y or N / 0.7 %	Y or N / 3.5 %	Y or N / 2.3 %	Y or N / 2.3 %	Y or N / 2.5 %	Y or N / 0.5 %	Y or N / 3.1 %
25	Does CR have a cross slope of 2% or less?	Y or N / 0.7 %	Y or N / 1.3 %	Y or N / 2.7 %	Y or N / 2.1 %	Y or N / 1.9 %	Y or N / 0.4 %	Y or N / 2.4 %	Y or N / 1.9 %
26	Does CR have a gutter slope of 5% or less?	Y or N / 1.3 %	Y or N / 2.6 %	Y or N / 3.8 %	Y or N / 2.5 %	Y or N / 2.5 %	Y or N / 1.5 %	Y or N / 6.7 %	Y or N / 3.9 %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / .5 "	Y or N / .25 "	Y or N / .25 "	Y or N / .5 "	Y or N / — "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES *	YES *	YES *	— %	NO *	NO *	YES %	YES *
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	~~Y or N~~	Y or N	~~Y or N~~	Y or N	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "

Comments: C.R. "D" #27: HIGH ASPHALT C.R. "G" #27: HIGH ASPHALT
C.R. "E" #27: HIGH ASPHALT
C.R. "F" #27: HIGH ASPHALT

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 87.A	Date: AUGUST 24, 2012
Location: JOHN ALLEY B/T WHITE OAK & SCHRAGE	Surveyors: B WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS SCHRAGE NW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS WHITE OAK NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, Is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 87. A	Date: AUGUST 24, 2012
Location: JOHN ALLEY B/T WHITE OAK & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS SCHRAGE NW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS WHITE OAK NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25"	.25"	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	6.3%	6.0%	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	—%	—%	%	%	%	%	%	%
		—%	—%	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	SCH-RAGE	W.O.						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	5.6%	7.9%	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		—"	—"	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		6.3%	6.0%	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.7%	1.9%	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		—%	—%	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		.25"	.25"	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		—"	—"	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	—%	—%	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		—%	—%	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		—"	—"	"	"	"	"	"	"

Comments: C.R. "A" #27 : LOW SIDEWALK ; C.R. "B" #27 : LOW SIDEWALK
C.R. "A" #32 : CURB/LAWN C.R. "B" #32 : CURB/LAWN

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 88	Date: AUGUST 22, 2012
Location: FRED & WHITE OAK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 2020 WHITE OAK	NE	Curb Ramp E: LOOKING AT 2020 WHITE OAK	SW
Curb Ramp B: LOOKING AT 1600 FRED	NE	Curb Ramp F: LOOKING AT 1600 FRED	SW
Curb Ramp C: LOOKING AT I.C. SCHOOL	NW	Curb Ramp G: LOOKING AT 2026 WHITE OAK	SE
Curb Ramp D: LOOKING AT 2026 WHITE OAK	NW	Curb Ramp H: LOOKING AT I.C. SCHOOL	SE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	— "	— "	— "	— "
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A	A	A	A
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	—
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NE	NW	NW	SW	SW	SE	SE
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.	N.C.	N.C.	S.S.	S.S.
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	N
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	— "	— "	— "	— "
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	— "	— "	— "	— "

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 88	Date: AUGUST 22, 2012
Location: FRED & WHITE OAK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 2020 WHITE OAK	NE	Curb Ramp E: LOOKING AT 2020 WHITE OAK	SW
Curb Ramp B: LOOKING AT 1600 FRED	NE	Curb Ramp F: LOOKING AT 1600 FRED	SW
Curb Ramp C: LOOKING AT I.C. SCHOOL	NW	Curb Ramp G: LOOKING AT 2026 WHITE OAK	SE
Curb Ramp D: LOOKING AT 2026 WHITE OAK	NW	Curb Ramp H: LOOKING AT I.C. SCHOOL	SE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	1.0 "	.5 "	— "	.25 "	.25 "	.25 "
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	2.3 %	3.6 %	3.9 %	2.8 %	5.5 %	3.8 %	1.7 %	4.9 %
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	5.8 % 7.7 %	5.8 % 7.7 %	— % 3.4 %	— % 3.4 %	— % 8.9 %	— % 8.9 %	— % 4.9 %	— % 4.9 %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	W.O.	FRED	W.O.	FRED	FRED	W.O.	W.O.	FRED
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	3.3 %	7.2 %	2.7 %	4.5 %	5.8 %	2.8 %	1.8 %	5.9 %
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
24	Does CR have a running slope of 8.33% or less?	Y or N 2.3 %	Y or N 3.6 %	Y or N 3.9 %	Y or N 2.8 %	Y or N 5.5 %	Y or N 3.8 %	Y or N 1.7 %	Y or N 4.9 %
25	Does CR have a cross slope of 2% or less?	Y or N 1.1 %	Y or N 0.2 %	Y or N 2.7 %	Y or N 2.5 %	Y or N 2.0 %	Y or N 3.7 %	Y or N 2.6 %	Y or N 1.2 %
26	Does CR have a gutter slope of 5% or less?	Y or N 3.8 %	Y or N 3.7 %	Y or N 7.5 %	Y or N 3.1 %	Y or N 2.3 %	Y or N 1.8 %	Y or N 2.2 %	Y or N 2.6 %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N — "	Y or N — "	Y or N 1.0 "	Y or N .5 "	Y or N — "	Y or N .25 "	Y or N .25 "	Y or N .25 "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES %	YES %	YES %	YES %	YES %	YES %	YES %	YES %
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "

Comments: C.R. "C" #27: HIGH ASPHALT
C.R. "D" #27: HIGH ASPHALT
C.R. "F" #27: HIGH ASPHALT
C.R. "G" #27: HIGH ASPHALT
C.R. "H" #27: HIGH ASPHALT

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 89	Date: AUGUST 22, 2012
Location: FRED ALLEY B/T WHITE OAK & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS SCHRAGE SW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS WHITE OAK SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 89	Date: AUGUST 22, 2012
Location: FRED ALLEY B/T WHITE OAK & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS SCHRAGE SW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS WHITE OAK SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.3 %	0.8 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	SCH-RAGE	W.O.						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.2 %	1.0 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.3 %	0.8 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.8 %	3.3 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" #32: CURB/BUILDING
C.R. "B" #32: CURB/FENCE

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 90	Date: OCTOBER 02, 2012
Location: WHITE OAK ALLEY B/T FRED & 121 ST	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS FRED SW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS 121 ST NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	NW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 90	Date: OCTOBER 02, 2012
Location: WHTE OAK ALLEY B/T FRED & 121 ST	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS FRED SW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS 121 ST NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.3 %	0.1 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	FRED	121						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.5 %	2.2 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.3 %	0.1 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.4 %	1.9 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "B" #32 : GRASS/BUILDING

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 91	Date: OCTOBER 02, 2012
Location: 121ST ALLEY EAST OF WHITE OAK	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS WHITE OAK NE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS SCHRAGE NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 91	Date: OCTOBER 02, 2012
Location: 121ST ALLEY EAST OF WHITE OAK	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS WHITE OAK NE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS SCHRAGE NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	6.6 %	4.2 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	W.O.	SCH-RAGE						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	7.3 %	1.1 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		6.6 %	4.2 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.4 %	1.0 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" #32: GRASS/CURB
C.R. "B" #32: BUILDING / CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 92	Date: OCTOBER 02, 2012
Location: 121 ST & WHITE OAK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT DINOS	NW	Curb Ramp E: LOOKING AT 1546 121 ST	SE
Curb Ramp B: LOOKING AT 1546 121 ST	NW	Curb Ramp F: LOOKING AT DINOS	SE
Curb Ramp C: LOOKING AT 1549 121 ST	SW	Curb Ramp G: LOOKING AT EMPTY LOT	NE
Curb Ramp D: LOOKING AT EMPTY LOT	SW	Curb Ramp H: LOOKING AT 1549 121 ST	NE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	— "	— "	— "	— "
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A	A	A	A
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.					B.C.	B.C.	B.C.	B.C.
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	—
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NW	SW	SW	SE	SE	NE	NE
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	N
15	What are the dimensions of any common landing for two curb ramps?	72 x 72 "	72 x 72 "	70 x 71 "	70 x 71 "	— "	— "	— "	— "
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	— "	— "	— "	— "

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 92	Date: OCTOBER 02, 2012
Location: 121 ST & WHITE OAK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT DINOS	NW	Curb Ramp E: LOOKING AT 1546 121 ST	SE
Curb Ramp B: LOOKING AT 1546 121 ST	NW	Curb Ramp F: LOOKING AT DINOS	SE
Curb Ramp C: LOOKING AT 1549 121 ST	SW	Curb Ramp G: LOOKING AT EMPTY LOT	NE
Curb Ramp D: LOOKING AT EMPTY LOT	SW	Curb Ramp H: LOOKING AT 1549 121 ST	NE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.75"	.25"	.25"	.25"	.25"	.25"	.50"	1.0"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	8.4 %	7.1 %	7.4 %	7.8 %	4.9 %	4.1 %	6.0 %	7.7 %
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	1.9 %	1.9 %	5.6 %	5.6 %
		— %	— %	— %	— %	6.0 %	6.0 %	— %	— %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	W.O.	121	121	W.O.	W.O.	121	121	W.O.
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	8.1 %	3.6 %	7.1 %	7.8 %	0.1 %	5.2 %	0.4 %	6.7 %
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	— "	— "
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		8.4 %	7.1 %	7.4 %	7.8 %	4.9 %	4.1 %	6.0 %	7.7 %
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.2 %	0.4 %	0.6 %	0.1 %	2.6 %	0.4 %	4.2 %	2.2 %
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.1 %	3.4 %	4.4 %	3.3 %	1.1 %	2.5 %	6.3 %	9.6 %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		.25"	— "	— "	— "	.25"	.25"	.25"	— "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	— "	— "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	YES %	YES %	YES %	YES %
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
		— %	— %	— %	— %	— %	— %	— %	— %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
		— "	— "	— "	— "	— "	— "	— "	— "

Comments: C.R. "A" #27: LOW CURB TRANSITION
C.R. "E" #27: LOW CURB TRANSITION
C.R. "F" #27: HIGH CURB TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 93	Date: SEPTEMBER 24, 2012
Location: 121st ALLEY EAST OF NEW YORK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS WHITE OAK	NW	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS NEW YORK	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS NEW YORK	SE	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS WHITE OAK	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C	C	C				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NE	SE	SW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	NC.	N.C.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 93	Date: SEPTEMBER 24, 2012
Location: 121 ST ALLEY EAST OF NEW YORK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS WHITE OAK	NW	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS NEW YORK	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS NEW YORK	SE	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS WHITE OAK	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	.25 "	.25 "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	1.3 %	2.2 %	1.1 %	0.9 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	W.O.	N.Y.	N.Y.	W.O.				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.1 %	3.1 %	3.2 %	1.0 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.3 %	2.2 %	1.1 %	0.9 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.8 %	1.5 %	2.0 %	1.6 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" #32: FENCE/DRIVEWAY
C.R. "B" #32: BUILDING/GRASS
C.R. "C" #32: STAIRS/GRASS

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 94	Date: SEPTEMBER 24, 2012
Location: NEW YORK & 121 ST	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 2100 NEW YORK	NW	Curb Ramp E: LOOKING AT 2100 NEW YORK	SE
Curb Ramp B: LOOKING AT 2045 NEW YORK	NW	Curb Ramp F: LOOKING AT 2045 NEW YORK	SE
Curb Ramp C: LOOKING AT 1447 121 ST	SW	Curb Ramp G: LOOKING AT 2101 NEW YORK	NE
Curb Ramp D: LOOKING AT 2101 NEW YORK	SW	Curb Ramp H: LOOKING AT 1447 121 ST	NE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	— "	— "	— "	— "
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A	A	A	A
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	—
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NW	SW	SW	SE	SE	NE	NE
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	N
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	— "	— "	— "	— "
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	45 "	— "	— "	— "	— "	— "	— "	— "

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 94	Date: SEPTEMBER 24, 2012
Location: NEW YORK & 121 ST	Surveyors: B. WASVODA

Describe each curb ramp's location:			
Curb Ramp A:	LOOKING AT 2100 NEW YORK NW	Curb Ramp E:	LOOKING AT 2100 NEW YORK SE
Curb Ramp B:	LOOKING AT 2045 NEW YORK NW	Curb Ramp F:	LOOKING AT 2045 NEW YORK SE
Curb Ramp C:	LOOKING AT 1447 121 ST SW	Curb Ramp G:	LOOKING AT 2101 NEW YORK NE
Curb Ramp D:	LOOKING AT 2101 NEW YORK SW	Curb Ramp H:	LOOKING AT 1447 121 ST NE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25 "	— "	.25 "	.25 "	.75 "	.75 "	.25 "	.50 "
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	5.6 %	4.3 %	2.2 %	2.6 %	3.3 %	2.5 %	1.4 %	4.1 %
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	6.1 %	6.1 %	5.3 %	5.3 %	6.1 %	6.1 %	4.5 %	4.5 %
		— %	— %	— %	— %	— %	— %	— %	— %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	121	N.Y.	121	N.Y.	N.Y.	121	121	N.Y.
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.3 %	5.3 %	2.0 %	4.2 %	4.1 %	4.1 %	1.9 %	3.3 %
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	— "	— "
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		5.6 %	4.3 %	2.2 %	2.6 %	3.3 %	2.5 %	1.4 %	4.1 %
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.5 %	1.5 %	0.6 %	1.2 %	2.0 %	0.9 %	1.2 %	1.7 %
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.4 %	2.8 %	3.6 %	3.4 %	4.2 %	3.0 %	3.2 %	3.6 %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	— "	— "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	— "	— "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES %	YES %	YES %	YES %	YES %	YES %	YES %	YES %
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
		— %	— %	— %	— %	— %	— %	— %	— %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
		— "	— "	— "	— "	— "	— "	— "	— "

Comments: C.R. "E & F" 2" GAP B/T CURB TRANSITION & SIDEWALK

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 95	Date: SEPTEMBER 24, 2012
Location: NEW YORK ALLEY B/T FRED & 121 ST	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS FRED	SE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS 121 ST	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS 121 ST	NW	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS FRED	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C	C	C				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	NE	NW	SW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	S.S.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 95	Date: SEPTEMBER 24, 2012
Location: NEW YORK ALLEY B/T FRED & 121 ST	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS FRED	SE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS 121 ST	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS 121 ST	NW	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS FRED	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	5.5 %	4.2 %	5.4 %	5.7 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	FRED	121	121	FRED				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	3.8 %	0.7 %	6.0 %	4.3 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		5.5 %	4.2 %	5.4 %	5.7 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.7 %	7.7 %	0.5 %	0.2 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" #32: FENCE/CURB
C.R. "B" #32: DRIVEWAY/CURB
C.R. "C" #32: BUILDING/CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 96	Date: SEPTEMBER 24,2012
Location: NEW YORK & FRED	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 1501 FRED	SE	Curb Ramp E: LOOKING AT 1462 FRED	NW
Curb Ramp B: LOOKING AT 1462 FRED	SE	Curb Ramp F: LOOKING AT 1501 FRED	NW
Curb Ramp C: LOOKING AT 1500 FRED	NE	Curb Ramp G: LOOKING AT 2018 NEW YORK	SW
Curb Ramp D: LOOKING AT 2018 NEW YORK	NE	Curb Ramp H: LOOKING AT 1500 FRED	SW

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	78"	79"	78"	78"	78"	78"	78"	79"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A	A	A	A
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	—
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SE	NE	NE	NW	NW	SW	SW
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	N
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	—"	—"	—"	—"	—"	—"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	41"	39"	45"	45"	45"	21"	45"	43"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 96	Date: SEPTEMBER 24, 2012
Location: NEW YORK & FRED	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 1501 FRED	SE	Curb Ramp E: LOOKING AT 1462 FRED	NW
Curb Ramp B: LOOKING AT 1462 FRED	SE	Curb Ramp F: LOOKING AT 1501 FRED	NW
Curb Ramp C: LOOKING AT 1500 FRED	NE	Curb Ramp G: LOOKING AT 2018 NEW YORK	SW
Curb Ramp D: LOOKING AT 2018 NEW YORK	NE	Curb Ramp H: LOOKING AT 1500 FRED	SW

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25"	.25"	.25"	.50"	.25"	.25"	.25"	.25"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	4.4 %	7.7 %	4.6 %	4.9 %	3.3 %	3.9 %	4.1 %	3.1 %
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	7.0 % 8.6 %	7.0 % 8.6 %	5.9 % 4.7 %	5.9 % 4.7 %	6.0 % 3.4 %	6.0 % 3.4 %	5.4 % 4.5 %	5.4 % 4.5 %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	FRED	N.Y.	FRED	N.Y.	FRED	N.Y.	FRED	N.Y.
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	3.8 %	1.8 %	4.7 %	4.6 %	2.6 %	2.7 %	1.3 %	2.4 %
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N —"	Y or N —"	Y or N —"	Y or N —"	Y or N —"	Y or N —"	Y or N —"	Y or N —"
24	Does CR have a running slope of 8.33% or less?	Y or N 4.4 %	Y or N 7.7 %	Y or N 4.6 %	Y or N 4.9 %	Y or N 3.3 %	Y or N 3.9 %	Y or N 4.1 %	Y or N 3.1 %
25	Does CR have a cross slope of 2% or less?	Y or N 0.4 %	Y or N 0.4 %	Y or N 0.4 %	Y or N 0.4 %	Y or N 0.4 %	Y or N 0.4 %	Y or N 0.3 %	Y or N 0.3 %
26	Does CR have a gutter slope of 5% or less?	Y or N 2.3 %	Y or N 3.5 %	Y or N 1.6 %	Y or N 3.2 %	Y or N 0.5 %	Y or N 2.8 %	Y or N 2.4 %	Y or N 3.7 %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N —"	Y or N —"	Y or N 2.0"	Y or N —"	Y or N 2.0"	Y or N —"	Y or N —"	Y or N —"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N —"	Y or N —"	Y or N —"	Y or N —"	Y or N —"	Y or N —"	Y or N —"	Y or N —"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES %	YES %	YES %	YES %	YES %	YES %	YES %	YES %
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ —%	~~Y or N~~ —%	~~Y or N~~ —%	~~Y or N~~ —%	~~Y or N~~ —%	~~Y or N~~ —%	~~Y or N~~ —%	~~Y or N~~ —%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ —"	~~Y or N~~ —"	~~Y or N~~ —"	~~Y or N~~ —"	~~Y or N~~ —"	~~Y or N~~ —"	~~Y or N~~ —"	~~Y or N~~ —"

Comments: C.R. "B" # 32 : STOP SIGN C.R. "E" # 32: HYDRANT / STOP SIGN

C.R. "C" # 27: CURB TRANITION IN C.R.

C.R. "C" # 32: CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 97	Date: SEPTEMBER 21, 2012
Location: NEW YORK ALLEY B/T JOHN & FRED	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS JOHN	SE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS FRED	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS FRED	NW	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS JOHN	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C	C	C				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	NE	NW	SW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 97	Date: SEPTEMBER 21, 2012
Location: NEW YORK ALLEY B/T JOHN & FRED	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS JOHN	SE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS FRED	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS FRED	NW	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS JOHN	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	7.9 %	7.0 %	6.6 %	6.2 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	JOHN	FRED	FRED	JOHN				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.6 %	0.8 %	3.4 %	3.6 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		7.9 %	7.0 %	6.6 %	6.2 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.0 %	3.1 %	1.6 %	2.7 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R."A" # 32: BUILDING / CURB
C.R."B" # 32 BUILDING / CURB
C.R."C" # 32 FENCE / CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 98	Date: SEPTEMBER 19, 2012
Location: JOHN ALLEY EAST OF NEW YORK	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS WHITE OAK NW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS NEW YORK NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A	R.A.						
8	is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments: C.R. "A": SMASHED

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 98	Date: SEPTEMBER 19, 2012
Location: JOHN ALLEY EAST OF NEW YORK	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS WHITE OAK NW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS NEW YORK NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	.25 "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	6.3 %	6.1 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	W.O.	N.Y.						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	4.6 %	3.7 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		6.3 %	6.1 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.8 %	1.9 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		27 "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R."A" #32: PARKING LOT/CURB
C.R."B" #27: HIGH C.R.
C.R. "B" #32: GRASS/CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 99	Date: SEPTEMBER 19, 2012
Location: NEW YORK & JOHN	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT PARKING LOT	NW	Curb Ramp E: LOOKING AT 1462 JOHN	SE
Curb Ramp B: LOOKING AT 1462 JOHN	NW	Curb Ramp F: LOOKING AT PARKING LOT	SE
Curb Ramp C: LOOKING AT 1500 JOHN	NE	Curb Ramp G: LOOKING AT 1500 JOHN	SW
Curb Ramp D: LOOKING AT WEINERS	NE	Curb Ramp H: LOOKING AT WEINERS	SW

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	78"	78"	77"	78"	77"	77"	77"	78"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A	A	A	A
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	—
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NW	NE	NE	SE	SE	SW	SW
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	N.C.	N.C.	S.S.	S.S.	S.S.	S.S.
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	N
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	—"	—"	—"	—"	—"	—"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	22"	—	42"	46"	43"	45"	33"	35"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 99	Date: SEPTEMBER 19, 2012
Location: NEW YORK & JOHN	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT PARKING LOT	NW	Curb Ramp E: LOOKING AT 1462 JOHN	SE
Curb Ramp B: LOOKING AT 1462 JOHN	NW	Curb Ramp F: LOOKING AT PARKING LOT	SE
Curb Ramp C: LOOKING AT 1500 JOHN	NE	Curb Ramp G: LOOKING AT 1500 JOHN	SW
Curb Ramp D: LOOKING AT WEINERS	NE	Curb Ramp H: LOOKING AT WEINERS	SW

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	.25 "	.50 "	.25 "	— "	— "	— "
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	2.5 %	5.5 %	4.2 %	5.5 %	7.1 %	5.9 %	2.4 %	2.1 %
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	5.9 % 3.2 %	5.9 % 3.2 %	5.2 % 2.9 %	5.2 % 2.9 %	4.3 % 7.9 %	4.3 % 7.9 %	7.7 % 3.5 %	7.7 % 3.5 %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	N.Y.	JOHN	JOHN	N.Y.	N.Y.	JOHN	N.Y.	JOHN
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	2.4 %	4.6 %	0.5 %	3.5 %	7.1 %	3.6 %	4.7 %	2.8 %
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
24	Does CR have a running slope of 8.33% or less?	Y or N 2.5 %	Y or N 5.5 %	Y or N 4.2 %	Y or N 5.5 %	Y or N 7.1 %	Y or N 5.9 %	Y or N 2.4 %	Y or N 2.1 %
25	Does CR have a cross slope of 2% or less?	Y or N 1.3 %	Y or N 1.3 %	Y or N 2.4 %	Y or N 2.4 %	Y or N 0.7 %	Y or N 0.7 %	Y or N 0.8 %	Y or N 0.8 %
26	Does CR have a gutter slope of 5% or less?	Y or N 2.6 %	Y or N 1.3 %	Y or N 3.6 %	Y or N 0.3 %	Y or N 1.9 %	Y or N 2.8 %	Y or N 0.3 %	Y or N 0.8 %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES %	YES %	YES %	YES %	YES %	YES %	YES %	YES %
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "

Comments: C.R. "F" #32: SIGN
C.R. "H" #32: SIGN

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 100	Date: SEPTEMBER 17, 2012
Location: FISCHRUPP ALLEY EAST OF NEW YORK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS NEW YORK	NE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS WHITE OAK	NW	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS WHITE OAK	SW	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS NEW YORK	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C	C	C				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NW	SW	SE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	N.C.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments: C.R. "C": SMASHED ACROSS

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 100	Date: SEPTEMBER 17, 2012
Location: FISCHRUPP ALLEY EAST OF NEW YORK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS NEW YORK	NE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS WHITE OAK	NW	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS WHITE OAK	SW	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS NEW YORK	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	.25 "	.50 "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	2.8 %	3.6 %	5.1 %	4.1 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	N.Y.	W.O.	W.O.	N.Y.				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.8 %	0.2 %	8.7 %	4.3 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.8 %	3.6 %	5.1 %	4.1 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.6 %	6.9 %	3.4 %	0.8 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	1.0 "	.50 "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		46 "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "B" #32: GARAGE / DRIVEWAY
C.R. "C" #27: HIGH TRANSITION TO SIDEWALK
C.R. "D" #27: HIGH TRANSITION TO SIDEWALK ; #32: LANDSCAPING

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 101	Date: SEPTEMBER 17, 2012
Location: NEW YORK & FISCHRUPP	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT MIDTOWN	SE	Curb Ramp E: LOOKING AT 1923 NEW YORK	NW
Curb Ramp B: LOOKING AT 1923 NEW YORK	SE	Curb Ramp F: LOOKING AT MIDTOWN	NW
Curb Ramp C: LOOKING AT 1929 NEW YORK	NE	Curb Ramp G: LOOKING AT 1922 NEW YORK	SW
Curb Ramp D: LOOKING AT 1922 NEW YORK	NE	Curb Ramp H: LOOKING AT 1929 NEW YORK	SW

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	77"	71"	71"	78"	78"	56"	56"	77"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	B	B	B	B	B	B	B	B
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.		—
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	V
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SE	NE	NE	NW	NW	SW	SW
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.	N.C.	N.C.
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	N
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	—"	—"	—"	—"	—"	—"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	—"	75"	—"	—"	—"	—"	—"	—"

Comments: C.R. "E" #9: FIRE HYDRANT

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 101	Date: SEPTEMBER 17, 2012
Location: NEW YORK & FISCHRUPP	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT MIDTOWN	SE	Curb Ramp E: LOOKING AT 1923 NEW YORK	NW
Curb Ramp B: LOOKING AT 1923 NEW YORK	SE	Curb Ramp F: LOOKING AT MIDTOWN	NW
Curb Ramp C: LOOKING AT 1929 NEW YORK	NE	Curb Ramp G: LOOKING AT 1922 NEW YORK	SW
Curb Ramp D: LOOKING AT 1922 NEWYORK	NE	Curb Ramp H: LOOKING AT 1929 NEW YORK	SW

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25"	— "	— "	.25"	— "	.25"	.25"	— "
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.9 %	3.0 %	4.1 %	3.9 %	5.0 %	7.1 %	8.2 %	— %
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	~~Y or N~~
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	5.4 % / — %	5.4 % / — %	7.4 % / — %	7.4 % / — %	3.5 % / — %	3.5 % / — %	— % / — %	— % / — %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	N.Y.	FISCH-RUPP	FISCH-RUPP	N.Y.	N.Y.	FISCH-RUPP	FISCH-RUPP	N.Y.
22	What is the slope of the transition to the sidewalk? (should be 5% or less)	2.2 %	7.2 %	5.2 %	4.7 %	2.4 %	5.6 %	9.2 %	— %
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	~~Y or N~~ — "
24	Does CR have a running slope of 8.33% or less?	Y or N 0.9 %	Y or N 3.0 %	Y or N 4.1 %	Y or N 3.9 %	Y or N 5.0 %	Y or N 7.1 %	Y or N 8.2 %	~~Y or N~~ — %
25	Does CR have a cross slope of 2% or less?	Y or N 3.2 %	Y or N 1.7 %	Y or N 2.8 %	Y or N 3.6 %	Y or N 0.8 %	Y or N 0.3 %	Y or N 3.2 %	~~Y or N~~ — %
26	Does CR have a gutter slope of 5% or less?	Y or N 2.2 %	Y or N 1.4 %	Y or N 1.4 %	Y or N 2.1 %	Y or N 2.6 %	Y or N 0.1 %	Y or N 4.6 %	~~Y or N~~ %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N .25"	Y or N .25"	Y or N .25"	Y or N — "	Y or N — "	Y or N — "	Y or N 1.0"	~~Y or N~~ — "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	~~Y or N~~
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES — %	— %	YES — %	YES — %	YES — %	YES — %	— %	— %
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ — %	Y or N 5.4 %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "

Comments: C.R. "A" #27: LOW CURB TRANSITION
C.R. "B" #27: LOW CURB TRANSITION
C.R. "C" #27: LOW CURB TRANSITION
C.R. "F" #32: SEWER/CURB
C.R. "G" #27: LOW CURB TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 102	Date: SEPTEMBER 17, 2012
Location: NEW YORK ALLEY B/T 119th & FISCHRUPP	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS FISCHRUPP	NW	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS 119th	SW	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS 119th	SE	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS FISCHRUPP	NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C	C	C				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	SW	SE	NE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" #9: UTILITY POLE

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 102	Date: SEPTEMBER 17, 2012
Location: NEW YORK ALLEY B/T 119th & FISCHRUPP	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT FISCHRUPP	NW	Curb Ramp E:	
Curb Ramp B: LOOKING AT 119th	SW	Curb Ramp F:	
Curb Ramp C: LOOKING AT 119th	SE	Curb Ramp G:	
Curb Ramp D: LOOKING AT FISCHRUPP	NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	8.5 %	3.9 %	4.7 %	2.5 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	FISCH-RUPP	119	119	FISCH-RUPP				
22	What is the slope of the transition to the sidewalk? (should be 5% or less)	4.8 %	0.6 %	1.3 %	3.6 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		8.5 %	3.9 %	4.7 %	2.5 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		5.0 %	2.3 %	3.7 %	5.4 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R."A" #32: BUILDING/CURB
C.R."B" #32: BUILDING/CURB
C.R."C" #32: BUILDING/CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 103	Date: SEPTEMBER 17, 2012
Location: FISCHRUPP ALLEY WEST OF NEW YORK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS CLARK	NE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS NEW YORK	NW	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS NEW YORK	SW	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS CLARK	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the Intersection? (NE,SE,NW,SW)	NE	NW	SW	SE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	S.S.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 103	Date: SEPTEMBER 17, 2012
Location: FISCHRUPP ALLEY WEST OF NEW YORK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS CLARK	NE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS NEW YORK	NW	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS NEW YORK	SW	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS CLARK	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	9.5 %	3.3 %	10.8 %	12.6 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	CLARK	N.Y.	N.Y.	CLARK				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	4.5 %	4.4 %	0.6 %	8.2 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	26 "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		9.5 %	3.3 %	10.8 %	12.6 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		6.2 %	7.0 %	1.7 %	5.4 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.1 %	7.2 %	4.6 %	3.5 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		.75 "	— "	.50 "	.75 "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R."A" #27: LOW CURB TRANSITION; #32: POLE/CURB/GRASS
C.R."C" #27: HIGH CURB TRANSITION; #32: LANDSCAPE/CURB
C.R."D" #27: HIGH CURB TRANSITION ; # 32: BUILDING/DRIVEWAY

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 104	Date: SEPTEMBER 17, 2012
Location: FISCHRUPP ALLEY EAST OF CLARK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS CLARK	SE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS NEW YORK	SW	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS NEW YORK	NW	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS CLARK	NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SW	NW	NE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	S.S.	S.S.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 104	Date: SEPTEMBER 17, 2012
Location: FISCHRUPP ALLEY EAST OF CLARK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS CLARK	SE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS NEW YORK	SW	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS NEW YORK	NW	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS CLARK	NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	.25 "	.25 "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	16.3 %	8.5 %	5.7 %	4.5 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	CLARK	N.Y.	N.Y.	CLARK				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.6 %	10.7 %	1.4 %	0.9 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		33 "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		16.3 %	8.5 %	5.7 %	4.5 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.0 %	2.3 %	6.0 %	5.2 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.1 %	4.8 %	2.0 %	2.1 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		.50 "	— "	1.5 "	.50 "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R."A" #27: HIGH CURB TRANSITION/LOW C.R. TRANSITION; #32: CURB
C.R."B" #32: WALL/CURB
C.R."C" #27: HIGH CURB TRANSITION; #32: BUILDING/CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 105	Date: SEPTEMBER 10, 2012
Location: CLARK & FISCHRUPP	Surveyors: B. WAJVODA

Describe each curb ramp's location:

Curb Ramp A: LOOKING AT 1931 CLARK	SW	Curb Ramp E: LOOKING AT CHURCH	NE
Curb Ramp B: LOOKING AT CHURCH	SW	Curb Ramp F: LOOKING AT 1931 CLARK	NE
Curb Ramp C: LOOKING AT COMMUNITY CENTER	NW	Curb Ramp G: LOOKING AT 1923 CLARK	SE
Curb Ramp D: LOOKING AT 1923 CLARK	NW	Curb Ramp H: LOOKING AT COMMUNITY CENTER	SE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	70"	72"	72"	70"	70"	58"	58"	70"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A	B	B	A
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.			B.C.	B.C.				
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	—
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SW	NW	NW	NE	NE	SE	SE
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	IRR.	IRR.	R.A.	R.A.	R.A.
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	N.C.	N.C.	S.S.	S.S.	S.S.	S.S.
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	N
15	What are the dimensions of any common landing for two curb ramps?	75 x 78"	75 x 78"	—"	—"	—"	—"	—"	—"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	—"	—"	—"	—"	—"	—"	—"	—"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 105	Date: SEPTEMBER 10, 2012
Location: CLARK & FISCHRUPP	Surveyors: B.WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 1931 CLARK	SW	Curb Ramp E: LOOKING AT CHURCH	NE
Curb Ramp B: LOOKING AT CHURCH	SW	Curb Ramp F: LOOKING AT 1931 CLARK	NE
Curb Ramp C: LOOKING AT COMMUNITY CENTER	NW	Curb Ramp G: LOOKING AT 1923 CLARK	SE
Curb Ramp D: LOOKING 1923 CLARK	NW	Curb Ramp H: LOOKING AT	SE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	.50 "	.50 "	.50 "	— "	— "	.25 "
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	1.6 %	6.2 %	2.0 %	1.4 %	3.2 %	10.4 %	6.9 %	5.6 %
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— % / — %	— % / — %	9.0 % / — %	9.0 % / — %	— % / — %	— % / — %	— % / — %	— % / — %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	CLARK	FISCH-RUPP	FISCH-RUPP	CLARK	CLARK	FISCH-RUPP	FISCH-RUPP	CLARK
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.3 %	6.1 %	1.6 %	5.3 %	0.8 %	4.7 %	1.6 %	5.9 %
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "
24	Does CR have a running slope of 8.33% or less?	Y or N / 1.6 %	Y or N / 6.2 %	Y or N / 2.0 %	Y or N / 1.4 %	Y or N / 3.2 %	Y or N / 10.4 %	Y or N / 6.9 %	Y or N / 5.6 %
25	Does CR have a cross slope of 2% or less?	Y or N / 1.6 %	Y or N / 0.2 %	Y or N / 1.1 %	Y or N / 1.1 %	Y or N / 3.2 %	Y or N / 0.5 %	Y or N / 0.8 %	Y or N / 2.7 %
26	Does CR have a gutter slope of 5% or less?	Y or N / 2.0 %	Y or N / 4.6 %	Y or N / 2.8 %	Y or N / 6.3 %	Y or N / 5.3 %	Y or N / 6.6 %	Y or N / 2.3 %	Y or N / 4.2 %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N / .5 "	Y or N / .25 "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / 2.0 "	Y or N / 1.5 "	Y or N / — "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	YES %	YES %	— %	— %	— %	— %
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "

Comments: C.R."A" #27: HIGH CURB TRANSITION C.R."F" #27: LOW CURB TRANSITION TO SIDEWALK/HIGH CURB

C.R."B" #27: HIGH CURB TRANSITION C.R."F" #32: STOP SIGN

C.R."E" #27: 1" GAP B/T CURB & SIDEWALK C.R."G" #27: LOW CURB TRANSITION TO SIDEWALK/HIGH CURB TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 1006	Date: SEPTEMBER 10, 2012
Location: CLARK ALLEY B/T 119th & FISCHRUPP	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS 119th	SE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS FISCHRUPP	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS FISCHRUPP	NW	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS 119th	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C	C	C				
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	NE	NW	SW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	N.C.	N.C.	S.S.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 106	Date: SEPTEMBER 10, 2012
Location: CLARK ALLEY B/T 119th & FISCHRUPP	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS 119th	SE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS FISCHRUPP	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS FISCHRUPP	NW	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS 119th	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	(Y) or N	Y or (N)	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25"	—"	—"	.25"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	1.2 %	2.3 %	2.3 %	1.1 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	—% —%	—% —%	—% —%	—% —%	% %	% %	% %	% %
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	119	FISCH-RUPP	FISCH-RUPP	119				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.9 %	3.3 %	1.4 %	0.9 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N —"	(Y) or N —"	(Y) or N —"	(Y) or N —"	Y or N "	Y or N "	Y or N "	Y or N "
24	Does CR have a running slope of 8.33% or less?	(Y) or N 1.2 %	(Y) or N 2.3 %	(Y) or N 2.5 %	(Y) or N 1.1 %	Y or N %	Y or N %	Y or N %	Y or N %
25	Does CR have a cross slope of 2% or less?	Y or (N) 2.2 %	(Y) or N 1.4 %	Y or (N) 3.4 %	Y or (N) 2.6 %	Y or N %	Y or N %	Y or N %	Y or N %
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~ —%	~~Y or N~~ —%	~~Y or N~~ —%	~~Y or N~~ —%	Y or N %	Y or N %	Y or N %	Y or N %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N —"	(Y) or N —"	(Y) or N —"	(Y) or N —"	Y or N "	Y or N "	Y or N "	Y or N "
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N —"	(Y) or N —"	(Y) or N —"	(Y) or N —"	Y or N "	Y or N "	Y or N "	Y or N "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	—%	—%	—%	—%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ —%	~~Y or N~~ —%	~~Y or N~~ —%	~~Y or N~~ —%	Y or N %	Y or N %	Y or N %	Y or N %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	Y or (N) —"	Y or (N) —"	Y or (N) —"	Y or (N) —"	Y or N "	Y or N "	Y or N "	Y or N "

Comments: C.R."A" #32: LANDSCAPE
C.R."B" #32: BUILDING
C.R."C" #32: BUILDING / CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 107	Date: SEPTEMBER 11, 2012
Location: TEMPLE & COMMUNITY	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT CHURCH	NW	Curb Ramp E:	
Curb Ramp B: LOOKING AT COMMUNITY CENTER	NW	Curb Ramp F:	
Curb Ramp C: LOOKING AT PARKING LOT	NE	Curb Ramp G:	
Curb Ramp D: LOOKING AT PARKING LOT	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	95"	95"	95"	95"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NW	NE	SW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	IRR.	IRR.	R.A.	IRR.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	—"	—"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	—"	—"	68"	41"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 107	Date: SEPTEMBER 11, 2012
Location: TEMPLE & COMMUNITY	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT CHURCH	NW	Curb Ramp E:	
Curb Ramp B: LOOKING AT COMMUNITY CENTER	NW	Curb Ramp F:	
Curb Ramp C: LOOKING AT PARKING LOT	NE	Curb Ramp G:	
Curb Ramp D: LOOKING AT PARKING LOT	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	4.5 %	4.5 %	6.3 %	4.8 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	TEM-PLE	COMM-UNITY	TEM-PLE	COMM-UNITY				
22	What is the slope of the transition to the sidewalk? (should be 5% or less)	2.5 %	2.5 %	2.0 %	3.9 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.5 %	4.5 %	6.3 %	4.8 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.1 %	0.1 %	0.4 %	2.4 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.8 %	2.8 %	0.1 %	0.5 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 108	Date: SEPTEMBER 11, 2012
Location: COMMUNITY ALLEY B/T INDIANAPOLIS & TEMPLE	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT INDIANAPOLIS	SE	Curb Ramp E:	
Curb Ramp B: LOOKING AT CLARK	SW	Curb Ramp F:	
Curb Ramp C: LOOKING AT INDIANAPOLIS	NE	Curb Ramp G:	
Curb Ramp D: LOOKING AT CLARK	NW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C	C	C				
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SW	NE	NW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	S.S.	N.C.	S.S.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 108	Date: SEPTEMBER 11, 2012
Location: COMMUNITY ALLEY B/T INDIANAPOLIS & TEMPLE	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT INDIANAPOLIS	SE	Curb Ramp E:	
Curb Ramp B: LOOKING AT CLARK	SW	Curb Ramp F:	
Curb Ramp C: LOOKING AT INDIANAPOLIS	NE	Curb Ramp G:	
Curb Ramp D: LOOKING AT CLARK	NW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	(Y) or N	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	.25 "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	3.9 %	1.4 %	4.3 %	5.4 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— % / — %	— % / — %	— % / — %	— % / — %	% / %	% / %	% / %	% / %
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	INDY	CLARK	INDY	CLARK				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.4 %	0.4 %	0.5 %	5.7 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N / — "	(Y) or N / — "	(Y) or N / — "	(Y) or N / — "	Y or N / "	Y or N / "	Y or N / "	Y or N / "
24	Does CR have a running slope of 8.33% or less?	(Y) or N / 3.9 %	(Y) or N / 1.4 %	(Y) or N / 4.3 %	(Y) or N / 5.4 %	Y or N / %	Y or N / %	Y or N / %	Y or N / %
25	Does CR have a cross slope of 2% or less?	Y or (N) / 2.9 %	(Y) or N / 0.8 %	(Y) or N / 1.1 %	(Y) or N / 1.1 %	Y or N / %	Y or N / %	Y or N / %	Y or N / %
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~ / — %	~~Y or N~~ / — %	(Y) or N / 2.5 %	~~Y or N~~ / — %	Y or N / %	Y or N / %	Y or N / %	Y or N / %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N / — "	(Y) or N / — "	(Y) or N / — "	(Y) or N / — "	Y or N / "	Y or N / "	Y or N / "	Y or N / "
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N / — "	(Y) or N / — "	(Y) or N / — "	(Y) or N / — "	Y or N / "	Y or N / "	Y or N / "	Y or N / "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	Y or N / %	Y or N / %	Y or N / %	Y or N / %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	Y or N / "	Y or N / "	Y or N / "	Y or N / "

Comments: C.R. "A" #32: CURB/WALL/GRASS
C.R. "B" #32: CURB/DRIVEWAY
C.R. "C" #32: LANDSCAPE/GRASS

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 109	Date: SEPTEMBER 11, 2012
Location: INDIANAPOLIS & COMMUNITY	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT AMERICAN LEGION	NE	Curb Ramp E:	
Curb Ramp B: LOOKING AT 1948 INDIANAPOLIS	NE	Curb Ramp F:	
Curb Ramp C: LOOKING AT WALGREENS	SE	Curb Ramp G:	
Curb Ramp D: LOOKING AT PARKING LOT	NW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	73 "	70 "	73 "	70 "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.		—				
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	V				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NE	SE	NW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	T.C.	T.C.	T.C.	T.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 109	Date: SEPTEMBER 11, 2012
Location: INDIANAPOLIS & COMMUNITY	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT AMERICAN LEGION	NE	Curb Ramp E:	
Curb Ramp B: LOOKING AT 1948 INDIANAPOLIS	NE	Curb Ramp F:	
Curb Ramp C: LOOKING AT WALGREENS	SE	Curb Ramp G:	
Curb Ramp D: LOOKING AT PARKING LOT	NW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25"	—"	.25"	—"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	8.0 %	4.2 %	5.1 %	— %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	6.3 %	6.3 %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	COMMUNITY	INDY	COMMUNITY	INDY				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	4.1 %	4.5 %	4.1 %	— %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		—"	—"	—"	—"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		8.0 %	4.2 %	5.1 %	— %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		2.5 %	5.7 %	3.4 %	— %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		5.5 %	1.3 %	3.5 %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		—"	.50"	—"	—"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		—"	—"	—"	—"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES %	YES %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		—"	—"	—"	—"	"	"	"	"

Comments: C.R."B" #27: HIGH CURB TRANSITION

C.R."C": MISSING A PIECE OF THE CURB TRANSITION & GUTTER SLOPE

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 110	Date: SEPTEMBER 17, 2012
Location: INDIANAPOLIS ALLEY B/T 119th & COMMUNITY	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 119th	SE	Curb Ramp E:	
Curb Ramp B: LOOKING AT INDIANAPOLIS	SE	Curb Ramp F:	
Curb Ramp C: LOOKING AT COMMUNITY	NE	Curb Ramp G:	
Curb Ramp D:		Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)								
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—					
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SE	NE					
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.					
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.					
14	What type of transit stop is there? (none, bus, other)	N	N	N					
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 110	Date: SEPTEMBER 17, 2012
Location: INDIANAPOLIS ALLEY B/T 119th & COMMUNITY	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 119th	SE	Curb Ramp E:	
Curb Ramp B: LOOKING AT INDIANAPOLIS	SE	Curb Ramp F:	
Curb Ramp C: LOOKING AT COMMUNITY	NE	Curb Ramp G:	
Curb Ramp D:		Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	.25 "	— "	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	1.0 %	5.7 %	2.7 %	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	5.7 %	5.7 %	— %	%	%	%	%	%
		— %	— %	— %	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	119	INDY	COMMUNITY					
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.5 %	0.3 %	3.4 %	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.0 %	5.7 %	2.7 %	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		6.2 %	6.2 %	2.5 %	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	.25 "	— "	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES %	YES %	— %	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	"	"	"	"	"

Comments: C.R. "B" #27: HIGH CURB TRANSITION
C.R. "C" #32: WALL / STREET

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 110. A	Date: SEPT. 17, 2012
Location: WALGREENS DRIVEWAY OFF OF INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 119th SE	Curb Ramp E:
Curb Ramp B: LOOKING AT COMMUNITY NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	NE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 110.A	Date: SEPTEMBER 17, 2012
Location: WALGREENS DRIVE WAY OFF OF INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 119th SE	Curb Ramp E:
Curb Ramp B: LOOKING AT COMMUNITY NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	3.3 %	1.5 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— % — %	— % — %	% %	% %	% %	% %	% %	% %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	119	COMMUNITY						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	2.4 %	1.2 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N — "	Y or N — "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
24	Does CR have a running slope of 8.33% or less?	Y or N 3.3 %	Y or N 1.5 %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
25	Does CR have a cross slope of 2% or less?	Y or N 1.1 %	Y or N 2.6 %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~ — %	~~Y or N~~ — %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N — "	Y or N — "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N — "	Y or N — "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ — %	~~Y or N~~ — %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ — "	~~Y or N~~ — "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "

Comments: C.R. "A" # 32: UTILITY POLE

C.R. "B" # 32: LANDSCAPING/CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 111	Date: AUGUST 27, 2012
Location: EUCLID & INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 1918 INDIANAPOLIS SW	Curb Ramp E:
Curb Ramp B: LOOKING AT 1926 INDIANAPOLIS NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	—	—						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	V	V						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	NW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 111	Date: AUGUST 27, 2012
Location: EUCLID & INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 1918 INDIANAPOLIS SW	Curb Ramp E:
Curb Ramp B: LOOKING AT 1926 INDIANAPOLIS NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	4.1 %	5.0 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		0.5 %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	EU-CLID	EU-CLID						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	— %	— %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.1 %	5.0 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.3 %	%	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	%	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.0 "	4.0 "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R."A" #27: NO C.R. JUST A CURB - LARGE HOLE IN SIDEWALK
C.R."B" #27: NO C.R. JUST A CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 112	Date: AUGUST 27, 2012
Location: EUCLID ALLEY B/T ATCHISON & INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 1916-18 INDIANAPOLIS	NW	Curb Ramp E:	
Curb Ramp B: LOOKING AT 1217 EUCLID	NE	Curb Ramp F:	
Curb Ramp C: LOOKING AT 1222 EUCLID	SE	Curb Ramp G:	
Curb Ramp D: LOOKING AT 1926 INDIANAPOLIS	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NE	SE	SW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	IRR.	IRR.	IRR.	IRR.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	N.C.	S.S.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 112	Date: AUGUST 27, 2012
Location: EUCLID ALLEY B/T ATCHISON & INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A:	LOOKING AT 1916-18 INDIANAPOLIS	NW	Curb Ramp E:
Curb Ramp B:	LOOKING AT 1217 EUCLID	NE	Curb Ramp F:
Curb Ramp C:	LOOKING AT 1222 EUCLID	SE	Curb Ramp G:
Curb Ramp D:	LOOKING AT 1926 INDIANAPOLIS	SW	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	.5 "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	3.7 %	1.6 %	12.0 %	5.8 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— % / — %	— % / — %	— % / — %	— % / — %	% / %	% / %	% / %	% / %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	INDY	ATCH-ISON	ATCH-ISON	INDY				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.6 %	2.9 %	1.2 %	5.9 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / "	Y or N / "	Y or N / "	Y or N / "
24	Does CR have a running slope of 8.33% or less?	Y or N / 3.7 %	Y or N / 1.6 %	Y or N / 12.0 %	Y or N / 5.8 %	Y or N / %	Y or N / %	Y or N / %	Y or N / %
25	Does CR have a cross slope of 2% or less?	Y or N / 1.9 %	Y or N / 1.2 %	Y or N / 4.1 %	Y or N / 4.5 %	Y or N / %	Y or N / %	Y or N / %	Y or N / %
26	Does CR have a gutter slope of 5% or less?	Y or N / 0.3 %	Y or N / 1.3 %	Y or N / 4.5 %	Y or N / 0.2 %	Y or N / %	Y or N / %	Y or N / %	Y or N / %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N / — "	Y or N / — "	Y or N / .5 "	Y or N / — "	Y or N / "	Y or N / "	Y or N / "	Y or N / "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / "	Y or N / "	Y or N / "	Y or N / "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	Y or N / %	Y or N / %	Y or N / %	Y or N / %
32	If no flared sides, is there an obstruction of grass in each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	Y or N / "	Y or N / "	Y or N / "	Y or N / "

Comments: C.R."A" #32: GRASS/FENCE
C.R."B" #32: GRASS/FENCE
C.R."C" #32: BUILDING/DRIVEWAY ; #27: HIGH ASPHALT

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 113	Date: AUGUST 27, 2012
Location: EUCLID & ATCHISON	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS 1926 ATCHISON NE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS 1200 EUCLID NE	Curb Ramp F:
Curb Ramp C: LOOKING TOWARDS 1201 EUCLID SE	Curb Ramp G:
Curb Ramp D: LOOKING TOWARDS 1928 ATCHISON SE	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NE	SE	SE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	69x 73 "	69x 73 "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 113	Date: AUGUST 27, 2012
Location: EUCLID & ATCHISON	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS 1926 ATCHISON	NE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS 1200 EUCLID	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS 1201 EUCLID	SE	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS 1928 ATCHISON	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25 "	.25 "	.25 "	.25 "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	8.0 %	9.5 %	9.6 %	8.4 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	ATCH-ISON	EU-CLID	EU-CLID	ATCH-ISON				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	3.0 %	6.9 %	7.1 %	2.4 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
		8.0 %	9.5 %	9.6 %	8.4 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
		8.1 %	2.3 %	3.3 %	8.4 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	(Y) or N	(Y) or N	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
		4.1 %	4.1 %	5.3 %	10.1 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or (N)	Y or (N)	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N
		1.0 "	1.0 "	.5 "	1.0 "	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" # 27: HIGH ASPHALT, HIGH CURB TRANSITION, HIGH SIDEWALK
C.R. "B" # 27: HIGH ASPHALT, HIGH CURB TRANSITION, HIGH SIDEWALK
C.R "C" # 27: HIGH ASPHALT HIGH CURB TRANSITION, HIGH SIDEWALK

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 114	Date: AUGUST 27, 2012
Location: ATCHISON ALLEY B/T 119th & EUCLID	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS 119th SE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS EUCLID NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? if present, answer questions 1.A, 1.B, 1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	NE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 114	Date: AUGUST 27, 2012
Location: ATCHISON ALLEY B/T 119th & EUCLID	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS 119th SE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS EUCLID NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	9.2 %	9.8 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	119	EUCLID						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	7.4 %	1.1 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		9.2 %	9.8 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.2 %	1.8 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		6.0 %	0.4 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	2.0 "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" #32: GRASS / LANDSCAPING
C.R. "B" #27: SIDEWALK IS TOO HIGH OF CURB TRANSITION
C.R. "B" # 32: CURB / BUILDING

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 115	Date: AUGUST 28, 2012
Location: ATCHISON ALLEY B/T EUCLID & 120th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS 120th SE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS W. FRED NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	SE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 115	Date: AUGUST 28, 2012
Location: ATCHISON ALLEY B/T EUCLID & 120th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS 120th SE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS W. FRED NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	5.5 %	6.2 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	120th	W. FRED						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.1 %	3.0 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		5.5 %	6.2 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.3 %	2.0 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	1.3 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, Is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R."A" #32: GRASS/UTILITY POLE/DRIVEWAY - GAP B/T ASPHALT & CONCRETE
C.R."B" #32: GRASS/BUILDING

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 116	Date: AUGUST 28, 2012
Location: 120th & ATCHISON	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 1948 ATCHISON	NE	Curb Ramp E:	
Curb Ramp B: LOOKING AT 1200 120th	NE	Curb Ramp F:	
Curb Ramp C: LOOKING AT 1201 120th	SE	Curb Ramp G:	
Curb Ramp D: LOOKING AT ATCHISON	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NE	SE	SE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	72" x 69"	72" x 69"	77" x 71"	77" x 71"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Aiteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 116	Date: AUGUST 28, 2012
Location: 120th & ATCHISON	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 1998 ATCHISON	NE	Curb Ramp E:	
Curb Ramp B: LOOKING AT 1200 120th	NE	Curb Ramp F:	
Curb Ramp C: LOOKING AT 1201 120th	SE	Curb Ramp G:	
Curb Ramp D: LOOKING AT ATCHISON	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25"	.25"	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	9.9 %	8.4 %	9.9 %	7.6 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	ATCH-ISON	120	120	ATCH-ISON				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	11.0 %	9.1 %	7.9 %	5.4 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		9.9 %	8.4 %	9.9 %	7.6 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		6.2 %	3.4 %	3.8 %	2.8 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.8 %	4.8 %	8.1 %	5.7 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.0"	1.0"	1.0"	1.0"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" #27: HIGH CURB TRANSITION
C.R. "B" #27: HIGH CURB TRANSITION
C.R. "C" #27: HIGH CURB TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 117	Date: AUGUST 28, 2012
Location: ATCHISON ALLEY B/T 120th & WEST FRED	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS EUCLID SE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS 120th NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	NE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 117	Date: AUGUST 28, 2012
Location: ATCHISON ALLEY B/T 120th & WEST FRED	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS EUCLID SE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS 120th NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	6.1 %	4.5 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	EU-CLID	120						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	5.9 %	1.6 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		6.1 %	4.5 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.8 %	4.8 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.7 %	0.5 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" #32: BUILDING/GRASS -LARGE GAP B/T ASPHALT & CONCRETE

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 118	Date: AUGUST 28, 2012
Location: WEST FRED & ATCHISON	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 2026 ATCHISON	NE	Curb Ramp E:	
Curb Ramp B: LOOKING AT 1202 W. FRED	NE	Curb Ramp F:	
Curb Ramp C: LOOKING AT 1201 W. FRED	SE	Curb Ramp G:	
Curb Ramp D: LOOKING AT ATCHISON	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NE	SE	SE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	73 x 75 "	73 x 75 "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 118	Date: AUGUST 28, 2012
Location: WEST FRED & ATCHISON	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING 2026 ATCHISON	NE	Curb Ramp E:	
Curb Ramp B: LOOKING AT 1202 W. FRED	NE	Curb Ramp F:	
Curb Ramp C: LOOKING AT 1201 W. FRED	SE	Curb Ramp G:	
Curb Ramp D: LOOKING AT ATCHISON	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	(Y) or N	Y or (N)	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25 "	— "	.25 "	.25 "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	10.1 %	9.9 %	11.7 %	9.5 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	ATCH-ISON	W. FRED	W. FRED	ATCH-ISON				
22	What is the slope of the transition to the sidewalk? (should be 5% or less)	5.2 %	11.2 %	10.7 %	7.5 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
		10.1 %	9.9 %	11.7 %	9.5 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
		7.3 %	5.5 %	4.6 %	5.4 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	(Y) or N	Y or (N)	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N
		4.6 %	5.1 %	5.0 %	5.1 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or (N)	Y or (N)	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N
		.5 "	.25 "	— "	.25 "	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction on grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" #27: CURB TRANSITION TO SIDEWALK IS LOW
C.R. "B" #27: CURB TRANSITION TO SIDEWALK IS LOW
C.R. "D" #27: CURB TRANSITION TO SIDEWALK IS LOW

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 119	Date:
Location: ATCHISON ALLEY B/T WEST FRED & 121 ST	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS WEST FRED SE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS 121 ST NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	NE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 119	Date:
Location: ATCHISON ALLEY B/T WEST FRED & 121 ST	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS WEST FRED SE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS 121 ST NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	3.9 %	3.6 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	WEST FRED	121						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	3.4 %	1.4 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.9 %	3.6 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.7 %	3.6 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		8.5 %	3.8 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		.50 "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" #27: LOW CURB TRANSITION

C.R. "A" # 32: BUILDING/GRASS

C.R. "B" # 32: FENCE/GRASS

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 120	Date:
Location: 121 ST & ATCHISON	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS ATCHISON NE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS 121 ST NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	69 "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.						
14	What type of transit stop is there? (none, bus, other)	N.C.	N						
15	What are the dimensions of any common landing for two curb ramps?	71 x 71 "	71 x 71 "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 120	Date:
Location: 121 ST & ATCHISON	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS ATCHISON NE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS 121 ST NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	50 "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	3.0 %	1.5 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	ATCH-ISON	121						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	4.2 %	4.4 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.0 %	1.5 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.2 %	0.6 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.3 %	7.1 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.0 "	.50 "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" #27: HIGH CURB TRANSITION / HIGH SIDEWALK

C.R. "B" #27: HIGH CURB TRANISITION / HIGH SIDEWALK

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 121	Date:
Location: 121 ST & KELLY	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS 121 ST	NE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS KELLY	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS KELLY	NW	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS 121 ST	NW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NE	NW	NW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	IR.R.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 121	Date:
Location: 121 ST & KELLY	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS 121 ST	NE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS KELLY	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS KELLY	NW	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS 121 ST	NW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.50"	.50"	.25"	.25"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	5.5 %	6.2 %	2.2 %	5.1 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	121	KELLY	KELLY	121				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	2.8 %	4.4 %	2.8 %	3.3 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		5.5 %	6.2 %	2.2 %	5.1 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.6 %	2.0 %	1.9 %	0.2 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		9.1 %	7.9 %	8.1 %	6.3 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		.50"	.50"	1.0"	1.0"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" #27: LOW CURB TRANSITION

C.R. "B" #27: LOW CURB TRANSITION / POLE

C.R. "C" #27: LOW CURB TRANSITION : #32: LANDSCAPING

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 122	Date:
Location: KELLY ALLEY B/T WEST FRED & 121ST	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS WEST FRED	SW	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS 121 ST	NW	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS 121 ST	NE	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS WEST FRED	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What Is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	NW	NE	SE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	N.C.	S.S.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 122	Date:
Location: KELLY ALLEY B/T WEST FRED & 121 ST	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS WEST FRED	SW	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS 121 ST	NW	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS 121 ST	NE	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS WEST FRED	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	.25 "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.8 %	1.6 %	3.7 %	4.6 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	WEST FRED	121	121	WEST FRED				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	2.1 %	0.8 %	4.8 %	2.1 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.8 %	1.6 %	3.7 %	4.6 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.0 %	0.4 %	0.8 %	0.6 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.7 %	1.9 %	0.6 %	0.2 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		.25 "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" #27: HIGH CURB TRANSITION

C.R. "B" #32: GARAGE / DRIVEWAY

C.R. "C" #32: BUILDING / GRASS

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 123	Date: AUGUST 28, 2012
Location: WEST FRED & KELLY	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 1301 W. FRED	SE	Curb Ramp E: LOOKING AT 1246 W. FRED	NW
Curb Ramp B: LOOKING AT 1246 W. FRED	SE	Curb Ramp F: LOOKING AT 1302 W. FRED	NE
Curb Ramp C: LOOKING AT 1302 W. FRED	SW	Curb Ramp G:	
Curb Ramp D: LOOKING AT 1247 W. FRED	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	— "	— "	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A	A		
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the Intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—		
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SE	SW	SW	NW	NE		
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A	R.A.	R.A	R.A	R.A.		
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	N.C.	N.C.	N.C.		
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N		
15	What are the dimensions of any common landing for two curb ramps?	72 x 70 "	72 x 70 "	74 x 71 "	74 x 71 "	— "	— "	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	— "	— "	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 123	Date: AUGUST 28, 2012
Location: WEST FRED & KELLY	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 1301 W. FRED	SE	Curb Ramp E: LOOKING AT 1246 W. FRED	NW
Curb Ramp B: LOOKING AT 1246 W. FRED	SE	Curb Ramp F: LOOKING AT 1302 W. FRED	NE
Curb Ramp C: LOOKING AT 1302 W. FRED	SW	Curb Ramp G:	
Curb Ramp D: LOOKING AT 1247 W. FRED	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	.5 "	— "	— "	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	9.1 %	11.2 %	8.6 %	8.0 %	7.2 %	4.4 %	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	— %	— %	%	%
		— %	— %	— %	— %	— %	— %	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	W. FRED	KELLY	KELLY	W. FRED	W. FRED	W. FRED		
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	9.2 %	10.8 %	9.2 %	6.8 %	7.2 %	8.3 %	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		9.1 %	11.2 %	8.6 %	8.0 %	7.2 %	4.4 %	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.6 %	1.6 %	2.8 %	3.4 %	1.9 %	1.2 %	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		6.0 %	10.3 %	4.9 %	8.3 %	7.0 %	5.4 %	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.0 "	1.0 "	.5 "	.5 "	.5 "	.5 "	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	— %	— %	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
		— %	— %	— %	— %	— %	— %	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	"	"

Comments: C.R. "A" #27: LOW CURB TRANSITION C.R."E" #27: LOW CURB TRANSITION
C.R. "B" #27: CRACKS IN ASPHALT; LOW CURB TRANSITION
C.R. "C" #27: UNEVEN GUTTER SLOPE C.R."F" #27: HIGH CURB TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 124	Date: AUGUST 28, 2012
Location: WEST FRED ALLEY B/T ATCHISON & INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS KELLY PLACE	SE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS INDIANAPOLIS	SW	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS INDIANAPOLIS	NW	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS KELLY PLACE	NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	Y or N	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SW	NW	NE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	N.C.	S.S.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 124	Date: AUGUST 28, 2012
Location: WEST FRED ALLEY B/T ATCHISON & INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS KELLY PLACE	SE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS INDIANAPOLIS	SW	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS INDIANAPOLIS	NW	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS KELLY PLACE	NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	.25 "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	2.7 %	2.8 %	9.0 %	12.4 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	KELLY	INDY	INDY	KELLY				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	3.9 %	2.3 %	7.4 %	0.4 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	26 "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.7 %	2.8 %	9.0 %	12.4 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.2 %	2.3 %	1.8 %	6.5 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	5.1 %	4.0 %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	.25 "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R."A" #32: BUILDING/CURB
C.R."C" #27: LOW CURB TRANSITION TO SIDEWALK
C.R."C" #32: FENCE/LANDSCAPING

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 125	Date: AUGUST 28, 2012
Location: 120th ALLEY B/T ATCHISON & INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 1244 120th SE	Curb Ramp E:
Curb Ramp B: LOOKING AT EMPTY LOT SW	Curb Ramp F:
Curb Ramp C: LOOKING AT 1962 INDIANAPOLIS NW	Curb Ramp G:
Curb Ramp D: LOOKING AT 1237 120th NE	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	TBD	TBD	TBD	TBD				
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SW	NW	NE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	IRR.	IRR.	IRR.	IRR.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	N.C.	S.S.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 125	Date: AUGUST 28, 2012
Location: 120th ALLEY B/T ATCHISON & INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 1244 120th SE	Curb Ramp E:
Curb Ramp B: LOOKING AT EMPTY LOT SW	Curb Ramp F:
Curb Ramp C: LOOKING AT 1952 INDIANAPOLIS NW	Curb Ramp G:
Curb Ramp D: LOOKING AT 1237 120th NE	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25"	— "	.25"	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	2.6 %	1.9 %	2.7 %	7.3 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— % / — %	— % / — %	— % / — %	— % / — %	% / %	% / %	% / %	% / %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	ATCH-ISON	INDY	INDY	ATCH-ISON				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	3.2 %	0.1 %	3.4 %	3.2 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / 32 "	Y or N / "	Y or N / "	Y or N / "	Y or N / "
24	Does CR have a running slope of 8.33% or less?	Y or N / 2.6 %	Y or N / 1.9 %	Y or N / 2.7 %	Y or N / 7.3 %	Y or N / %	Y or N / %	Y or N / %	Y or N / %
25	Does CR have a cross slope of 2% or less?	Y or N / 1.9 %	Y or N / 2.9 %	Y or N / 2.3 %	Y or N / 8.6 %	Y or N / %	Y or N / %	Y or N / %	Y or N / %
26	Does CR have a gutter slope of 5% or less?	Y or N / 2.8 %	Y or N / 3.6 %	Y or N / 0.1 %	Y or N / 4.5 %	Y or N / %	Y or N / %	Y or N / %	Y or N / %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N / .25"	Y or N / — "	Y or N / .25"	Y or N / 2.0"	Y or N / "	Y or N / "	Y or N / "	Y or N / "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / "	Y or N / "	Y or N / "	Y or N / "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	Y or N / %	Y or N / %	Y or N / %	Y or N / %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	Y or N / "	Y or N / "	Y or N / "	Y or N / "

Comments: C.R. "A" #27: HIGH ASPHALT/CURB TRANSITION; #32: GRASS/FENCE
C.R "B" #32: HOUSE/GRASS
C.R "C" #32: LANDSCAPING ; #27: HIGH ASPHALT

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 126	Date: AUGUST 28, 2012
Location: 120th & INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT EMPTY LOT	NW	Curb Ramp E:	
Curb Ramp B: LOOKING AT 1952 INDIANAPOLIS	SW	Curb Ramp F:	
Curb Ramp C: LOOKING AT AMERICAN LEGION	SW	Curb Ramp G:	
Curb Ramp D: LOOKING AT EMPTY LOT	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	72"	72"	68"	68"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	—	—	—				
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	V				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	SW	SW	SE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	T.C.	T.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	—"	—"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	—"	—"	—"	—"	"	"	"	"

Comments: C.R. "A" #9 PEDESTRIAN SIGNAL IN CENTER OF C.R.
C.R. "B" #9 TRAFFIC LIGHT/PEDESTRIAN SIGNAL IN C.R.

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 126	Date: AUGUST 28, 2012
Location: 120th & INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT EMPTY LOT	NW	Curb Ramp E:	
Curb Ramp B: LOOKING AT 1952 INDIANAPOLIS	SW	Curb Ramp F:	
Curb Ramp C: LOOKING AT AMERICAN LEGION	SW	Curb Ramp G:	
Curb Ramp D: LOOKING AT EMPTY LOT	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	2.7 %	3.2 %	0.9 %	4.2 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	2.2 % 1.9 %	— % — %	— % — %	— % — %	% %	% %	% %	% %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	120	120	INDY	INDY				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	— %	— %	— %	— %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N "	Y or N "	Y or N "	Y or N "
24	Does CR have a running slope of 8.33% or less?	Y or N 2.7 %	Y or N 3.2 %	Y or N 0.9 %	Y or N 4.2 %	Y or N %	Y or N %	Y or N %	Y or N %
25	Does CR have a cross slope of 2% or less?	Y or N 2.3 %	Y or N 0.1 %	Y or N 2.5 %	Y or N 0.4 %	Y or N %	Y or N %	Y or N %	Y or N %
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	Y or N %	Y or N %	Y or N %	Y or N %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N "	Y or N "	Y or N "	Y or N "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N "	Y or N "	Y or N "	Y or N "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES —	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	Y or N %	Y or N %	Y or N %	Y or N %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	Y or N "	Y or N "	Y or N "	Y or N "

Comments: C.R. "A" SIDEWALK HAS A LOT OF DAMAGE
C.R. "B" SIDEWALK HAS LARGE CRACKS
C.R. "D" #32: UTILITY POLE

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 127	Date: AUGUST 28, 2012
Location: WEST FRED & INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 2040 INDIANAPOLIS SW	Curb Ramp E:
Curb Ramp B: LOOKING AT 2048 INDIANAPOLIS NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	—	B.C.						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	V	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	NW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 127	Date: AUGUST 28, 2012
Location: WEST FRED & INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 2040 INDIANAPOLIS SW	Curb Ramp E:
Curb Ramp B: LOOKING AT 2048 INDIANAPOLIS NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	— %	5.6 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	3.0 %	%	%	%	%	%	%
		— %	2.0 %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	W. FRED	INDY						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	— %	1.3 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	~~Y or N~~	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	~~Y or N~~	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	5.6 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	~~Y or N~~	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	0.6 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	~~Y or N~~	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	~~Y or N~~	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	~~Y or N~~	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	YES %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 128	Date:
Location: 121ST ALLEY WEST OF INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS KELLY NE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS INDIANAPOLIS NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	S.S.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 128	Date:
Location: 121ST ALLEY WEST OF INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS KELLY NE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS INDIANAPOLIS NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.7 %	1.8 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	KELLY	INDY						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.7 %	0.4 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.7 %	1.8 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.6 %	2.6 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.8 %	2.1 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" # 32: GRASS / GAS LINE
C.R. "B" # 32: GRASS / LANDSCAPING

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 129	Date:
Location: 121ST & INDIANAPOLIS WEST SIDE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT OMNI AUTO SALES NW	Curb Ramp E:
Curb Ramp B:	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	"	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A							
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.							
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—							
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW							
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	IRR.							
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	T.C.							
14	What type of transit stop is there? (none, bus, other)	N							
15	What are the dimensions of any common landing for two curb ramps?	— "	"	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	"	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 129	Date:
Location: 121ST & INDIANAPOLIS WEST SIDE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT OMNI AUTO SALES NW	Curb Ramp E:
Curb Ramp B:	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	1.0 "	"	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	5.9 %	%	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	4.8 %	%	%	%	%	%	%	%
		2.1 %	%	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	INDY							
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	7.3 %	%	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	"	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		5.9 %	%	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.7 %	%	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.2 %	%	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.0 "	"	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	"	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES %	%	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	%	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	"	"	"	"	"	"	"

Comments: C.R. "A" #27: LOW CURB RAMP
SEVERAL CRACKS IN C.R.

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 130	Date:
Location: 121ST & INDIANAPOLIS EAST SIDE	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 1401 121 ST	SE	Curb Ramp E:	
Curb Ramp B: LOOKING AT CHURCH	SE	Curb Ramp F:	
Curb Ramp C: LOOKING AT OMNI AUTO SALES	NE	Curb Ramp G:	
Curb Ramp D:		Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A					
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.	B.C.					
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—					
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SE	NE					
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.					
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	T.C.	T.C.	T.C.					
14	What type of transit stop is there? (none, bus, other)	N	N	N					
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 130	Date:
Location: 121ST & INDIANAPOLIS EAST SIDE	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 1401 121ST	SE	Curb Ramp E:	
Curb Ramp B: LOOKING AT CHURCH	SE	Curb Ramp F:	
Curb Ramp C: LOOKING AT OMNI AUTO SALES	NE	Curb Ramp G:	
Curb Ramp D:		Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	2.6 %	3.0 %	7.7 %	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	5.6 %	%	%	%	%	%
		— %	— %	2.6 %	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	121	INDY	121					
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.2 %	2.2 %	5.0 %	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.6 %	3.0 %	7.7 %	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.0 %	1.0 %	0.5 %	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	4.5 %	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	YES %	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 131	Date:
Location: 121 ST & DAVIDSON	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS INDIANAPOLIS	NE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS OMNI AUTO SALES	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS EMPTY LOT	NW	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS OMNI AUTO SALES	NW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.	B.C.	B.C.				
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NE	NW	NW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	S.S.	S.S.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 131	Date:
Location: 121ST & DAVIDSON	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS INDIANAPOLIS	NE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS OMNI AUTO SALES	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS EMPTY LOT	NW	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS OMNI AUTO SALES	NW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.50 "	.25 "	.75 "	.25 "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	4.8 %	1.2 %	5.8 %	3.4 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	6.3 %	6.3 %	6.2 %	6.2 %	%	%	%	%
		— %	— %	9.9 %	9.9 %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	INDY	N.Y.	N.Y.	INDY				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	8.0 %	1.9 %	2.4 %	2.7 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.8 %	1.2 %	5.8 %	3.4 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.4 %	2.4 %	0.8 %	0.8 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		5.9 %	5.8 %	5.8 %	4.3 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.5 "	— "	1.0 "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES %	YES %	YES %	YES %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" #27: HIGH CURB TRANSITION
C.R. "C" #27: HIGH CURB TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 132	Date:
Location: 121ST ALLEY EAST OF DAVIDSON	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS NEW YORK	NW	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS INDIANAPOLIS	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS INDIANAPOLIS	SE	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS NEW YORK	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C	C	C				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NE	SE	SW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	IRR.	IRR.	IRR.	IRR.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	S.S.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 132	Date:
Location: 121 ST ALLEY EAST OF DAVIDSON	Surveyors: B. WAJVODA

Describe each curb ramp's location:		
Curb Ramp A: LOOKING TOWARDS NEW YORK	NW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS INDIANAPOLIS	NE	Curb Ramp F:
Curb Ramp C: LOOKING TOWARDS INDIANAPOLIS	SE	Curb Ramp G:
Curb Ramp D: LOOKING TOWARDS NEW YORK	SW	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	.25 "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.7 %	0.5 %	0.4 %	1.3 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	N.Y.	INDY	INDY	N.Y.				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.1 %	0.3 %	0.8 %	1.8 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.7 %	0.5 %	0.4 %	1.3 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.6 %	2.3 %	2.4 %	3.9 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "D" # 32: BUILDING/GRASS

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 133	Date:
Location: 121ST ALLEY WEST OF NEW YORK	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS DAVIDSON SE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS NEW YORK SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 133	Date:
Location: 121ST ALLEY WEST OF NEW YORK	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS DAVIDSON SE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS NEW YORK SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.2 %	0.1 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	DAVID-SON	N.Y.						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.2 %	0.5 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.2 %	0.1 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.2 %	1.6 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" #32: BUILDING/GRASS

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 134	Date:
Location: FRED ALLEY EAST OF DAVIDSON	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS NEW YORK	SW	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS DAVIDSON	SE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS DAVIDSON	NE	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS NEW YORK	NW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C	C	C				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SE	NE	NW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	S.S.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 134	Date:
Location: FRED ALLEY EAST OF DAVIDSON	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS NEW YORK	SW	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS DAVIDSON	SE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS DAVIDSON	NE	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS NEW YORK	NW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25"	.25"	—"	—"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.3 %	6.9 %	4.6 %	2.9 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	—% —%	—% —%	—% —%	—% —%	% %	% %	% %	% %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	N.Y.	DAVID-SON	DAVID-SON	N.Y.				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.5 %	4.4 %	8.9 %	0.5 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N —"	Y or N —"	Y or N —"	Y or N —"	Y or N "	Y or N "	Y or N "	Y or N "
24	Does CR have a running slope of 8.33% or less?	Y or N 0.3 %	Y or N 6.9 %	Y or N 4.6 %	Y or N 2.9 %	Y or N %	Y or N %	Y or N %	Y or N %
25	Does CR have a cross slope of 2% or less?	Y or N 2.2 %	Y or N 3.2 %	Y or N 1.5 %	Y or N 5.7 %	Y or N %	Y or N %	Y or N %	Y or N %
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~ —%	~~Y or N~~ —%	~~Y or N~~ —%	~~Y or N~~ —%	Y or N %	Y or N %	Y or N %	Y or N %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N —"	Y or N —"	Y or N —"	Y or N —"	Y or N "	Y or N "	Y or N "	Y or N "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N —"	Y or N —"	Y or N —"	Y or N —"	Y or N "	Y or N "	Y or N "	Y or N "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	—%	—%	—%	—%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ —%	~~Y or N~~ —%	~~Y or N~~ —%	~~Y or N~~ —%	Y or N %	Y or N %	Y or N %	Y or N %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ —"	~~Y or N~~ —"	~~Y or N~~ —"	~~Y or N~~ —"	Y or N "	Y or N "	Y or N "	Y or N "

Comments: C.R. "A" #32: DRIVEWAY
C.R. "B" #32: LANDSCAPE / CURB
C.R. "C" #32: LANDSCAPE / CURB / HYDRANT

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 135	Date:
Location: DAVIDSON & FRED	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 2027 DAVIDSON	NE	Curb Ramp E:	
Curb Ramp B: LOOKING AT 2022 DAVIDSON	NE	Curb Ramp F:	
Curb Ramp C: LOOKING AT 2021 DAVIDSON	SE	Curb Ramp G:	
Curb Ramp D: LOOKING AT 2024 DAVIDSON	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.	B.C.	B.C.				
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NE	SE	SE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 135	Date:
Location: DAVIDSON & FRED	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 2027 DAVIDSON	NE	Curb Ramp E:	
Curb Ramp B: LOOKING AT 2022 DAVIDSON	NE	Curb Ramp F:	
Curb Ramp C: LOOKING AT 2021 DAVIDSON	SE	Curb Ramp G:	
Curb Ramp D: LOOKING AT 2024 DAVIDSON	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	(Y) or N	(Y) or N	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25 "	.25 "	.25 "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	4.0 %	1.5 %	1.7 %	0.3 %	%	%	%	%
19	Is a side slope or parallel slope present?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	4.9 %	4.9 %	3.0 %	3.0 %	%	%	%	%
		— %	— %	5.3 %	5.3 %	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	FRED	DAVID-SON	FRED	DAVID-SON				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	4.2 %	0.4 %	0.5 %	0.0 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		4.0 %	1.5 %	1.7 %	0.3 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		0.3 %	0.3 %	0.7 %	0.7 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		4.1 %	2.7 %	3.9 %	1.9 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES %	YES %	YES %	YES %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "D" # 32: SIGN

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 136	Date: SEPTEMBER 19, 2012
Location: JOHN ALLEY WEST OF NEW YORK	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS NEW YORK NW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS DAVIDSON NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	S.S.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 136	Date: SEPTEMBER 19, 2012
Location: JOHN ALLEY WEST OF NEW YORK	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS NEW YORK NW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS DAVIDSON NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	9.0 %	10.1 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	N.Y.	DAVID-SON						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	5.5 %	6.4 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		9.0 %	10.1 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.1 %	3.6 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" # 32: FENCE/CURB
C.R. "B" # 32: BUILDING/CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 137	Date: SEPTEMBER 19, 2012
Location: JOHN ALLEY EAST OF DAVIDSON	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS NEW YORK SW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS DAVIDSON SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	S.S.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 137	Date: SEPTEMBER 19, 2012
Location: JOHN ALLEY EAST OF DAVIDSON	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS NEW YORK	SW	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS DAVIDSON	SE	Curb Ramp F:	
Curb Ramp C:		Curb Ramp G:	
Curb Ramp D:		Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25"	—"	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	8.7%	8.7%	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	—%	—%	%	%	%	%	%	%
		—%	—%	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	N.Y.	DAVID-SON						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	9.0%	4.7%	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		—"	—"	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		8.7%	8.7%	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.1%	1.6%	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		—%	—%	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		.50"	—"	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		—"	—"	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	—%	—%	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		—%	—%	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		—"	—"	"	"	"	"	"	"

Comments: C.R. "A" #27: LOW CURB RAMP
C.R. "A" #32: GRASS/CURB
C.R. "B" #32: GRASS/CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 138	Date: SEPTEMBER 19, 2012
Location: DAVIDSON & JOHN	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 2001 DAVIDSON SW	Curb Ramp E:
Curb Ramp B: LOOKING AT 2002 DAVIDSON SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 138	Date: SEPTEMBER 19, 2012
Location: DAVIDSON & JOHN	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 2001 DAVIDSON SW	Curb Ramp E:
Curb Ramp B: LOOKING AT 2002 DAVIDSON SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	.25 "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	4.0 %	3.2 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	7.4 % 5.8 %	9.9 % — %	% %	% %	% %	% %	% %	% %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	JOHN	DAVID-SON						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	3.7 %	3.3 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N — "	Y or N — "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
24	Does CR have a running slope of 8.33% or less?	Y or N 4.0 %	Y or N 3.2 %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
25	Does CR have a cross slope of 2% or less?	Y or N 0.1 %	Y or N 4.1 %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
26	Does CR have a gutter slope of 5% or less?	Y or N 0.3 %	Y or N 1.7 %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N 1.5 "	Y or N — "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N — "	Y or N — "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES*	YES*	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ — %	~~Y or N~~ — %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ — "	~~Y or N~~ — "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "

Comments: C.R. "A" #27: HIGH CURB TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 139	Date: SEPTEMBER 19, 2012
Location: JOHN ALLEY EAST OF CLARK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS DAVIDSON	NW	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS CLARK	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS CLARK	SE	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS DAVIDSON	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NE	SE	SW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	IRR.	IRR.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 139	Date: SEPTEMBER 19, 2012
Location: JOHN ALLEY EAST OF CLARK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS DAVIDSON	NW	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS CLARK	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS CLARK	SE	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS DAVIDSON	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	.25 "	.25 "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.5 %	4.6 %	1.4 %	1.6 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	DAVID-SON	CLARK	CLARK	DAVID-SON				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.1 %	5.3 %	1.9 %	6.3 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.5 %	4.6 %	1.4 %	1.6 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.3 %	3.4 %	1.4 %	3.4 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.7 %	1.5 %	2.1 %	2.3 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" # 32: GARAGE / DRIVEWAY
C.R. "B" # 32: FENCE/CURB
C.R. "C" # 32: BUILDING/CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 140	Date: SEPTEMBER 06, 2012
Location: CLARK & JOHN	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 1951 CLARK	NW	Curb Ramp E: LOOKING AT 1951 CLARK	SE
Curb Ramp B: LOOKING AT ST. MARY'S CHURCH	NW	Curb Ramp F:	
Curb Ramp C: LOOKING AT PENNY PARK	NE	Curb Ramp G:	
Curb Ramp D: LOOKING AT ST. MARY'S CHURCH	NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	68"	—"	68"	72"	72"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A			
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.	B.C.	B.C.				
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—			
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NW	NE	NE	SE			
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	IRR.	R.A.	R.A.	R.A.			
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	N.C.	N.C.	S.S.			
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N			
15	What are the dimensions of any common landing for two curb ramps?	—"	—"	—"	—"	—"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	34"	34"	—"	—"	—"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 140	Date: SEPTEMBER 06, 2012
Location: CLARK & JOHN	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 1951 CLARK	NW	Curb Ramp E: LOOKING AT 1951 CLARK	SE
Curb Ramp B: LOOKING AT ST. MARY'S CHURCH	NW	Curb Ramp F:	
Curb Ramp C: LOOKING AT PENNY PARK	NE	Curb Ramp G:	
Curb Ramp D: LOOKING AT ST. MARY'S CHURCH	NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	.25 "	.25 "	— "	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	5.3 %	5.1 %	3.6 %	8.3 %	5.1 %	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	5.1 %	8.4 %	— %	6.7 %	6.8 %	%	%	%
		— %	12.3 %	— %	— %	— %	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	CLARK	CLARK	CLARK	JOHN	JOHN			
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	4.3 %	4.4 %	1.7 %	6.1 %	5.7 %	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	— "	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		5.3 %	5.1 %	3.6 %	8.3 %	5.1 %	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.6 %	0.9 %	5.8 %	1.9 %	0.4 %	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.5 %	2.6 %	4.2 %	5.0 %	2.3 %	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	— "	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	— "	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES %	NO %	— %	YES %	YES %	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N
		— %	— %	— %	— %	— %	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N
		— "	— "	— "	— "	— "	"	"	"

Comments: C.R. "A" #32 : CURB

C.R. "B" : 1" GAP B/T CURB TRANSITION & SIDEWALK

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 140. A	Date: SEPT. 06, 2012
Location: CLARK ALLEY B/T INDIANAPOLIS & JOHN	Surveyors: BWAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS INDIANAPOLIS NW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS PENNY PARK SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	SW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	S.S.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 140. A	Date: SEPTEMBER 06, 2012
Location: CLARK ALLEY B/T INDIANAPOLIS & JOHN	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS INDIANAPOLIS NW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS PENNY PARK SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	.25 "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.9 %	4.6 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	INDY	JOHN						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.8 %	2.8 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.9 %	4.6 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.0 %	2.7 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" # 32 : FENCE/BRICK

C.R. "B" # 32 : UTILITY POLE/FENCE/CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 141	Date: SEPTEMBER 05, 2012
Location: CLARK & INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT WELCOME SIGN SE	Curb Ramp E:
Curb Ramp B: LOOKING AT WHITING MEDICAL CENTER NE	Curb Ramp F:
Curb Ramp C: LOOKING AT 2040 INDIANAPOLIS NE	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A					
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	—	—						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	V	V	—					
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	NE	NE					
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irreguiar)	R.A.	R.A.	R.A.					
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	S.S.	S.S.					
14	What type of transit stop is there? (none, bus, other)	N	N	N					
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 141	Date: SEPTEMBER 05, 2012
Location: CLARK & INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT WELCOME SIGN SE	Curb Ramp E:
Curb Ramp B: LOOKING AT WHITING MEDICAL CENTER NE	Curb Ramp F:
Curb Ramp C: LOOKING AT 2040 INDIANAPOLIS NE	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	~~Y or N~~	~~Y or N~~	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	— %	— %	4.7 %	%	%	%	%	%
19	Is a side slope or parallel slope present?	~~Y or N~~	~~Y or N~~	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	%	%	%	%	%
		— %	— %	— %	%	%	%	%	%
20	Is there a slip-resistant surface?	~~Y or N~~	~~Y or N~~	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	CLARK	CLARK	INDY					
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	— %	— %	2.1 %	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	~~Y or N~~	~~Y or N~~	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	~~Y or N~~	~~Y or N~~	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	4.7 %	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	~~Y or N~~	~~Y or N~~	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	0.1 %	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	~~Y or N~~	~~Y or N~~	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	1.0 "	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 142	Date: SEPTEMBER 05, 2012
Location: CLARK ALLEY B/T INDIANAPOLIS & JOHN	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS JOHN STREET SE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS INDIANAPOLIS NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	NE						
7	What is the Geometry of the intersection? (Right Angie, T,Y,Skewed, or Irreguiar)	R.A.	R.A.						
8	Is there a pedestrian island or right turn iane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 142	Date: SEPTEMBER 05, 2012
Location: CLARK ALLEY B/T INDIANAPOLIS & JOHN	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS JOHN STREET SE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS INDIANAPOLIS NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	1.8 %	0.2 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	JOHN	INDY						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less).	0.1 %	0.2 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.8 %	0.2 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.8 %	2.4 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" # 32 : WALL/GRASS
C.R. "B" # 32 : GRASS

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 143	Date: OCTOBER 02, 2012
Location: WHITE OAK ALLEY B/T 121ST & STEIBER	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS 121ST SW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS STEIBER NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	NW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 143	Date: OCTOBER 02, 2012
Location: WHITE OAK ALLEY B/T 121ST & STEIBER	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS 121ST SW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS STEIBER NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25 "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	3.5 %	4.3 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	121	STE-IBER						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.7 %	1.8 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.1 %	4.3 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.8 %	5.1 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" #32: DRIVEWAY/GARAGE

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 144	Date: OCTOBER 02, 2012
Location: WHITE OAK & STEIBER	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 1546 STEIBER	NW	Curb Ramp E: LOOKING AT 1546 STEIBER	SE
Curb Ramp B: LOOKING AT 2120 SCHRAGE	NW	Curb Ramp F: LOOKING AT 2120 SCHRAGE	SE
Curb Ramp C: LOOKING AT 1547 STEIBER	SW	Curb Ramp G: LOOKING AT 1547 STEIBER	NE
Curb Ramp D: LOOKING AT PARK	SW	Curb Ramp H: LOOKING AT PARK	NE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	— "	— "	— "	— "
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A	A	A	A
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	—
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NW	SW	SW	SE	SE	NE	NE
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	N
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	— "	— "	— "	— "
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	— "	— "	— "	— "

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 144	Date: OCTOBER 02, 2012
Location: WHITE OAK & STEIBER	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 1546 STEIBER	NW	Curb Ramp E: LOOKING AT 1546 STEIBER	SE
Curb Ramp B: LOOKING AT 2120 SCHRAGE	NW	Curb Ramp F: LOOKING AT 2120 SCHRAGE	SE
Curb Ramp C: LOOKING AT 1547 STEIBER	SW	Curb Ramp G: LOOKING AT 1547 STEIBER	NE
Curb Ramp D: LOOKING AT PARK	SW	Curb Ramp H: LOOKING AT PARK	NE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25 "	.50 "	.25 "	.50 "	.75 "	.25 "	— "	.25 "
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	3.0 %	3.0 %	8.5 %	8.7 %	2.6 %	3.7 %	6.2 %	5.0 %
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	6.6 %	6.6 %	14.6 %	14.6 %	— %	— %
		— %	— %	— %	— %	— %	— %	— %	— %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	STEI-BER	W.O.	STE-IBER	W.O	W.O.	STE-IBER	W.O.	STE-IBER
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	4.2 %	1.7 %	8.5 %	5.2 %	6.0 %	5.6 %	3.0 %	2.1 %
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	— "	— "
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.0 %	3.0 %	8.5 %	8.7 %	2.6 %	3.7 %	6.2 %	5.0 %
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.1 %	0.1 %	0.6 %	3.6 %	0.9 %	0.9 %	1.3 %	1.3 %
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.5 %	3.2 %	2.8 %	4.1 %	4.8 %	3.0 %	3.0 %	2.6 %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	.5 "	.5 "	.5 "	— "	— "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	— "	— "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	YES %	YES %	NO %	NO %	— %	— %
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
		— %	— %	— %	— %	— %	— %	— %	— %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
		— "	— "	— "	— "	— "	— "	— "	— "

Comments: C.R. "D" # 27: LOW CURB TRANSITION

C.R. "E" # 27: HIGH CURB TRANSITION E/F: CRACKED C.R.

C.R. "F" # 27: HIGH CURB TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 145	Date: OCTOBER 02, 2012
Location: SCHRAGE & STEIBER	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT PARK NW	Curb Ramp E:
Curb Ramp B: LOOKING AT 2120 SCHRAGE SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	70 "	70 "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	SW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	S.S.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 145	Date: OCTOBER 02, 2012
Location: SCHRAGE & STEIBER	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT PARK NW	Curb Ramp E:
Curb Ramp B: LOOKING AT 2120 SCHRAGE SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25 "	.25 "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	1.2 %	1.2 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	5.4 %	— %	%	%	%	%	%	%
		5.3 %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	STE-IBER	STE-IBER						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.2 %	0.3 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.2 %	1.2 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.2 %	1.8 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.5 %	2.1 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 146	Date: OCTOBER 02, 2012
Location: WHITE OAK ALLEY SOUTH OF STEIBER	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS STEIBER SW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS INDIANAPOLIS NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	NW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 146	Date: OCTOBER 02, 2012
Location: WHITE OAK ALLEY SOUTH OF STEIBER	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS STEIBER SW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS INDIANAPOLIS NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	.25 "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.7 %	1.8 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	STE-IBER	INDY						
22	What is the slope of the transition to the sidewalk? (should be 5% or less)	0.8 %	2.5 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.7 %	1.8 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.7 %	0.1 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction of grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "B" #32: GARAGE/DRIVEWAY

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 147	Date:
Location: STEIBER ALLEY EAST OF NEW YORK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS WHITE OAK	NW	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS NEW YORK	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS NEW YORK	SE	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS WHITE OAK	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C	C	C				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, Is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NE	SE	SW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 147	Date:
Location: STEIBER ALLEY EAST OF NEW YORK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS WHITE OAK	NW	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS NEW YORK	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS NEW YORK	SE	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS WHITE OAK	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	2.7 %	1.8 %	0.5 %	0.9 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	W.O.	N.Y.	N.Y.	W.O.				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.2 %	1.2 %	0.3 %	0.4 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.7 %	1.8 %	0.5 %	0.9 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.6 %	2.0 %	1.1 %	3.6 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "B" #32: FENCE / GRASS
C.R. "C" #32: LANDSCAPE / GRASS
C.R. "D" #32: DRIVEWAY

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 148	Date:
Location: STEIBER & NEW YORK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT EMPTY LOT	SE	Curb Ramp E: LOOKING AT EMPTY LOT	NW
Curb Ramp B: LOOKING AT 1446 STEIBER	SE	Curb Ramp F: LOOKING AT 1446 STEIBER	NW
Curb Ramp C: LOOKING AT 2201 NEW YORK	NE	Curb Ramp G: LOOKING AT 2120 NEW YORK	SW
Curb Ramp D: LOOKING AT 2120 NEW YORK	NE	Curb Ramp H: LOOKING AT 2201 NEW YORK	SW

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	— "	— "	— "	— "
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A	A	A	A
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	—
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SE	NE	NE	NW	NW	SW	SW
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	N
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	— "	— "	— "	— "
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	— "	— "	— "	— "

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 148	Date:
Location: STEIBER & NEW YORK	Surveyors: B. WAJVODA

Describe each curb ramp's location:

Curb Ramp A: LOOKING AT EMPTY LOT	SE	Curb Ramp E: LOOKING AT EMPTY LOT	NW
Curb Ramp B: LOOKING AT 1446 STEIBER	SE	Curb Ramp F: LOOKING AT 1446 STEIBER	NW
Curb Ramp C: LOOKING AT 2201 NEW YORK	NE	Curb Ramp G: LOOKING AT 2120 NEW YORK	SW
Curb Ramp D: LOOKING AT 2120 NEW YORK	NE	Curb Ramp H: LOOKING AT 2201 NEW YORK	SW

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25"	.25"	.25"	.25"	1.0"	.50"	.50"	.25"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.8%	1.4%	3.2%	0.6%	2.1%	3.6%	2.2%	0.7%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	9.2%	9.2%	5.9%	5.9%	14.2%	14.2%	6.4%	6.4%
		—%	—%	—%	—%	—%	—%	—%	—%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	STE-IBER	N.Y.	STE-IBER	N.Y.	N.Y.	STE-IBER	STE-IBER	N.Y.
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	5.0%	3.1%	3.2%	2.9%	4.1%	7.6%	2.7%	5.7%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		—"	—"	—"	—"	—"	—"	—"	—"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.8%	1.4%	3.2%	0.6%	2.1%	3.6%	2.2%	0.7%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.2%	0.2%	2.0%	2.0%	1.2%	1.2%	0.2%	0.2%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.5%	2.6%	1.8%	3.9%	7.0%	4.4%	3.1%	1.9%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		—"	—"	—"	—"	—"	—"	—"	—"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		—"	—"	—"	—"	—"	—"	—"	—"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES %	YES %	YES %	YES %	NO %	NO %	YES %	YES %
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
		—%	—%	—%	—%	—%	—%	—%	—%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
		—"	—"	—"	—"	—"	—"	—"	—"

Comments: C/D: GAP BETWEEN SIDEWALK AND CURB (1+ IN.)

PLANT/WEED OVER GROWTH

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 149	Date:
Location: NEW YORK ALLEY SOUTH OF STEIBER	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS STEIBER	SE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS INDIANAPOLIS	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS INDIANAPOLIS	NW	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS STEIBER	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C	C	C				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	NE	NW	SW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	IRR.	IRR.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	N.C.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 149	Date:
Location: NEW YORK ALLEY SOUTH OF STEIBER	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS STEIBER	SE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS INDIANAPOLIS	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS INDIANAPOLIS	NW	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS STEIBER	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	4.8 %	5.8 %	7.5 %	3.0 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	STE-IBER	INDY	INDY	STE-IBER				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	3.2 %	3.9 %	5.6 %	2.4 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		4.8 %	5.8 %	7.5 %	3.0 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
		3.2 %	2.7 %	2.7 %	4.3 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" #32: FENCE/CURB
C.R. "B" #32: FENCE/CURB
C.R. "C" #32: GRASS/CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 150	Date:
Location: SCHRAGE & 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS BASEBALL FIELD SW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS MEMORIAL SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	B	B						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	T.C.	T.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments: C.R. "B" #9: UTILITY POLE

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 150	Date:
Location SCHRAGE & 119th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS BASEBALL FIELD SW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS MEMORIAL SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	4.4 %	4.5 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	SCH-RAGE	SCH-RAGE						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	5.3 %	6.6 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.4 %	4.5 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.3 %	2.9 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.5 %	1.5 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: CRACKS IN SIDEWALK SLAB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 151	Date:
Location: STEIBER ALLEY B/T INDIANAPOLIS & NEW YORK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS NEW YORK	NW	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS INDIANAPOLIS	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS INDIANAPOLIS	SE	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS NEW YORK	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C	C	C				
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NE	SE	SW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	IRR.	IRR.	IRR.	IRR.				
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 151	Date:
Location: STEIBER ALLEY B/T INDIANAPOLIS & NEW YORK	Surveyors: B.WAJVODA

Describe each curb ramp's location:		
Curb Ramp A: LOOKING TOWARDS NEW YORK	NW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS INDIANAPOLIS	NE	Curb Ramp F:
Curb Ramp C: LOOKING TOWARDS INDIANAPOLIS	SE	Curb Ramp G:
Curb Ramp D: LOOKING TOWARDS NEW YORK	SW	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25"	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.4 %	0.1 %	0.5 %	0.2 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	N.Y.	INDY	INDY	N.Y.				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.2 %	2.3 %	1.6 %	0.6 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.4 %	0.1 %	0.5 %	0.2 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.6 %	4.1 %	1.3 %	2.0 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" # 32: BUILDING/GRASS
C.R. "B" # 32: FENCE/GRASS
C.R. "C" # 32: FENCE/GRASS

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 152	Date:
Location: STEIBER & INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT SAN LUIS	SE	Curb Ramp E:	
Curb Ramp B: LOOKING AT EMPTY LOT	SE	Curb Ramp F:	
Curb Ramp C: LOOKING AT EMPTY LOT	NE	Curb Ramp G:	
Curb Ramp D: LOOKING AT 2203 INDIANAPOLIS	NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SE	NE	NE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.	S.S.	S.S.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 152	Date:
Location: STEIBER & INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT SAN LUIS SE	Curb Ramp E:
Curb Ramp B: LOOKING AT EMPTY LOT SE	Curb Ramp F:
Curb Ramp C: LOOKING AT EMPTY LOT NE	Curb Ramp G:
Curb Ramp D: LOOKING AT 2203 INDIANAPOLIS NE	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25 "	.25 "	.25 "	.25 "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	4.5 %	4.5 %	1.3 %	2.3 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	STE-IBER	INDY	INDY	STE-IBER				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.5 %	1.0 %	1.4 %	3.9 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.5 %	4.5 %	1.3 %	2.3 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.7 %	1.7 %	0.2 %	0.2 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.6 %	0.5 %	2.1 %	3.7 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 153	Date:
Location: WHITE OAK & INDIANAPOLIS NORTH SIDE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT K&S TIRE SHOP NE	Curb Ramp E:
Curb Ramp B:	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	"	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A							
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—							
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE							
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.							
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.							
14	What type of transit stop is there? (none, bus, other)	N							
15	What are the dimensions of any common landing for two curb ramps?	— "	"	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	"	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 153	Date:
Location: WHITE OAK & INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT K & S TIRE SHOP NE	Curb Ramp E:
Curb Ramp B:	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	"	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	7.9 %	%	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	%	%	%	%	%	%	%
		— %	%	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	W.O.							
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.5 %	%	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	"	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		7.9 %	%	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.6 %	%	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.1 %	%	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	"	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	"	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	%	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	%	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	"	"	"	"	"	"	"

Comments: C.R. "A" #32: GRASS/GARBAGE CANS

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 154	Date:
Location: WHITE OAK & INDIANAPOLIS SOUTH SIDE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 2350 WHITE OAK SE	Curb Ramp E:
Curb Ramp B: LOOKING AT YARD SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments: C.R. "B" #9: S.S.

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 154	Date:
Location: WHITE OAK & INDIANAPOLIS SOUTH SIDE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 2350 WHITE OAK SE	Curb Ramp E:
Curb Ramp B: LOOKING AT YARD SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	.25 "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	6.1 %	4.2 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	W.O	W.O.						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	3.3 %	2.8 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		6.1 %	4.2 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.9 %	4.5 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.2 %	1.9 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction of grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: A LOT OF DEBRIS IN CURB RAMPS
C.R. "B" # 32: S.S.

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 155	Date:
Location: SCHRAGE & INDIANAPOLIS NORTH SIDE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS BIZIK GLASS BLOCK NW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS JOHNS PIZZA NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	73 "	73 "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.							
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	T.C.	T.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 155	Date:
Location: SCHRAGE & INDIANAPOLIS NORTH SIDE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS BIZIK GLASS BLOCK NW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS JOHNS PIZZA NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	.50 "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	2.7 %	9.4 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	6.9 %	— %	%	%	%	%	%	%
		0.4 %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	SCH-RAGE	SCH-RAGE						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	— %	9.2 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.7 %	9.4 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.5 %	1.2 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.7 %	3.9 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	.50 "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "B" #27: HIGH CURB TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 156	Date:
Location: SCHRAGE & INDIANAPOLIS SOUTH WEST SIDE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS HAPPY JACKS SW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS JOHNS PIZZA SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	T.C.	T.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 156	Date:
Location: SCHRAGE & INDIANAPOLIS SOUTH WEST SIDE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS HAPPY JACKS SW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS JOHNS PIZZA SW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.50 "	.50 "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	3.0 %	3.0 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	5.0 % 4.1 %	5.0 % 4.1 %	% %	% %	% %	% %	% %	% %
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	INDY	INDY						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	4.5 %	4.5 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N — "	(Y) or N — "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
24	Does CR have a running slope of 8.33% or less?	(Y) or N 3.0 %	(Y) or N 3.0 %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
25	Does CR have a cross slope of 2% or less?	(Y) or N 1.8 %	(Y) or N 1.8 %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
26	Does CR have a gutter slope of 5% or less?	(Y) or N 2.7 %	(Y) or N 2.7 %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N — "	(Y) or N — "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N — "	(Y) or N — "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES %	YES %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ — %	~~Y or N~~ — %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %	Y or N %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ — "	~~Y or N~~ — "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "	Y or N "

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 157	Date:
Location: WHITE OAK ALLEY SOUTH OF INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: NO SIDEWALK PRESENT	Curb Ramp E:
Curb Ramp B:	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	"	"	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)								
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?								
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)								
7	What is the Geometry of the Intersection? (Right Angle, T,Y,Skewed, or Irregular)								
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)								
14	What type of transit stop is there? (none, bus, other)								
15	What are the dimensions of any common landing for two curb ramps?	"	"	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	"	"	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 157	Date:
Location: WHITE OAK ALLEY SOUTH OF INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: NO SIDEWALK PRESENT	Curb Ramp E:
Curb Ramp B:	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	"	"	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	%	%	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	%	%	%	%	%	%	%	%
		%	%	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?								
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	%	%	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	%	%	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		%	%	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		"	"	"	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 158	Date:
Location: SCHRAGE ALLEY SOUTH OF INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS INDIANAPOLIS SW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS 125th NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	NW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 158	Date:
Location: SCHRAGE ALLEY SOUTH OF INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS INDIANAPOLIS SW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS 125th NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	1.4 %	5.4 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	INDY	125						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.9 %	2.4 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.4 %	5.4 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.3 %	0.5 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" #32: LANDSCAPING / GRASS
C.R. "B" #32: FENCE / GRASS

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 159	Date:
Location: SCHRAGE & INDIANAPOLIS SOUTH EAST SIDE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS EMPTY LOT SE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS BIZIK GLASS BLOCK SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	T.C.	T.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 159	Date:
Location: SCHRAGE & INDIANAPOLIS SOUTH EAST SIDE	Surveyors: B WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS EMPTY LOT SE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS BIZIK GLASS BLOCK SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	1.0 "	1.25 "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	1.4 %	0.5 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	1.0 %	1.0 %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	SCH-RAGE	INDY						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.1 %	0.4 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.4 %	0.5 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.0 %	1.0 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.5 %	1.5 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES %	YES %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 160	Date:
Location: SCHRAGE ALLEY SOUTH EAST OF INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS 125th NE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS INDIANAPOLIS SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	SE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 160	Date:
Location: SCHRAGE ALLEY SOUTH EAST OF INDIANAPOLIS	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS 125th	NE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS INDIANAPOLIS	SE	Curb Ramp F:	
Curb Ramp C:		Curb Ramp G:	
Curb Ramp D:		Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.1 %	1.3 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	125	INDY						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.3 %	2.8 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.1 %	1.3 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.2 %	1.4 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" #27: GRASS/GRAVEL

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 161	Date:
Location: SCHRAGE & 125th SOUTH SIDE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT PARK SW	Curb Ramp E:
Curb Ramp B: LOOKING AT EMPTY LOT NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.		B.C.						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	NW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	IRR.	IRR.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 161	Date:
Location: SCHRAGE & 125th SOUTH SIDE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT PARK SW	Curb Ramp E:
Curb Ramp B: LOOKING AT EMPTY LOT NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.75"	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.3 %	4.0 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	8.2 %	%	%	%	%	%	%
		— %	4.0 %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	12.5	125						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	3.3 %	— %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.3 %	4.0 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.2 %	0.7 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		7.6 %	4.2 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	YES %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R."A" #32: FENCE / CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 162	Date:
Location: SCHRAGE & 125th NORTH SIDE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS PARK NW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS HOUSE NW	Curb Ramp F:
Curb Ramp C: LOOKING TOWARDS 2454 SCHRAGE NE	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A					
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.		—						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	V	—					
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NW	NE					
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.					
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If Island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	N.C.					
14	What type of transit stop is there? (none, bus, other)	N	N	N					
15	What are the dimensions of any common landing for two curb ramps?	72 x 72 "	72 x 72 "	— "	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 162	Date:
Location: SCHRAGE & 125th NORTH SIDE	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS PARK	NW	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS HOUSE	NW	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS 2454 SCHRAGE	NE	Curb Ramp G:	
Curb Ramp D:		Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25 "	— "	— "	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	8.3 %	— %	7.7 %	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	11.2 %	%	%	%	%	%
		— %	— %	6.8 %	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	SCH-RAGE	125	SCH-RAGE					
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	6.6 %	— %	7.4 %	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		8.3 %	— %	7.7 %	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.7 %	— %	0.5 %	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.6 %	— %	7.6 %	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	1.0 "	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	NO %	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	"	"	"	"	"

Comments: C.R. "A" #32: LANDSCAPE/GRASS

C.R. "C" #27: HIGH CURB TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 163	Date:
Location: 125th ALLEY B/T WHITE OAK & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS SCHRAGE SW	Curb Ramp E:
Curb Ramp B:	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	"	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C							
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	—							
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—							
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW							
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.							
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.							
14	What type of transit stop is there? (none, bus, other)	N							
15	What are the dimensions of any common landing for two curb ramps?	— "	"	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	"	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 163	Date:
Location: 125th ALLEY B/T WHITE OAK & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS SCHRAGE SW	Curb Ramp E:
Curb Ramp B:	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	"	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.0 %	%	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	%	%	%	%	%	%	%
		— %	%	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	SCH-RAGE							
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.3 %	%	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	"	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.0 %	%	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.3 %	%	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	%	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	"	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	"	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	%	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	%	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	"	"	"	"	"	"	"

Comments: C.R. "A" #32: DRIVEWAY

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 164	Date:
Location: 125th & WHITE OAK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT FENCED LOT	SE	Curb Ramp E:	
Curb Ramp B: LOOKING AT 2454 SCHRAGE	SE	Curb Ramp F:	
Curb Ramp C: LOOKING AT HOUSE	NE	Curb Ramp G:	
Curb Ramp D: LOOKING AT EMPTY LOT	NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.			B.C.	B.C.				
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SE	NE	NE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	IRR.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	57 x 75"	57 x 75"	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 164	Date:
Location: 125th & WHITE OAK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT FENCE	SE	Curb Ramp E:	
Curb Ramp B: LOOKING AT 2454 SCHRAGE	SE	Curb Ramp F:	
Curb Ramp C: LOOKING AT HOUSE	NE	Curb Ramp G:	
Curb Ramp D: LOOKING AT EMPTY LOT	NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25 "	.25 "	.25 "	.75 "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	4.1 %	2.8 %	2.3 %	5.0 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	9.5 %	9.5 %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	W.O.	125	125	W.O.				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	3.7 %	2.4 %	4.0 %	5.5 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.1 %	2.8 %	2.3 %	5.0 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.0 %	1.7 %	4.7 %	2.4 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		9.5 %	8.5 %	4.0 %	7.1 %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	.75 "	.75 "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	YES %	YES %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "C" #27: LOW CURB TRANSITION C.R. "D" #27: LOW CURB TRANSITION
C.R. "C" #32: S.S.
C/D: CRACK IN CURB RAMP

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 165	Date:
Location: 126th & BIRCH	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS BIRCH SE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS 126th SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	59 x 60"	59 x 60"	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 165	Date:
Location: 126th & BIRCH	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS BIRCH SE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS 126th SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.25"	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	4.6 %	2.2 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	BIRCH	126						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	4.5 %	0.2 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.6 %	2.2 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.8 %	0.0 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.4 %	1.5 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 166	Date:
Location: 126th ALLEY B/T BIRCH & WHITE OAK	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS WHITEOAK SW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS BIRCH SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	S.S.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 166	Date:
Location: 126th ALLEY B/T BIRCH & WHITE OAK	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS WHITE OAK SW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS BIRCH SE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	.25 "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.6 %	0.2 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	W.O.	BIRCH						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.6 %	0.5 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.6 %	0.2 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.2 %	1.6 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" #32: GRASS/FENCE

C.R. "B" #32: GRASS/FENCE

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 167	Date:
Location: 126th & WHITE OAK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT EMPTY LOT	SW	Curb Ramp E: LOOKING AT HOUSE	NE
Curb Ramp B: LOOKING AT HOUSE	SW	Curb Ramp F: LOOKING AT EMPTY LOT	NE
Curb Ramp C: LOOKING AT 2604 WHITE OAK	SE	Curb Ramp G:	
Curb Ramp D: LOOKING AT EMPTY LOT	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	— "	— "	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A	A		
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.			B.C.	B.C.				
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—		
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SW	SE	SE	NE	NE		
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	IRR.	R.A.	R.A.	R.A.	R.A.		
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.		
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N		
15	What are the dimensions of any common landing for two curb ramps?	60 x 60 "	60 x 60 "	— "	— "	— "	— "	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	— "	— "	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 167	Date:
Location: 126th & WHITE OAK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT EMPTY LOT	SW	Curb Ramp E: LOOKING AT HOUSE	NE
Curb Ramp B: LOOKING AT HOUSE	SW	Curb Ramp F: LOOKING AT EMPTY LOT	NE
Curb Ramp C: LOOKING AT 2604 WHITE OAK	SE	Curb Ramp G:	
Curb Ramp D: LOOKING AT EMPTY LOT	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	.50 "	.25 "	.25 "	— "	.25 "	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	6.0 %	5.6 %	3.8 %	2.6 %	2.0 %	4.8 %	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— % / — %	— % / — %	6.0 % / — %	6.0 % / — %	7.2 % / — %	7.2 % / — %	% / %	% / %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	126	W.O.	W.O.	126	126	W.O.		
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	3.3 %	1.3 %	3.6 %	3.4 %	2.0 %	4.9 %	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / "	Y or N / "
24	Does CR have a running slope of 8.33% or less?	Y or N / 6.0 %	Y or N / 5.6 %	Y or N / 3.8 %	Y or N / 2.6 %	Y or N / 2.0 %	Y or N / 4.8 %	Y or N / %	Y or N / %
25	Does CR have a cross slope of 2% or less?	Y or N / 0.4 %	Y or N / 1.1 %	Y or N / 1.1 %	Y or N / 1.1 %	Y or N / 0.5 %	Y or N / 0.5 %	Y or N / %	Y or N / %
26	Does CR have a gutter slope of 5% or less?	Y or N / 1.8 %	Y or N / 7.1 %	Y or N / 0.9 %	Y or N / 5.7 %	Y or N / 0.7 %	Y or N / 2.0 %	Y or N / %	Y or N / %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / "	Y or N / "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / — "	Y or N / "	Y or N / "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	YES %	YES %	YES %	YES %	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	~~Y or N~~ / — %	Y or N / %	Y or N / %
32	If no flared sides, is there an obstruction on grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	~~Y or N~~ / — "	Y or N / "	Y or N / "

Comments: C.R. "C": GAP BETWEEN RAMP AND CURB (2+ IN.)
C.R. "E": GAP BETWEEN RAMP AND CURB (2+ IN.)

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 168	Date:
Location: 126th ALLEY B/T WHITE OAK & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS SCHRAGE	NW	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS WHITE OAK	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS WHITE OAK	SE	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS SCHRAGE	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C	C	C				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NE	SE	SW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	S.S.						
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 168	Date:
Location: 126th ALLEY B/T WHITE OAK & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS SCHRAGE	NW	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS WHITE OAK	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS WHITE OAK	SE	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS SCHRAGE	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	4.5 %	6.5 %	0.1 %	4.1 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	SCH-RAGE	W.O.	W.O.	SCH-RAGE				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	4.9 %	6.9 %	1.4 %	4.3 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.5 %	6.5 %	0.1 %	4.1 %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.5 %	3.2 %	3.1 %	2.8 %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" # 32: CURB / GRASS
C.R. "B" # 32: CURB / GRASS
C.R. "C" # 32: FENCE / CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 169	Date:
Location: 126th & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT EMPTY LOT (SE)	NE	Curb Ramp E: LOOKING AT EMPTY LOT (SE)	SW
Curb Ramp B: LOOKING AT EMPTY LOT (NW)	NE	Curb Ramp F: LOOKING AT 2602 SCHRAGE	NW
Curb Ramp C: LOOKING AT EMPTY LOT (NE)	SE	Curb Ramp G: LOOKING AT EMPTY LOT (NE)	NW
Curb Ramp D: LOOKING AT EMPTY LOT (NW)	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	— "	— "	— "	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A	A	A	
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.		B.C.	B.C.	B.C.	B.C.	
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NE	SE	SW	SW	NW	NW	
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	N.C.	S.S.	S.S.	N.C.	N.C.	
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	— "	— "	— "	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	— "	— "	— "	"

Comments: C.R. "A": CRACK ACROSS CURB RAMP

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 169	Date:
Location: 126th & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT EMPTY LOT (SE)	NE	Curb Ramp E: LOOKING AT EMPTY LOT (SE)	SW
Curb Ramp B: LOOKING AT EMPTY LOT (NW)	NE	Curb Ramp F: LOOKING AT 2602 SCHRAGE	NW
Curb Ramp C: LOOKING AT EMPTY LOT (NE)	SE	Curb Ramp G: LOOKING AT EMPTY LOT (NE)	NW
Curb Ramp D: LOOKING AT EMPTY LOT (NW)	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	.25 "	.50 "	.25 "	.25 "	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	5.3 %	8.4 %	5.2 %	0.8 %	0.9 %	4.7 %	0.9 %	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	14.0 % — %	14.0 % — %	— % — %	3.3 % 5.6 %	3.3 % 5.6 %	4.6 % 5.2 %	4.6 % 5.2 %	% %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	126	SCH-RAGE	126	126	SCH-RAGE	126	SCH-RAGE	
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	5.9 %	12.0 %	5.4 %	1.9 %	1.3 %	4.4 %	4.0 %	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N "
24	Does CR have a running slope of 8.33% or less?	Y or N 5.3 %	Y or N 8.4 %	Y or N 5.2 %	Y or N 0.8 %	Y or N 0.9 %	Y or N 4.7 %	Y or N 0.9 %	Y or N %
25	Does CR have a cross slope of 2% or less?	Y or N 3.5 %	Y or N 3.5 %	Y or N 1.8 %	Y or N 1.9 %	Y or N 0.6 %	Y or N 2.4 %	Y or N 2.4 %	Y or N %
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	Y or N 5.4 %	Y or N 1.3 %	Y or N 2.0 %	Y or N 5.8 %	Y or N %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N 1.0 "	Y or N 1.0 "	Y or N 1.0 "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	NO %	NO %	— %	YES %	YES %	YES %	YES %	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	Y or N %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	Y or N "

Comments: C.R. "A" #27: HIGH CURB TRANSITION ; #32: CURB/GRASS
C.R. "B" #27: HIGH CURB TRANSITION ; #32: CURB/GRASS
C.R. "C" #27: HIGH CURB TRANSITION ; #32: CURB/GRASS

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 170	Date:
Location: 127th & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS HOUSE	NW	Curb Ramp E: LOOKING TOWARDS EMPTY LOT	SE
Curb Ramp B: LOOKING TOWARDS 2648 SCHRAGE	SW	Curb Ramp F: LOOKING TOWARDS 2701 SCHRAGE	NE
Curb Ramp C: LOOKING TOWARDS 2701 SCHRAGE	SW	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS 2700 SCHRAGE	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	— "	— "	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A	A		
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—		
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	SW	SW	SE	SE	NE		
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.					
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	S.S.	S.S.					
14	What type of transit stop is there? (none, bus, other)	N	N	N					
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 170	Date:
Location: 127th & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS 2700 SCHRAGE	NW	Curb Ramp E: LOOKING TOWARDS EMPTY LOT	SE
Curb Ramp B: LOOKING TOWARDS 2648 SCHRAGE	SW	Curb Ramp F: LOOKING TOWARDS 2701 SCHRAGE	NE
Curb Ramp C: LOOKING TOWARDS 2701 SCHRAGE	SW	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS 2700 SCHRAGE	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	— "	— "	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	3.4 %	3.3 %	3.7 %	6.0 %	4.3 %	3.8 %	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	— %	— %	%	%
		— %	— %	— %	— %	— %	— %	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	127	127	SCH-RAGE	SCH-RAGE	127	127		
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	1.3 %	0.7 %	4.1 %	— %	1.5 %	3.7 %	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.4 %	3.3 %	3.7 %	6.0 %	4.3 %	3.8 %	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		9.5 %	1.9 %	0.5 %	1.2 %	4.3 %	5.0 %	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
		— %	— %	— %	— %	— %	— %	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.0 "	1.0 "	.50 "	1.0 "	.50 "	1.0 "	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	— %	— %	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
		— %	— %	— %	— %	— %	— %	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
		— "	— "	— "	— "	— "	— "	— "	— "

Comments: C.R. "A" #27: HIGH CURB TRANSITION
C.R. "A" #32: GRASS/CURB
C.R. "B" #27: HIGH CURB TRANSITION
C.R. "D" #27: HIGH CURB TRANSITION
C.R. "E" #27: LOW C.R. TO CURB
C.R. "D" #32: FENCE/CURB
C.R. "F" #27: HIGH CURB TRANSIT
C.R. "F" #32: GRASS/CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 171	Date:
Location: 127th ALLEY B/T WHITE OAK & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:		
Curb Ramp A: LOOKING TOWARDS WHITE OAK	NE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS SCHRAGE	NW	Curb Ramp F:
Curb Ramp C: LOOKING TOWARDS SCHRAGE	SW	Curb Ramp G:
Curb Ramp D: LOOKING TOWARDS WHITE OAK	SE	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.			—	—				
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	V	V				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NW	SW	SE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	—	—				
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	N.C.	—	—				
14	What type of transit stop is there? (none, bus, other)	N	N	—	—				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments: C.R."C": 7" STEP DOWN FROM SIDEWALK TO ALLEY
C.R."D": 8" STEP DOWN FROM SIDEWALK TO ALLEY

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 171	Date:
Location: 127th ALLEY B/T WHITE OAK & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS WHITE OAK	NE	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS SCHRAGE	NW	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS SCHRAGE	SW	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS WHITE OAK	SE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	15.0 %	1.2 %	— %	— %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— % — %	— % — %	— % — %	— % — %	% %	% %	% %	% %
20	Is there a slip-resistant surface?	Y or N	Y or N	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	W.O.	SCH-RAGE	—	—				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	7.3 %	0.4 %	— %	— %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N — "	Y or N — "	~~Y or N~~ — "	~~Y or N~~ — "	Y or N "	Y or N "	Y or N "	Y or N "
24	Does CR have a running slope of 8.33% or less?	Y or N 15.0 %	Y or N 1.2 %	~~Y or N~~ — %	~~Y or N~~ — %	Y or N %	Y or N %	Y or N %	Y or N %
25	Does CR have a cross slope of 2% or less?	Y or N 0.3 %	Y or N 1.3 %	~~Y or N~~ — %	~~Y or N~~ — %	Y or N %	Y or N %	Y or N %	Y or N %
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	Y or N %	Y or N %	Y or N %	Y or N %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N — "	Y or N — "	~~Y or N~~ — "	~~Y or N~~ — "	Y or N "	Y or N "	Y or N "	Y or N "
28	Does CR have detectable warnings?	Y or N	Y or N	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N — "	Y or N — "	~~Y or N~~ — "	~~Y or N~~ — "	Y or N "	Y or N "	Y or N "	Y or N "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	Y or N %	Y or N %	Y or N %	Y or N %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	Y or N "	Y or N "	Y or N "	Y or N "

Comments: C.R. "A" #32: DRIVEWAY

C.R. "B" #32: DRIVEWAY

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 172	Date:
Location: 127th & WHITE OAK	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 2706 WHITE OAK SE	Curb Ramp E: LOOKING AT HOUSE NW
Curb Ramp B: LOOKING AT HOUSE SE	Curb Ramp F: LOOKING AT 2706 WHITE OAK NW
Curb Ramp C: LOOKING AT 2705 WHITE OAK NE	Curb Ramp G:
Curb Ramp D: LOOKING AT HOUSE NE	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	— "	— "	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A	A		
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—		
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SE	NE	NE	NW	NW		
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	IRR.	IRR.	R.A.		
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.	S.S.	S.S.		
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N		
15	What are the dimensions of any common landing for two curb ramps?	68 x 71 "	68 x 71 "	69 x 71 "	69 x 71 "	60 x 60 "	60 x 60 "	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	— "	— "	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 172	Date:
Location: 127th & WHITE OAK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 2706 WHITE OAK	SE	Curb Ramp E: LOOKING AT HOUSE	NW
Curb Ramp B: LOOKING AT HOUSE	SE	Curb Ramp F: LOOKING AT 2706 WHITE OAK	NW
Curb Ramp C: LOOKING AT 2705 WHITE OAK	NE	Curb Ramp G:	
Curb Ramp D: LOOKING AT HOUSE	NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.50"	.50"	.50"	.25"	.25"	—"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	4.4 %	4.8 %	8.2 %	11.6 %	2.3 %	5.9 %	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	— %	— %	%	%
		— %	— %	— %	— %	— %	— %	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	W.O.	127	127	W.O.	W.O.	127		
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	2.3 %	0.3 %	1.6 %	3.4 %	0.2 %	4.7 %	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		—"	—"	—"	—"	—"	—"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		4.4 %	4.8 %	8.2 %	11.6 %	2.3 %	5.9 %	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.8 %	0.6 %	0.8 %	1.9 %	4.4 %	0.4 %	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N
		2.3 %	— %	— %	5.1 %	4.0 %	3.1 %	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		.50"	—"	—"	.25"	—"	—"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		—"	—"	—"	—"	—"	—"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	— %	— %	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
		— %	— %	— %	— %	— %	— %	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N
		—"	—"	—"	—"	—"	—"	"	"

Comments: C.R. "A" #27: HIGH CURB TRANSITION
C.R. "D" #27: HIGH CURB TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 173	Date:
Location: 127th ALLEY B/T BIRCH & WHITE OAK	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS BIRCH NE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS WHITE OAK NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	S.S.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 173	Date:
Location: 127th ALLEY B/T BIRCH & WHITE OAK	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS BIRCH NE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS WHITE OAK NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.3 %	0.6 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	BIRCH	W.D.						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.3 %	0.3 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.3 %	0.6 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.7 %	3.2 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments:

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 174	Date:
Location: 127th & BIRCH	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS 127th NE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS BIRCH NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? if present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.		—						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	R						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	IRR.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	60 x 59 "	60 x 59 "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments: C.R."B" #9: UTILITY POLE

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 174	Date:
Location: 127th & BIRCH	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS 127th NE	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS BIRCH NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	(Y) or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	.75 "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	3.8 %	— %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	127	BIRCH						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	2.8 %	— %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.8 %	— %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.1 %	— %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	(Y) or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		2.2 %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or (N)	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		.50 "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	(Y) or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" #27: LOW CURB TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 175	Date:
Location: 128 ½ & WHITE OAK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT PARK	SE	Curb Ramp E:	
Curb Ramp B: LOOKING AT 2749 WHITE OAK	SE	Curb Ramp F:	
Curb Ramp C: LOOKING AT 2750 WHITE OAK	NE	Curb Ramp G:	
Curb Ramp D: LOOKING AT 2801 WHITE OAK	NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.				—				
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	V				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SE	SE	NE	NE				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	S.S.	S.S.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	62 x 72 "	62 x 72 "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 175	Date:
Location: 128th & WHITE OAK	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT PARK	SE	Curb Ramp E:	
Curb Ramp B: LOOKING AT 2749 WHITE OAK	SE	Curb Ramp F:	
Curb Ramp C: LOOKING AT 2750 WHITE OAK	NE	Curb Ramp G:	
Curb Ramp D: LOOKING AT 2801 WHITE OAK	NE	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	1.3 %	6.2 %	3.8 %	— %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	— %	— %	%	%	%	%
		— %	— %	— %	— %	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	W.O.	128	W.O.	—				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.8 %	1.6 %	1.3 %	— %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		1.3 %	6.2 %	3.8 %	— %	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		1.7 %	1.3 %	1.7 %	— %	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	~~Y or N~~	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		3.2 %	— %	1.5 %	— %	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		1.0 "	— "	2.0 "	— "	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— %	— %	— %	— %	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
		— "	— "	— "	— "	"	"	"	"

Comments: C.R. "A" #27: HIGH CURB TRANSITION
C.R. "C" #27: HIGH CURB TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 176	Date:
Location: 128th ALLEY B/T WHITE OAK & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS SCHRAGE	NW	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS WHITE OAK	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS WHITE OAK	SE	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS SCHRAGE	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A				
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—				
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NE	SE	SW				
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.				
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	S.S.	S.S.	N.C.				
14	What type of transit stop is there? (none, bus, other)	N	N	N	N				
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 176	Date:
Location: 128th ALLEY B/T WHITE OAK & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING TOWARDS SCHRAGE	NW	Curb Ramp E:	
Curb Ramp B: LOOKING TOWARDS WHITE OAK	NE	Curb Ramp F:	
Curb Ramp C: LOOKING TOWARDS WHITE OAK	SE	Curb Ramp G:	
Curb Ramp D: LOOKING TOWARDS SCHRAGE	SW	Curb Ramp H:	

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.5 %	4.4 %	2.7 %	0.7 %	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— % — %	— % — %	— % — %	— % — %	% %	% %	% %	% %
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	SCH-RAGE	W.O.	W.O.	SCH-RAGE				
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	0.6 %	4.7 %	0.1 %	0.1 %	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N — "	(Y) or N — "	(Y) or N — "	(Y) or N — "	Y or N "	Y or N "	Y or N "	Y or N "
24	Does CR have a running slope of 8.33% or less?	(Y) or N 0.5 %	(Y) or N 4.4 %	(Y) or N 2.7 %	(Y) or N 0.7 %	Y or N %	Y or N %	Y or N %	Y or N %
25	Does CR have a cross slope of 2% or less?	Y or (N) 2.6 %	(Y) or N 1.8 %	Y or (N) 5.4 %	(Y) or N 1.9 %	Y or N %	Y or N %	Y or N %	Y or N %
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	Y or N %	Y or N %	Y or N %	Y or N %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N — "	(Y) or N — "	(Y) or N — "	Y or (N) 1.0 "	Y or N "	Y or N "	Y or N "	Y or N "
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N — "	(Y) or N — "	(Y) or N — "	(Y) or N — "	Y or N "	Y or N "	Y or N "	Y or N "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	— %	— %	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	Y or N %	Y or N %	Y or N %	Y or N %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	Y or (N)	Y or (N)	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	Y or N "	Y or N "	Y or N "	Y or N "

Comments: C.R. "A" #32: DRIVEWAY

C.R. "B" #32: DRIVEWAY

C.R. "C" #32: DRIVEWAY

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 177	Date:
Location: 128th & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 2750 SCHRAGE	SW	Curb Ramp E: LOOKING AT EMPTY LOT	NE
Curb Ramp B: LOOKING AT EMPTY LOT	SW	Curb Ramp F: LOOKING AT 2750 SCHRAGE	NE
Curb Ramp C: LOOKING AT 2800 SCHRAGE	NW	Curb Ramp G: LOOKING AT EMPTY LOT	SE
Curb Ramp D: LOOKING AT EMPTY LOT	NW	Curb Ramp H: LOOKING AT 2800 SCHRAGE	SE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	— "	— "	— "	— "	— "	— "
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	A	A	A	A	A	A	A	A
1.C	Is the crosswalk aligned to the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the Intersection?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.	B.C.
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—	—	—	—	—	—	—
5	If a curb ramp is not present, and if a curb is not present, Is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	SW	SW	NW	NW	NE	NE	SE	SE
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.	R.A.
8	Is there a pedestrian island or right turn lane?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
9	Are there any obstructions or obstacles?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	S.S.	S.S.	N.C.	N.C.	S.S.	S.S.	N.C.	N.C.
14	What type of transit stop is there? (none, bus, other)	N	N	N	N	N	N	N	N
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	— "	— "	— "	— "	— "	— "
16	Is the 12 inch grooved border around all sides present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	— "	— "	— "	— "	— "	— "

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 177	Date:
Location: 128th & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:			
Curb Ramp A: LOOKING AT 2750 SCHRAGE	SW	Curb Ramp E: LOOKING AT EMPTY LOT	NE
Curb Ramp B: LOOKING AT EMPTY LOT	SW	Curb Ramp F: LOOKING AT 2750 SCHRAGE	NE
Curb Ramp C: LOOKING AT 2800 SCHRAGE	NW	Curb Ramp G: LOOKING AT EMPTY LOT	SE
Curb Ramp D: LOOKING AT EMPTY LOT	NW	Curb Ramp H: LOOKING AT 2800 SCHRAGE	SE

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	— "	— "	— "	— "	— "	— "
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	8.9 %	3.7 %	4.5 %	8.8 %	3.2 %	8.5 %	2.4 %	6.1 %
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	1.7 % — %	1.7 % — %	12.1 % — %	12.1 % — %	— % — %	— % — %	0.5 % — %	0.5 % — %
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	128	SCHRAGE	128	SCHRAGE	128	SCHRAGE	128	SCHRAGE
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	7.1 %	0.4 %	12.3 %	6.2 %	7.6 %	— %	0.2 %	— %
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N — "	Y or N 30 "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
24	Does CR have a running slope of 8.33% or less?	Y or N 8.9 %	Y or N 3.7 %	Y or N 4.5 %	Y or N 8.8 %	Y or N 3.2 %	Y or N 8.5 %	Y or N 2.4 %	Y or N 6.1 %
25	Does CR have a cross slope of 2% or less?	Y or N 1.9 %	Y or N 1.9 %	Y or N 0.9 %	Y or N 0.9 %	Y or N 1.9 %	Y or N 1.9 %	Y or N 2.4 %	Y or N 2.4 %
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N — "	Y or N .50 "	Y or N — "	Y or N — "	Y or N — "	Y or N .25 "	Y or N 1.0 "	Y or N 1.0 "
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "	Y or N — "
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES %	YES %	NO %	NO %	— %	— %	YES %	YES %
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %	~~Y or N~~ — %
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~	~~Y or N~~
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "	~~Y or N~~ — "

Comments: C.R. "B" # 27: HIGH CURB TRANSITION
C.R. "A" # 32: CURB
C.R. "B" # 32: CURB / S.S.
C.R. "D" # 32: CURB
C.R. "F" # 27: HIGH CURB TRANSITION
C.R. "E" # 32: CURB/GRASS/POLE
C.R. "G" # 27: HIGH CURB TRANSITION
C.R. "H" # 27: HIGH CURB TRANSITION
C.R. "G" # 32: GRASS/CURB/HYDRANT

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 178	Date: SEPTEMBER 20, 2012
Location: 129th & WHITE OAK	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT TANK FIELD NE	Curb Ramp E:
Curb Ramp B: LOOKING AT PARKING LOT NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.	B.C.	B.C.						
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 178	Date: SEPTEMBER 20, 2012
Location: 129th & WHITE OAK	Surveyors: B. WAJVODA

Curb Ramp A: LOOKING AT TANK FIELD NE	Curb Ramp E:
Curb Ramp B: LOOKING AT PARKING LOT NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	~~Y~~ or N	~~Y~~ or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	0.3 %	1.4 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	5.8 %	5.8 %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	129	W.O.						
22	What is the slope of the transition to the sidewalk? (should be 5% or less)	1.0 %	3.2 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.3 %	1.4 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.9 %	1.9 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.8 %	0.1 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		.25 "	.25 "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	YES %	YES %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" #27: LOW CURB TRANSITION ; #32: GRASS/CURB
C.R. "B" #27: LOW CURB TRANSITION ; #32: GRASS/CURB

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 179	Date:
Location: 129th ALLEY B/T WHITE OAK & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS SCHRAGE NW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS WHITE OAK NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 179	Date:
Location: 129th ALLEY B/T WHITE OAK & SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS SCHRAGE NW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS WHITE OAK NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	3.6 %	6.7 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	SCH-RAGE	W.O.						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	2.8 %	10.6 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.6 %	6.7 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		0.6 %	3.4 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R."A" #32: FENCE / CURB
C.R."B" #32: CURB / POLE / PARKING LOT

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 180	Date:
Location: SCHRAGE & 129th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 1611 129th NE	Curb Ramp E:
Curb Ramp B: LOOKING AT R.R. TRACKS NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B, 1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NE	NW						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	S.S.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments:

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 180	Date:
Locatic SCHRAGE & 129th	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING AT 1611 129th NE	Curb Ramp E:
Curb Ramp B: LOOKING AT R.R. TRACKS NW	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	6.1 %	1.7 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	SCH-RAGE	SCH-RAGE						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	— %	— %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		6.1 %	1.7 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.6 %	0.8 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		1.7 %	0.8 %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		.25 "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" #27: HIGH CURB TRANSITION

ADA

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 181	Date:
Location: 129th ALLEY EAST OF SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS INDIANAPOLIS NW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS SCHRAGE NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
1	Are crosswalks present at any or all crossings? If present, answer questions 1.A, 1.B,1.C.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
1.A	What is the width of the crosswalk?	— "	— "	"	"	"	"	"	"
1.B	What is the type of crosswalk? (Brick, Asphalt, Concrete, Other)	C	C						
1.C	Is the crosswalk aligned to the curb ramp?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
2	Are curb ramp(s) present at any of the corners within the intersection?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
3	What is the general description for the curb ramp? Flared, Pan, Chute, Blended Corner, or Built-Up.								
4	If a curb ramp is not present, and if a curb is present, is it vertical or rolled?	—	—						
5	If a curb ramp is not present, and if a curb is not present, is there a flush transition from the street to the sidewalk?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
6	What is the directional corner of the intersection? (NE,SE,NW,SW)	NW	NE						
7	What is the Geometry of the intersection? (Right Angle, T,Y,Skewed, or Irregular)	R.A.	R.A.						
8	Is there a pedestrian island or right turn lane?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
8.A	If island is present, are there curb ramps and push buttons?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
9	Are there any obstructions or obstacles?	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
10	Are there visual or accessible pedestrian signals?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
11	Is a sidewalk present that leads to and from the curb?	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
12	Does the crosswalk have any tactile guide strips?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
13	What type of traffic control is present? (traffic control, stop sign, yield control, or no control)	N.C.	N.C.						
14	What type of transit stop is there? (none, bus, other)	N	N						
15	What are the dimensions of any common landing for two curb ramps?	— "	— "	"	"	"	"	"	"
16	Is the 12 inch grooved border around all sides present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
16.A	If the grooved border is present, what is the width?	— "	— "	"	"	"	"	"	"

Comments: C.R. "A" #9: UTILITY POLE

Turn Over

Curb Ramps

Construction/Alteration (circle one): Before 1/26/92 After 1/26/92

Intersection #: 181	Date:
Location: 129th ALLEY EAST OF SCHRAGE	Surveyors: B. WAJVODA

Describe each curb ramp's location:	
Curb Ramp A: LOOKING TOWARDS INDIANAPOLIS NW	Curb Ramp E:
Curb Ramp B: LOOKING TOWARDS SCHRAGE NE	Curb Ramp F:
Curb Ramp C:	Curb Ramp G:
Curb Ramp D:	Curb Ramp H:

#	Curb Ramp (CR) Questions	Curb Ramp A	Curb Ramp B	Curb Ramp C	Curb Ramp D	Curb Ramp E	Curb Ramp F	Curb Ramp G	Curb Ramp H
17	Is a lip present at the bottom of the curb ramp?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
17.A	If the lip is present, what is the height to the nearest 0.25 in?	— "	— "	"	"	"	"	"	"
18	What is the percent of the main slope of the curb ramp or level landing that is adjacent to and perpendicular to the street?	3.1 %	9.0 %	%	%	%	%	%	%
19	Is a side slope or parallel slope present?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
19.A	If a side or parallel slope is present, what is the slope or each sloping side or flare parallel to the street in percent?	— %	— %	%	%	%	%	%	%
		— %	— %	%	%	%	%	%	%
20	Is there a slip-resistant surface?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
21	What is the name of the street that the curb ramp is facing or if facing the intersection?	INDY	SCH-RAGE						
22	What is the slope of the transition to the sidewalk ? (should be 5% or less)	4.2 %	9.4 %	%	%	%	%	%	%
23	Is ramp of CR at least 36" wide (not including flared sides)?	Y or (N)	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		26 "	— "	"	"	"	"	"	"
24	Does CR have a running slope of 8.33% or less?	(Y) or N	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		3.1 %	9.0 %	%	%	%	%	%	%
25	Does CR have a cross slope of 2% or less?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		10.0 %	6.6 %	%	%	%	%	%	%
26	Does CR have a gutter slope of 5% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
27	Are transitions on and off CR flush and free of abrupt level changes? Record the height of ANY level changes.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
28	Does CR have detectable warnings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
29	Can CR be blocked by legally parked cars?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
30	Is the sidewalk at the "top" of CR at least 36" wide? Should be 48"	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"
31	Does CR have flared sides? If yes, answer ONE of the next two questions. If not, skip to question 32.	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
31.A	If the sidewalk at the "top" of CR is 48" wide or more, is the slope of the flared sides 10% or less?	— %	— %	%	%	%	%	%	%
31.B	If the sidewalk at the "top" of CR is less than 48" wide, is the slope of the flared sides 8.33% or less?	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— %	— %	%	%	%	%	%	%
32	If no flared sides, is there an obstruction or grass on each side of CR that discourages pedestrians from traveling across ramp? If the CR has flared sides, skip this question.	(Y) or N	(Y) or N	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
33	If CR is built-up to the curb, is it outside the path of cars? If CR is not built-up to curb, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
34	Is ramp of CR contained in markings?	Y or (N)	Y or (N)	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
35	If corner-type CR, is bottom landing at least 48" long and contained in crosswalk? If not corner-type CR, skip this question.	~~Y or N~~	~~Y or N~~	Y or N	Y or N	Y or N	Y or N	Y or N	Y or N
		— "	— "	"	"	"	"	"	"

Comments: C.R. "A" #32: CURB / GRASS / POLE

C.R. "B" #32: CURB / DIRT